

~~217/782-2113~~
~~217/785-1705~~

~~“REVISED”~~
CLEAN AIR ACT PERMIT PROGRAM (CAAPP) PERMIT

PERMITTEE

~~Ameren Energy~~Illinois Power Generating Company
Attn: ~~Michael L. Menner~~Rick Diericx
~~1901 Chouteau Avenue~~1500 Eastport Plaza Drive
~~St. Louis, Missouri 63103~~Collinsville, Illinois 62234

Application No.: 95090066 I.D. No.: 079808AAA
Applicant's Designation: Newton ~~Date Received: September 07, 1995~~
Operation of: ~~Electrical Power Generation at Newton Plant~~Newton Energy Center
~~Original Date Received: September 07, 1995~~
Original Date Issued: September 29, 2005
~~Expiration Date¹: September 29, 2010~~Date¹: TBD
~~Effective Date: TBD~~
Source Location: 6725 North 500th Street, Newton, Jasper County
Responsible Official: ~~Kenneth D. Schoef~~Alan Bogardus, Manager, ~~Newton Power Station~~Energy Center

This permit is hereby granted to the above-designated Permittee, Illinois Power Generating Company, to OPERATE an electrical power generation station, pursuant to the above referenced permit application. This permit is subject to the conditions contained herein.

The current federal Acid Rain Permit issued to Ameren Illinois Power Energy Generating Company by the Illinois EPA for this source is incorporated into this CAAPP permit (See Attachment 5).

Revision Date Received: November 3, 2005
Revision Date Issued: TBD
Purpose of Revision: Significant Modification

This significant modification to the CAAPP Permit represents certain changes to Permit Conditions, as discussed in the Statement of Basis for this action, resulting from the settlement resolution of an administrative permit appeal filed in 2005 before the Pollution Control Board.²

¹ Except as addressed in Condition 8.7 of this permit.

² This permit revises the initial CAAPP permit for the source, which was placed into effect on the same date as a consequence of the Pollution Control Board order in the appeal proceeding (PCB 06-068) granting a Joint Motion To Partially Lift Stay Of CAAPP Permit And Request Remand Of Permit To Respondent. The significant modification undertaken in this action revises the permit to facilitate a dismissal of the permit appeal. Unless otherwise indicated, all citations to the Code of Federal Regulations in this permit, as revised, are to the Code of Federal Regulations as effective on September 29, 2005.

| If you have any questions concerning this permit, please contact the ~~Utility~~
| ~~CAAPP~~ Unit at 217/~~782-2113~~785-1705 (217/782-9143 TDD).

| ~~Donald-Raymond E. Sutton~~Pilapil, P.E.
| ~~Acting~~ Manager, Permit Section
| Division of Air Pollution Control

| ~~DESREP:MNP~~MTR:~~jar~~DLR:psj

cc: Illinois EPA, FOS, Region 3
USEPA

| ~~Except as addressed in Condition 8.7 of this permit.~~

TABLE OF CONTENTS

	<u>PAGE</u>
1.0 INTRODUCTION	4
1.1 Source Identification	
1.2 Owner/Parent Company	
1.3 Operator	
1.4 General Source Description	
1.5 Title I Conditions	
2.0 LIST OF ABBREVIATIONS/ACRONYMS USED IN THIS PERMIT	5
3.0 CONDITIONS FOR INSIGNIFICANT ACTIVITIES	7
3.1 Identification of Insignificant Activities	
3.2 Compliance with Applicable Requirements	
3.3 Addition of Insignificant Activities	
4.0 SIGNIFICANT EMISSION UNITS AT THIS SOURCE	9
5.0 OVERALL SOURCE CONDITIONS	10
5.1 Applicability of Clean Air Act Permit Program (CAAPP)	
5.2 Applicable Regulations	
5.3 General Non-Applicability of Regulations of Concern	
5.4 Source-Wide Operational and Production Limits and Work Practices	
5.5 Source-Wide Emission Limitations	
5.6 General Recordkeeping Requirements	
5.7 General Reporting Requirements	
5.8 General Operational Flexibility/Anticipated Operating Scenarios	
5.9 <u>Submittal of Information for Permit Reopening</u>	
5.10 <u>Implementation of Permit Upon Date of Initial Effectiveness</u>	
6.0 CONDITIONS FOR EMISSIONS CONTROL PROGRAMS	16
6.1 NO _x Trading Program	
6.2 Acid Rain Program	
7.0 UNIT SPECIFIC CONDITIONS	26
7.1 Coal Fired Boilers	
7.2 Coal Handling Equipment	
7.3 Fly Ash Equipment	
7.4 Gasoline Storage Tank	
8.0 GENERAL PERMIT CONDITIONS	91
8.1 Permit Shield	

	<u>PAGE</u>	
8.2	Applicability of Title IV Requirements <u>(Acid Deposition Control)</u>	
8.3	Emissions Trading Programs	
8.4	Operational Flexibility/Anticipated Operating Scenarios	
8.5	Testing Procedures	
8.6	Reporting Requirements	
8.7	Title I Conditions	
9.0	STANDARD PERMIT CONDITIONS	96
9.1	Effect of Permit	
9.2	General Obligations of Permittee	
9.3	Obligation to Allow Illinois EPA Surveillance	
9.4	Fees	
9.5	Property Rights	
9.6	Recordkeeping	
9.7	Annual Emissions Report	
9.8	Requirements for Compliance Certification	
9.9	Certification	
9.10	Defense to Enforcement Actions	
9.11	Permanent Shutdown	
9.12	Reopening And Reissuing Permit For Cause	
9.13	Severability Clause	
9.14	Permit Expiration and Renewal	
9.15	General Authority for Permit Terms and Conditions <u>of this Permit</u>	
10.0	ATTACHMENTS	
10.1	Attachment 1 - Emissions of Particulate Matter from New Process Emission Units	1-1
10.2	Attachment 2 - Emissions of Particulate Matter from Existing Process Emission Units	2-1
10.3	Attachment 3 - Example Certification by a Responsible Official	3-1
10.4	Attachment 4 - Guidance	4-1
10.5	Attachment 5 - Acid Rain Program Permit	5-1

1.0 INTRODUCTION

1.1 Source Identification

~~Ameren Energy~~Illinois Power Generating Company - Newton ~~Power Station~~Energy Center
6725 North 500th Street
Newton, Illinois 62448
618/783-8402

I.D. No.: 079808AAA
Acid Rain Permit ORIS Code No.: 6017

Standard Industrial Classification: 4911, Electrical Services

1.2 Owner/Parent Company

~~Ameren Energy~~Illinois Power Generating Company
~~1901 Chouteau Avenue~~1500 Eastport Plaza Drive
~~St. Louis, Missouri 63103~~Collinsville, Illinois 62234

1.3 Operator

~~Ameren Energy~~Illinois Power Generating Company
~~1901 Chouteau Avenue~~1500 Eastport Plaza Drive
~~St. Louis, Missouri 63103~~Collinsville, Illinois 62234

~~Steven C. Whitworth~~Rick Dierick
~~314/554-4908~~618/343-7761

1.4 General Source Description

~~Ameren Energy~~Illinois Power Generating Company operates two coal-fired boilers at the Newton ~~Power Station~~Energy Center to produce electricity.

1.5 Title I Conditions

This CAAPP permit contains certain conditions for units at this source that address the applicability of permitting programs for the construction and modification of sources, which programs were established pursuant to Title I of the Clean Air Act (CAA) and regulations thereunder. These programs include 40 CFR 52.21, Prevention of Significant Deterioration (PSD) and 35 IAC Part 203, Major Stationary Sources Construction and Modification (MSSCAM), and are implemented by the Illinois EPA pursuant to Sections 9, 9.1, 39(a) and 39.5(7)(a) of Illinois' Environmental Protection Act (Act). These "Title I conditions" within this permit are specifically designated as "T1", if they reflect requirements established in construction permits issued for this source, "T1R" if they revise requirements established in such construction permits, or "T1N" if they are newly established in this CAAPP permit. These conditions continue in effect, notwithstanding the expiration date specified on the first page

of this permit, as their authority derives from Titles I and V of the CAA, as well as Titles II and X of the Act. (See also Condition 8.7.)

2.0 LIST OF ABBREVIATIONS/ACRONYMS USED IN THIS PERMIT

acfm	Actual Cubic Feet Per Minute
Act	Illinois Environmental Protection Act [415 ILCS 5/1 et seq.]
AP-42	Compilation of Air Pollutant Emission Factors, Volume 1, Stationary Point and Other Sources (and Supplements A through F), USEPA, Office of Air Quality Planning and Standards, Research Triangle Park, NC 27711
Btu	British thermal unit
CAA	Clean Air Act [42 U.S.C. Section 7401 et seq.]
CAAPP	Clean Air Act Permit Program
CAM	Compliance Assurance Monitoring
CEMS	Continuous Emission Monitoring System
CFR	Code of Federal Regulations
CO	Carbon Monoxide
dcfm	dry cubic feet per minute
EGU	Electrical Generating Unit(s)
Gal	Gallon
ESP	Electrostatic Precipitator
°F	degrees Fahrenheit
FGC	Flue Gas Conditioning
ft	foot
ft ³	cubic foot
HAP	Hazardous Air Pollutant
HP	horsepower
hr	Hour
IAC	Illinois Administrative Code
I.D. No.	Identification Number of Source, assigned by Illinois EPA
ILCS	Illinois Compiled Statutes
Illinois EPA	Illinois Environmental Protection Agency
°K	degrees Kelvin
Kg	kilogram
kW	Kilowatts
Lb or lb	Pound
LNB	Low NO _x Burners
m	meter
MACT	Maximum Achievable Control Technology
mmBtu	million British thermal units
MW	Megawatts
NESHAP	National Emission Standards for Hazardous Air Pollutants
NO _x	Nitrogen Oxides
NSPS	New Source Performance Standards (40 CFR Part 60)
NSSA	New Source Set-Aside
ORIS	Office of Regulatory Information System
OFA	Over-Fire Air
OM	organic material
PM	Particulate Matter
PM ₁₀	Particulate matter with an aerodynamic diameter less than or equal to a nominal 10 microns as measured by applicable test or monitoring methods
ppm	parts per million

Formatted: Subscript

PSD	Prevention of Significant Deterioration (40 CFR 52.21)
psia	pounds per square inch absolute
RMP	Risk Management Plan
SO ₂	Sulfur Dioxide
T	ton (2000 pounds)
T1	Title I - identifies Title I conditions that have been carried over from an existing permit
T1N	Title I New - identifies Title I conditions that are being established in this permit
T1R	Title I Revised - identifies Title I conditions that have been carried over from an existing permit and subsequently revised in this permit
USEPA	United States Environmental Protection Agency
VOC or VOM	volatile organic compounds or volatile organic material
VOL	volatile organic liquid
yr	year

3.0 CONDITIONS FOR INSIGNIFICANT ACTIVITIES

3.1 Identification of Insignificant Activities

The following activities at the source constitute insignificant activities as specified in 35 IAC 201.210:

- 3.1.1 Activities determined by the Illinois EPA to be insignificant activities, pursuant to 35 IAC 201.210(a)(1) and 201.211, as follows:

Glycol Storage Tanks
Cooling Towers

- 3.1.2 Activities that are insignificant activities based upon maximum emissions, pursuant to 35 IAC 201.210(a)(2) or (a)(3), as follows:

None

- 3.1.3 Activities that are insignificant activities based upon their type or character, pursuant to 35 IAC 201.210(a)(4) through (18), as follows:

Equipment used for filling drums, pails, or other packaging containers, excluding aerosol cans, with soaps, detergents, surfactants, lubricating oils, waxes, vegetable oils, greases, animal fats, glycerin, sweeteners, corn syrup, aqueous salt solutions, or aqueous caustic solutions [35 IAC 201.210(a)(8)].

Storage tanks of organic liquids with a capacity of less than 10,000 gallons and an annual throughput of less than 100,000 gallons per year, provided the storage tank is not used for the storage of gasoline or any material listed as a HAP pursuant to Section 112(b) of the CAA [35 IAC 201.210(a)(10)].

Storage tanks of any size containing virgin or re-refined distillate oil, hydrocarbon condensate from natural gas pipeline or storage systems, lubricating oil, or residual fuel oils [35 IAC 201.210(a)(11)].

Gas turbines and stationary reciprocating internal combustion engines of less than 112 kW (150 horsepower) power output [35 IAC 201.210(a)(15)].

Gas turbines and stationary reciprocating internal combustion engines of between 112 kW and 1,118 kW (150 and 1,500 horsepower) power output that are emergency or standby units [35 IAC 201.210(a)(16)].

Loading and unloading systems for railcars, tank trucks, or watercraft that handle only the following liquid materials, provided an organic solvent has not been mixed with such materials: soaps, detergents, surfactants, lubricating oils, waxes, glycerin, vegetable oils, greases, animal fats, sweetener, corn syrup, aqueous salt solutions, or aqueous caustic solutions [35 IAC 201.210(a)(18)].

- 3.1.4 Activities that are considered insignificant activities pursuant to 35 IAC 201.210(b).

Note: The heating of a coal-fired boiler with auxiliary fuel during maintenance and repair of the boiler is considered an insignificant activity under 35 IAC 201.210(b)(29) and is generally not addressed by the unit-specific conditions of this permit for the boilers. Notwithstanding such status as an insignificant activity, the opacity of the exhaust from each coal fired boiler is at all times subject to applicable opacity standards and the unit-specific conditions of this permit for boilers that relate to opacity are applicable during maintenance and repair of a boiler.

3.2 Compliance with Applicable Requirements

Insignificant activities are subject to applicable requirements notwithstanding status as insignificant activities. In particular, in addition to regulations of general applicability, such as 35 IAC 212.301 and 212.123 (Condition 5.2.2), the Permittee shall comply with the following requirements, as applicable:

- 3.2.1 For each cold cleaning degreaser, the Permittee shall comply with the applicable equipment and operating requirements of 35 IAC 215.182.
- 3.2.2 For each particulate matter process emission unit, other than units excluded by 35 IAC 212.323 ~~and/or~~ 212.681, the Permittee shall comply with the applicable particulate matter emission limit of 35 IAC 212.321 or 212.322. For example, the particulate matter emissions from a process emission unit shall not exceed 0.55 pounds per hour if the emission unit's process weight rate is 100 pounds per hour or less, pursuant to 35 IAC 266.110.
- 3.2.3 For each organic material emission unit that uses organic material, e.g., a mixer or printing line, the Permittee shall comply with the applicable VOM emission limit of 35 IAC 215.301, which requires that organic material emissions not exceed 8.0 pounds per hour or do not qualify as photochemically reactive material as defined in 35 IAC 211.4690.

3.3 Addition of Insignificant Activities

- 3.3.1 The Permittee is not required to notify the Illinois EPA of additional insignificant activities present at the source of a type that is identified in Condition 3.1, until the renewal application for this permit is submitted, pursuant to 35 IAC 201.212(a).
- 3.3.2 The Permittee must notify the Illinois EPA of any proposed addition of a new insignificant activity of a type addressed by 35 IAC 201.210(a) and/or 201.211 other than those identified in Condition 3.1, pursuant to Section 39.5(12)(b) of the Act.
- 3.3.3 The Permittee is not required to notify the Illinois EPA of additional insignificant activities present at the source of a type identified in 35 IAC 201.210(b).

4.0 SIGNIFICANT EMISSION UNITS AT THIS SOURCE

Emission Unit	Description	Emission Control Equipment/Measures	Ref.*
Boiler NB-1	Combustion Engineering Boiler Nominal 5,500 mmBtu/hr (1972)	Low NO _x Burners, Overfire Air and Electrostatic Precipitator (ESP) with Flue Gas Conditioning (FGC)	7.1
Boiler NB-2	Combustion Engineering Boiler Nominal 5,500 mmBtu/hr (1975)	Primary Air Duct Burners, Low NO _x Burners, Overfire Air and Electrostatic Precipitator (ESP) with Flue Gas Conditioning (FGC)	
Coal Handling Equipment	Coal Receiving, Transfer and Storage Operations	Enclosures and Covers, and Dust Suppression, and Application System, Dust Collection Device	7.2
Fly Ash Equipment	Transfer Systems, Hoppers, Silos and Loading Operations Loadout Processes	Dust Collection Devices, Wet Process, Enclosures, and Covers, and Chutes	7.3
Gasoline Storage NGT-1 Tank	Gasoline Storage Tank 1,000 Gallon Capacity	Submerged Loading Pipe	7.4

Formatted: Subscript

Formatted: Subscript

* Reference to Unit Specific Conditions in Section 7 of this permit.

5.0 OVERALL SOURCE CONDITIONS

5.1 Applicability of Clean Air Act Permit Program (CAAPP)

5.1.1 This permit is issued based on the source requiring a CAAPP permit as a major source of SO₂, CO, NO_x, VOM, PM, and HAP emissions.

Formatted: Subscript

5.1.2 This permit is issued based on the source requiring a CAAPP permit as an "affected source" for the purposes of Acid Deposition Control, Title IV of the Clean Air Act.

5.2 Applicable Regulations

5.2.1 Specific emission units at this source are subject to particular regulations as set forth in Section 7 (Unit-Specific Conditions) of this permit.

5.2.2 In addition, emission units at this source are subject to the following regulations of general applicability:

- a. No person shall cause or allow the emission of fugitive particulate matter from any process, including any material handling or storage activity, that is visible by an observer looking generally towards the zenith (i.e., overhead) at a point beyond the property line of the source unless the wind speed is greater than 40.2 kilometers per hour (25 miles per hour), pursuant to 35 IAC 212.301 and 212.314.
- b. No person shall cause or allow the emission of smoke or other particulate matter, with an opacity greater than 30 percent, into the atmosphere from any emission unit other than those emission units subject to the requirements of 35 IAC 212.122, pursuant to 35 IAC 212.123(a), except as allowed by 35 IAC 212.123(b) and 212.124.

Note: As new fuel combustion emission units with heat input capacity greater than 250 mmBtu/hr, the coal-fired boilers at this source are subject to 35 IAC 212.122, which sets a limit on opacity of 20 percent.

5.2.3 Ozone Depleting Substances

The Permittee shall comply with the standards for recycling and emissions reduction of ozone depleting substances pursuant to 40 CFR Part 82, Subpart F, including the following:

- a. Persons opening appliances for maintenance, service, repair, or disposal must comply with the required practices pursuant to 40 CFR 82.156.

- b. Equipment used during the maintenance, service, repair, or disposal of appliances must comply with the standards for recycling and recovery equipment pursuant to 40 CFR 82.158.
- c. Persons performing maintenance, service, repair, or disposal of appliances must be appropriately certified by an approved technician certification program pursuant to 40 CFR 82.161.

5.2.4 Risk Management Plan (RMP)

Should this stationary source, as defined in 40 CFR 68.3, become subject to the federal rules for Chemical Accident Prevention in 40 CFR Part 68, then the owner or operator shall submit:

- a. A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR 68.10(a); or
- b. A certification statement that the source is in compliance with all applicable requirements of 40 CFR Part 68, including the registration and submission of the RMP, as part of the annual compliance certification required by Condition 9.8.

Note: This condition is imposed pursuant to 40 CFR 68.215(a).

5.2.5 Future Emission Standards

- a. Should this source become subject to a regulation under 40 CFR Parts 60, 61, or 63, or 35 IAC Subtitle B after the date issued of this permit, the owner or operator shall, in accordance with the applicable regulation(s), comply with the applicable requirements by the date(s) specified and shall certify compliance or otherwise demonstrate initial compliance as provided by such regulation. Following the submittal of such a compliance certification or initial compliance demonstration, the Permittee shall address the applicable requirements of such regulation as part of the annual compliance certification required by Condition 9.8.

Note: This permit may also have to be revised or reopened to address such newly applicable regulations, as provided by Section 39.5(15)(a) of the Act. (See Condition 9.12.2.)

- b. This permit and the terms and conditions herein do not affect the Permittee's past and/or continuing

obligation with respect to statutory or regulatory requirements governing major source construction or modification under Title I of the CAA. Further, neither the issuance of this permit nor any of the terms or conditions of the permit shall alter or affect the liability of the Permittee for any violation of applicable requirements prior to or at the time of permit issuance.

5.2.6 Episode Action Plan

- a. Pursuant to 35 IAC 244.142, the Permittee shall maintain at the source and have on file with the Illinois EPA a written episode action plan (plan) for reducing the levels of emissions during yellow alerts, red alerts, and emergencies, consistent with safe operating procedures. The plan shall contain the information specified in 35 IAC 244.144.
- b. The Permittee shall immediately implement the appropriate steps described in this plan should an air pollution alert or emergency be declared.
- c. If an operational change occurs at the source that invalidates the plan, a revised plan shall be submitted to the Illinois EPA, Air Compliance Section for review within 30 days of the change, pursuant to 35 IAC 244.143(d). Such plans shall be further revised if disapproved by the Illinois EPA.

~~5.2.7 Compliance Assurance Monitoring (CAM) Plan~~

~~Pursuant to 40 CFR 64.5, if the Permittee submits a request for a significant revision of this permit that is applicable to an affected large pollutant-specific emissions unit, as defined by 40 CFR 64.1, 64.2 and 64.5(a), (e.g., a coal-fired boiler as it emits particulate matter), the Permittee shall submit as part of such application the information required under 40 CFR 64.4 for a CAM plan.~~

~~Note: As provided by 40 CFR 64.5(a)(1), the Permittee was not required to submit CAM plans for affected large pollutant specific emissions units with the application for this permit because a complete CAAPP application was submitted before April 20, 1999. For all pollutant-specific emissions units that meet the criteria in 40 CFR 64.42(a), so as to be subject to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for Major Stationary Sources, the source must submit the information required under 40 CFR 64.4 as part of the application for renewal of this permit.~~

5.3 General Non-Applicability of Regulations of Concern

None

Note: For individual emissions units and groups of similar emission units, non-applicability of regulations is addressed in Section 7 of this permit.

5.4 Source-Wide Operational and Production Limits and Work Practices

In addition to the source-wide requirements in the Standard Permit Conditions in Section 9, the Permittee shall fulfill the following source-wide operational and production limitations and/or work practice requirements:

None

5.5 Source-Wide Emission Limitations

5.5.1 Permitted Emissions for Fees

Emission limitations are not set for this source for the purpose of permit fees. Rather, the Permittee shall pay the maximum fee required pursuant to Section 39.5(18)(a)(ii)(A) of the Act, ~~which is currently \$250,000.00 per year.~~ (See also Condition 9.4.)

5.6 General Recordkeeping Requirements

5.6.1 Records for Emissions

The Permittee shall maintain records for the source to prepare its Annual Emission Report ~~including the following items, pursuant to Sections 4(b) and 39.5(7)(a), (b) and (c) of the Act; pursuant to 35 IAC 254.134~~

~~a. Records of annual emissions from the emission units that are covered by Section 7 (Unit Specific Conditions) of this permit, including emissions of mercury, hydrogen chloride, and hydrogen fluoride.~~

~~b. i. For purposes of estimating mercury emissions from the source, the mercury content of coal burned in boilers may be based on the data collected by USEPA in its Information Collection Request (ICR) pursuant to Section 112 of the Clean Air Act.~~

~~ii. If ICR data or other reliable data for elemental composition, including mercury content, is not available for coal that is burned in a boiler, the Permittee shall collect representative data on the elemental composition of the coal, similar to the ICR data collected by USEPA.~~

5.6.2 Retention and Availability of Records

The Permittee shall comply with the following requirements with respect to retention and availability of records pursuant to Sections 4(b) and 39.5(7) (a), (b), (e) (ii), (o)(v), and ~~(fp)~~ (ii)(A) and (B) of the Act.

- a. All records and logs required by this permit shall be retained for at least five years from the date of entry (unless a longer retention period is specified by the particular recordkeeping provision herein), shall be readily accessible to the Permittee, the Illinois EPA and USEPA, and made available for inspection and copying by the Illinois EPA or USEPA upon request. ~~All records and logs required by this permit shall be retained for at least five years from the date of entry (unless a longer retention period is specified by the particular recordkeeping provision herein), shall be kept at a location at the source that is readily accessible to the Illinois EPA or USEPA, and shall be made available for inspection and copying by the Illinois EPA or USEPA upon request.~~
- b. In response to an Illinois EPA or USEPA request made during the course of an inspection of the source, the Permittee shall retrieve and provide paper copies, or as electronic media, any records required by this permit that are retained in an electronic format (e.g., computer). Such response shall be provided at the time of the inspection; however, if the Permittee believes that the volume and nature of the requested material would make this overly burdensome, material shall be provided no later than 10 days thereafter unless a later date is agreed upon by the Permittee, Illinois EPA, and/or the USEPA. ~~The Permittee shall retrieve and print, on paper during normal source office hours, any records retained in an electronic format (e.g., computer) in response to an Illinois EPA or USEPA request for specific records during the course of a source inspection.~~
- c. Upon written request by the Illinois EPA for copies of records or reports required to be kept by this permit, the Permittee shall promptly submit a copy of such material to the Illinois EPA. For this purpose, material shall be submitted to the Illinois EPA within 30 days unless additional time is provided by the Illinois EPA or the Permittee believes that the volume and nature of requested material would make this overly burdensome, in which case, the Permittee shall respond within 30 days with the explanation and

a schedule for submittal of the requested material.
(See also Condition 9.12.4.)

~~d. For certain records required to be kept by this permit as specifically identified in the recordkeeping provisions in Section 7 of this permit, which records are a basis for control practices or other recordkeeping required by this permit, the Permittee shall promptly submit a copy of the record to the Illinois EPA when the record is created or revised. For this purpose, the initial record shall be submitted within 30 days of the effectiveness of this permit. Subsequent revisions shall be submitted within 10 days of the date the Permittee begins to rely upon the revised record.~~

5.7 General Reporting Requirements

5.7.1 General Source-Wide Reporting Requirements

The Permittee shall promptly notify the Illinois EPA of deviations of the source with the permit requirements as follows, pursuant to Section 39.5(7)(f)(ii) of the Act. Reports shall describe the probable cause of such deviations, and any corrective actions or preventive measures taken.

- a. For emissions units that are addressed by the unit-specific conditions of this permit, the timing for reporting of deviations shall be in accordance with such conditions.
- b.
 - i. For other emissions units and activities at the source, the timing for reporting of deviations shall be in accordance with the provisions of relevant regulations if such provisions address timing of deviation reports.
 - ii. Otherwise, if the relevant regulations do not address timing of deviation reports, deviation reports shall be submitted within 30 days.

5.7.2 Annual Emissions Report

The annual emissions report required pursuant to Condition 9.7 shall contain emissions information for the previous calendar year ~~including information for emissions of hydrogen chloride, hydrogen fluoride, and other hazardous air pollutants~~, as specified by 35 IAC Part 254 [Sections 4(b) and 39.5(7)(a), (b) and (f) of the Act].

5.8 General Operational Flexibility/Anticipated Operating Scenarios

None

Note: For individual emissions units or groups of similar emission units, operation flexibility and anticipated operating scenarios are addressed in Section 7 of this permit.

5.9 Submittal of Information for Permit Reopening

The Permittee shall promptly submit information to assist the Illinois EPA in a reopening of the CAAPP permit in accordance with Section 39.5(15)(a)(i) of the Act and 35 IAC 270.503(a)(1), as follows:

5.9.1 Unless the CAAPP permit has been reopened within 32 days after issuance of this permit, Permittee shall submit to the Illinois EPA the following information, as part of a revised CAAPP application, within 90 days of permit issuance:

- a. An identification of all additional Clean Air Act requirements that have become applicable to the source since September 29, 2005. Such identification shall adhere to the definition of "applicable Clean Air Act requirement" set forth at Section 39.5(1) of the Act, including any term or condition of a Title I preconstruction permit and other such designated requirement(s) promulgated under the federal Clean Air Act.
- b. For any requirement identified in Condition 5.9.1(a) for which the source does not currently comply:
 - i. An identification of such requirement and the affected emission unit(s) subject to the requirement;
 - ii. The nature of the noncompliance (i.e., continuous or intermittent);
 - iii. An explanation of the source's failure to comply with the requirement; and
 - iv. A proposed compliance plan and schedule for the noncompliant emission unit(s) (i.e., Form 294 CAAPP).

5.10 Implementation of Permit Upon Date of Initial Effectiveness

- a. If this revised permit becomes effective during the fourth quarter of a given year, any annual (identified by the permit as calendar year or otherwise) or semi-annual inspection or observation requirements, including the combustion evaluations for the coal-fired boilers,

Formatted: Normal, Indent: Left: 1", Hanging: 0.75", No bullets or numbering, Tab stops: 0.5", Left + 1", Left + 1.75", Left + 2.63", Left + 3", Left + 3.5", Left + 4", Left + 4.5", Left + 6", Left

the opacity observations for the coal handling and fly ash equipment, and the submerged fill pipe inspection for the storage tank, need not be performed by the Permittee until the following year.

- b. If this revised permit becomes effective on or after the 45th day of a given quarter (calendar or otherwise), any quarterly testing, inspection and observation requirements, including the PM and CO emission measurements based on the use of alternative fuel relative to standard fuel, need not be performed by the Permittee until the following quarter.
- c. If this revised permit becomes effective on or after the 15th day of a given month (calendar or otherwise), any monthly inspection requirements, including the monthly inspections of affected operations for the coal handling and fly ash equipment, need not be performed by the Permittee until the following month.
- d. If this revised permit becomes effective on or after Wednesday of a given week (calendar or otherwise), any weekly inspection requirements, including the weekly inspections for the fly ash loadout equipment and fly ash transport baghouses, need not be performed by the Permittee until the following week.
- e. The inspection requirements set forth in Condition 7.2.8(c) need not be performed by the Permittee until on or after the 35th day after the effective date of this revised permit.
- f. The first quarterly report to be submitted pursuant to Condition 7.1.10-2(a) must be submitted as follows. Thereafter, each subsequent quarterly report must be submitted as specified in Condition 7.1.10-2(a)(iii).
 - i. If this revised permit becomes effective before the 45th day of a calendar quarter, the report must be submitted within 60 days after the end of that quarter and address the period from the effective date of this permit through the end of that quarter.
 - ii. If this revised permit becomes effective on or after the 45th day of a calendar quarter, the report must be submitted within 60 days after the end of the first complete quarter in which this permit is effective and address the period from the effective date of this permit through the end of the first complete calendar quarter in which this permit is effective.

Formatted: Not Superscript/ Subscript

Formatted: Not Superscript/ Subscript

6.0 CONDITIONS FOR EMISSIONS CONTROL PROGRAMS

6.1 NO_x Trading Program³

6.1.1 Description of NO_x Trading Program

The NO_x Trading Program is a regional "cap and trade" market system for large sources of NO_x emissions in the eastern United States, including Illinois. It is designed to reduce and maintain NO_x emissions from the emission units covered by the program within a budget to help contribute to attainment and maintenance of the ozone ambient air quality standard in the multi-state region covered by the program. The NO_x Trading Program applies in addition to other applicable requirements for NO_x emissions and in no way relaxes these other requirements.

Electrical generating units (EGU) that are subject to the NO_x Trading Program are referred to as "budget EGU". Sources that have one or more EGU or other units subject to the NO_x Trading Program are referred to as budget sources.

The NO_x Trading Program controls NO_x emissions from budget EGU and other budget units during a seasonal control period from May 1 through September 30 of each year, when weather conditions are conducive to formation of ozone in the ambient air. By November 30 of each year, the allowance transfer deadline, each budget source must hold "NO_x allowances" for the actual NO_x emissions of its budget units during the preceding control period. The USEPA will then retire NO_x allowances in the source's accounts in amounts equivalent to its seasonal emissions. If a source does not have sufficient allowances in its accounts, USEPA would subtract allowances from the source's future allocation for the next control period and impose other penalties as appropriate. Stringent monitoring procedures developed by USEPA apply to budget units to assure that actual emissions of NO_x are accurately determined.

The number of NO_x allowances available for budget sources is set by the overall budget for NO_x emissions established by USEPA. This budget requires a substantial reduction in NO_x emissions from historical levels as necessary to meet air quality goals. In Illinois, existing budget sources initially receive their allocation or share of the NO_x allowances budgeted for EGU in an amount determined by rule [35 IAC Part 217, Appendix F]. Between 2007 and 2011, the allocation

Formatted: Subscript

³ Conditions 6.1.1 through 6.1.10 will be removed from the CAAPP permit in a later permitting action, as the Illinois regulations establishing a NO_x Trading Program for electrical generating units, 35 IAC Part 217 Subpart W, have been sunset and are no longer applicable.

mechanism for existing EGU gradually shifts to one based on the actual operation of EGU in preceding control periods. New budget EGU, for which limited operating data may be available, may obtain NO_x allowances from the new source set-aside (NSSA), a portion of the overall budget reserved for new EGU.

Formatted: Subscript

In addition to directly receiving or purchasing NO_x allowances as described above, budget sources may transfer NO_x allowances from one of their units to another. They may also purchase allowances in the marketplace from other sources that are willing to sell some of the allowances that they have received. Each budget source must designate an account representative to handle all its allowance transactions. The USEPA, in a central national system, will maintain allowance accounts and record transfer of allowances among accounts.

Formatted: Subscript

Formatted: Subscript

The ability of sources to transfer allowances will serve to minimize the costs of reducing NO_x emissions from budget units to comply with the overall NO_x budget. In particular, the NO_x emissions of budget units that may be most economically controlled will be targeted by sources for further control of emissions. This will result in a surplus of NO_x allowances from those units that can be transferred to other units at which it is more difficult to control NO_x emissions. Experience with reduction of sulfur dioxide emissions under the federal Acid Rain program has shown that this type of trading program not only achieves regional emission reductions in a more cost-effective manner but also results in greater overall reductions than application of traditional emission standards to individual emission units.

Formatted: Subscript

Formatted: Subscript

Formatted: Subscript

Formatted: Subscript

Formatted: Subscript

The USEPA developed the plan for the NO_x Trading Program with assistance from affected states. Illinois' rules for the NO_x Trading Program for EGU are located at 35 IAC Part 217, Subpart W, and have been approved by the USEPA. These rules provide for interstate trading, as mandated by Section 9.9 of the Act. Accordingly, these rules refer to and rely upon federal rules at 40 CFR Part 96, which have been developed by USEPA for certain aspects of the NO_x Trading Program, and which an individual state must follow to allow for interstate trading of allowances.

Formatted: Subscript

Formatted: Subscript

Formatted: Subscript

Note: This narrative description of the NO_x Trading Program in Condition 6.1.1 is for informational purposes only and is not enforceable implies no limits or constraints.

Formatted: Subscript

6.1.2 Applicability

- a. The following emission units at this source are budget EGU for purposes of the NO_x Trading Program. Accordingly, this source is a budget source and the Permittee is the owner or operator of a budget source and budget EGU. In this section of this permit, these emission units are addressed as budget EGU.

Formatted: Subscript

Newton Boilers 1 and 2 (NB-1 and NB-2)

- b. This permit does not provide "low-emitter status" for the above emission units pursuant to 35 IAC 217.754(c).

6.1.3 General Provisions of the NO_x Trading Program

- a. This source and the budget EGU at this source shall comply with all applicable requirements of Illinois' NO_x Trading Program, i.e., 35 IAC Part 217, Subpart W, and 40 CFR Part 96 (excluding 40 CFR 96.4(b) and 96.55(c), and excluding 40 CFR 96, Subparts C, E, and I), pursuant to 35 IAC 217.756(a) and 217.756(f) (2).

Formatted: Subscript

- b. Any provision of the NO_x Trading Program that applies to a budget source (including any provision applicable to the account representative of a budget source) shall also apply to the owner and operator of such budget source and to the owner and operator of each budget EGU at the source, pursuant to 35 IAC 217.756(f) (3).

Formatted: Subscript

- c. Any provision of the NO_x Trading Program that applies to a budget EGU (including any provision applicable to the account representative of a budget EGU) shall also apply to the owner and operator of such budget EGU. Except with regard to requirements applicable to budget EGUs with a common stack under 40 CFR 96, Subpart H, the owner and operator and the account representative of one budget EGU shall not be liable for any violation by any other budget EGU of which they are not an owner or operator or the account representative, pursuant to 35 IAC 217.756(f) (4).

Formatted: Subscript

6.1.4 Requirements for NO_x Allowances

Formatted: Subscript

- a. ~~Beginning in 2004, by~~ November 30 of each year, the allowance transfer deadline, as applicable, the account representative of each budget EGU at this source shall hold allowances available for compliance deduction under 40 CFR 96.54 in the budget EGU's compliance account or the source's overdraft account in an amount that shall not be less than the budget

EGU's total tons of NO_x emissions for the preceding control period, rounded to the nearest whole ton, as determined in accordance with 40 CFR 96, Subpart H, plus any number necessary to account for actual utilization (e.g., for testing, start-up, malfunction, and shut down) under 40 CFR 96.42(e) for the control period, pursuant to 35 IAC 217.756(d)(1). For purposes of this requirement, an allowance may not be utilized for a control period in a year prior to the year for which the allowance is allocated, pursuant to 35 IAC 217.756(d)(5).

Formatted: Subscript

- b. The account representative of a budget EGU that has excess emissions in any control period, i.e., NO_x emissions in excess of the number of NO_x allowances held as provided above, shall surrender allowances as required for deduction under 40 CFR 96.54(d)(1), pursuant to 35 IAC ~~204~~217.756(f)(5). In addition, the owner or operator of a budget EGU that has excess emissions shall pay any fine, penalty, or assessment, or comply with any other remedy imposed under 40 CFR 96.54(d)(3) and the Act, pursuant to 35 IAC 217.756(f)(6). Each ton of NO_x emitted in excess of the number of NO_x allowances held as provided above for each budget EGU for each control period shall constitute a separate violation of 35 IAC Part 217 and the Act, pursuant to 35 IAC 217.756(d)(2).

Formatted: Subscript

- c. An allowance allocated by the Illinois EPA or USEPA under the NO_x Trading Program is a limited authorization to emit one ton of NO_x in accordance with the NO_x Trading Program. As explained by 35 IAC 217.756(d)(6), no provisions of the NO_x Trading Program, the budget permit application, the budget permit, or a retired unit exemption under 40 CFR 96.5 and no provision of law shall be construed to limit the authority of the United States or the State of Illinois to terminate or limit this authorization. As further explained by 35 IAC 217.756(d)(7), an allowance allocated by the Illinois EPA or USEPA under the NO_x Trading Program does not constitute a property right. As provided by 35 IAC 217.756(d)(4), allowances shall be held in, deducted from, or transferred among allowances accounts in accordance with 35 IAC Part 217, Subpart W, and 40 CFR 96, Subparts F and G.

Formatted: Subscript

6.1.5 Monitoring Requirements for Budget EGU

- a. The Permittee shall comply with ~~the any applicable NO_x Trading Program~~ monitoring requirements of 40 CFR Part 96, Subpart H, for each budget EGU and the compliance of each budget EGU with the emission limitation under Condition 6.1.4(a) shall be

Formatted: Subscript

determined by the emission measurements recorded and reported in accordance with 40 CFR 96, Subpart H, pursuant to 35 IAC 217.756(c)(1), (c)(2) and (d)(3).

i. For Boilers NB-1 and NB-2, the Permittee is conducting continuous emissions monitoring for NO_x as generally provided for by 40 CFR 75.71(a).

Formatted: Subscript

b. The account representative for the source and each budget EGU at the source shall comply with those sections of the monitoring requirements of 40 CFR 96, Subpart H, applicable to an account representative, pursuant to 35 IAC 217.756(c)(1) and (d)(3).

6.1.6 Recordkeeping Requirements for Budget EGU

Unless otherwise provided below, the Permittee shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This 5-year period may be extended for cause at any time prior to the end of the 5 years, in writing by the Illinois EPA or the USEPA.

a. The account certificate of representation of the account representative for the source and each budget EGU at the source and all documents that demonstrate the truth of the statements in the account certificate of representation, in accordance with 40 CFR 96.13, as provided by 35 IAC 217.756(e)(1)(A). These certificates and documents must be retained on site at the source for at least 5-years after they are superseded because of the submission of a new account certificate of representation changing the account representative.

b. All emissions monitoring information, in accordance with 40 CFR 96, Subpart H, (provided that to the extent that 40 CFR 96, Subpart H, provides for a 3-year period for retaining records, the 3-year period shall apply), pursuant to 35 IAC 217.756(e)(1)(B).

c. Copies of all reports, compliance certifications, and other submissions and all records made or required under the NO_x Trading Program or documents necessary to demonstrate compliance with requirements of the NO_x Trading Program, pursuant to 35 IAC 217.756(e)(1)(C).

Formatted: Subscript

Formatted: Subscript

d. Copies of all documents used to complete a budget permit application and any other submission under the NO_x Trading Program, pursuant to 35 IAC 217.756(e)(1)(D).

Formatted: Subscript

6.1.7 Reporting Requirements for Budget EGU

- a. The account representative for this source and each budget EGU at this source shall submit to the Illinois EPA and USEPA the reports and compliance certifications required under the NO_x Trading Program, including those under 40 CFR 96, Subparts D and H, and 35 IAC 217.774, pursuant to 35 IAC 217.756(e)(2).
- b. Notwithstanding the provisions in Conditions 9.8 and 9.9 of this CAAPP permit, these submittals need only be signed by the designated representative, who may serve in place of the responsible official for this purpose, as provided by Section 39.5(1) of the Act, and submittals to the Illinois EPA need only be made to the Illinois EPA, Air Compliance Section.

Formatted: Subscript

6.1.8 Allocation of NO_x Allowances to Budget EGU

- a. As the budget EGU identified in Condition 6.1.2(a) are "existing" EGU listed in 35 IAC Part 217, Appendix F, these EGU are entitled to NO_x allowances as follows. (The portion of Appendix F that applies to the Permittee is provided in Condition 6.1.10.) The number of NO_x allowances actually allocated for the budget EGU shall be the number of NO_x allowances issued by USEPA pursuant to the allocation information reported to it by the Illinois EPA, which information may reflect adjustments to the overall allocations to budget EGU as provided for by 35 IAC 217.760(b) and (c):
 - i. In 2004 through 2006 (the first three years of the NO_x Trading Program), an annual allocation of NO_x allowances as specified by 35 IAC 217.764(a)(1), i.e., the number of NO_x allowances listed in Appendix F, Column 7, and as provided by 35 IAC 217.768(j), a pro-rata share of any NO_x allowances remaining in the new source set-aside (NSSA) following the allocation of allowances to new budget EGU.
 - ii. In 2007, as provided by 35 IAC 217.764(b), an allocation of NO_x allowances as specified by 35 IAC 217.764(b)(1), i.e., the number of NO_x allowances listed in Appendix F, Column 8, and as provided by 35 IAC 217.764(b)(4), a pro-rata share of any NO_x allowances remaining after the allocation of allowances pursuant to 35 IAC 217.764(b)(2) to budget EGU that commence operation between January 1, 1995 and April 30, 2003.

Formatted: Subscript

- iii. In 2008, as provided by 35 IAC 217.764(c), a specified allocation of NO_x allowances, i.e., the number of NO_x allowances listed in Appendix F, Column 8, and as provided by 35 IAC 217.764(c)(4), and a pro-rata share of any NO_x allowances remaining after the allocation of allowances to budget EGU that commence operation between January 1, 1995 and April 30, 2004.

 - Formatted: Subscript
 - Formatted: Subscript
 - Formatted: Subscript

- iv. In 2009, as provided by 35 IAC 217.764(d), a specified allocation of NO_x allowances, i.e., the number of NO_x allowances listed in Appendix F, Column 9, and as provided by 35 IAC 217.764(d)(4), and a pro-rata share of any NO_x allowances remaining after the allocation of NO_x allowances to budget EGU that commence operation between January 1, 1995 and April 30, 2005, and as provided by 35 IAC 217.764(d)(6), a pro-rata share of any surplus of NO_x allowances in the NSSA after the allocation of NO_x allowances to new budget EGU pursuant to 35 IAC 217.764(d)(5).

 - Formatted: Subscript

- v. In 2010, as provided by 35 IAC 217.764(e), a specified allocation of NO_x allowances, i.e., the number of NO_x allowances listed in Appendix F, Column 9, and a pro-rata share of any NO_x allowances remaining after the allocation of NO_x allowances to budget EGU that commence operation between January 1, 1995 and April 30, 2006, and a pro-rata share of any surplus of NO_x allowances in the NSSA following the allocation of NO_x allowances to new budget EGU.

 - Formatted: Subscript

- vi. In 2011 and annually thereafter, as provided by 35 IAC 217.764(f), an allocation of NO_x allowances based on the prior operation of the EGU during previous control periods, as described in Condition 6.1.8(b), and a pro-rata share of any surplus of NO_x allowances in the NSSA following the allocation of NO_x allowances to new budget EGU.

 - Formatted: Subscript
 - Formatted: Subscript
 - Formatted: Subscript
 - Formatted: Subscript

- b. In accordance with 35 IAC 217.762, the theoretical number of NO_x allowances for the budget EGU listed in Condition 6.1.2(a), calculated as the product of the applicable NO_x emissions rate and heat input as follows, shall be the basis for determining the pro-rata share of NO_x allowances for the budget EGU and the allocation of NO_x allowances to the budget EGU based on their prior operation:

 - Formatted: Subscript
 - Formatted: Subscript
 - Formatted: Subscript
 - Formatted: Subscript

i. The applicable NO_x emission rate for the budget EGU shall be 0.15 lb/mmBtu, as specified by 35 IAC 217.762(a)(1).

Formatted: Subscript

ii. The applicable heat input (mmBtu/control period) shall be the average of the two highest heat inputs from the control periods four to six years prior to the year for which the allocation is being made, as provided by 35 IAC 217.762(b)(1).

6.1.9 Budget Permit Required by the NO_x Trading Program

Formatted: Subscript

- a. For this source, this segment of the CAAPP Permit, i.e., Section 6.1, is the Budget Permit required by the NO_x Trading Program and is intended to contain federally enforceable conditions addressing all applicable NO_x Trading Program requirements. This Budget Permit shall be treated as a complete and segregable portion of the source's entire CAAPP permit, as provided by 35 IAC 217.758(a)(2).
- b. The Permittee and any other owner or operator of this source and each budget EGU at the source shall operate the budget EGU in compliance with this Budget Permit, pursuant to 35 IAC 217.756(b)(2).
- c. No provision of this Budget Permit or the associated application shall be construed as exempting or excluding the Permittee, or other owner or operator and, to the extent applicable, the account representative of a budget source or budget EGU from compliance with any other regulation or requirement promulgated under the CAA, the Act, the approved State Implementation Plan, or other federally enforceable permit, pursuant to 35 IAC 217.756(g).
- d. Upon recordation by USEPA under 40 CFR 96, Subpart F or G, or 35 IAC 217.782, every allocation, transfer, or deduction of an allowance to or from the budget units' compliance accounts or to or from the overdraft account for the budget source is deemed to amend automatically, and become part of, this budget permit, pursuant to 35 IAC 217.756(d)(8). This automatic amendment of this budget permit shall be deemed an operation of law and will not require any further review.
- e. No revision of this Budget Permit shall excuse any violation of the requirements of the NO_x Trading Program that occurs prior to the date that the revisions to this permit takes effect, pursuant to 35 IAC 217.756(f)(1).

Formatted: Subscript

Formatted: Subscript

Formatted: Subscript

f. The Permittee, or other owner or operator of the source, shall reapply for a Budget Permit for the source as required by 35 IAC Part 217, Subpart W and Section 39.5 of the Act. For purposes of the NO_x Trading Program, the application shall contain the information specified by 35 IAC 217.758(b)(2).

Formatted: Subscript

6.1.10 References

35 IAC Part 217 Appendix F - (provisions applicable to the Permittee)

Company Name/ I.D. No.	Generating Unit	EGU	NO _x Budget Allowances	80% of NO _x Budget Allowances	50% of NO _x Budget Allowances	2004, 2005, 2006 Allowances	2007, 2008 Allowances	2009, 2010 Allowances
1	2	3	4	5	6	7	8	9
079808AAA	Newton 1	Newton 1	1,101	881	551	1,046	863	539
079808AAA	Newton 2	Newton 2	1,074	859	537	1,020	842	526

6.2 Acid Rain Program

6.2.1 Applicability

Under Title IV of the CAA, Acid Deposition Control, this source is an affected source and the following emission units at the source are affected units for acid deposition:

Newton Boiler 1 (NB-1)
Newton Boiler 2 (NB-2)

Note: Title IV of the CAA, and other laws and regulations promulgated thereunder, establish requirements for affected sources related to control of emissions of pollutants that contribute to acid rain. For purposes of this permit, these requirements are referred to as Title IV provisions.

6.2.2 Applicable Emission Requirements

The owners and operators of the source shall not violate applicable Title IV provisions. In particular, NO_x emissions of affected units shall not exceed the limit set by 40 CFR Part 76, with the ability for averaging among units as allowed by an Acid Rain Permit. SO₂ emissions of the affected units shall not exceed any allowances that the source lawfully holds under Title IV provisions [Section 39.5(7)(g) and (17)(1) of the Act].

Note: Affected sources must hold SO₂ allowances to account for the SO₂ emissions from affected units at the source that are subject to Title IV provisions. Each allowance is a limited authorization to emit up to one ton of SO₂ emissions during or after a specified calendar year. The possession of allowances does not authorize exceedances of applicable emission standards or violations of ambient air quality standards.

6.2.3 Monitoring, Recordkeeping and Reporting

The owners and operators of the source and, to the extent applicable, their designated representative, shall comply with applicable requirements for monitoring, recordkeeping and reporting specified by Title IV provisions, including 40 CFR Part 75 [Section 39.5(7)(b) and 17(m) of the Act].

Note: As further addressed by Section 7 of this permit, the following emission determination methods are currently being used for the affected units at this source.

NO_x: Continuous Emissions Monitoring (40 CFR 75.12)

SO₂: Continuous Emissions Monitoring (40 CFR 75.11)
Opacity: Continuous Emission Monitoring (40 CFR 75.14)

6.2.4 Acid Rain Permit

The owners and operators of the source shall comply with the terms and conditions of the source's Acid Rain permit [Section 39.5(17)(1) of the Act].

Note: The source is subject to an Acid Rain permit, which was issued pursuant to Title IV provisions, including Section 39.5(17) of the Act. Affected sources must be operated in compliance with their Acid Rain permits. This source's Acid Rain permit is incorporated by reference into this permit and a copy of the current Acid Rain permit is included as Attachment 5 of this permit. Revisions and modifications of this Acid Rain permit, including administrative amendments and automatic amendments (pursuant to Sections 408(b) and 403(d) of the CAA or regulations thereunder) are governed by Title IV provisions, as provided by Section 39.5(13)(e) of the Act. Accordingly, revision or renewal of the Acid Rain permit may be handled separately from this CAAPP permit and a copy of the new Acid Rain permit may be included in this permit by administrative amendment.

6.2.5 Coordination with Other Requirements

- a. This permit does not contain any conditions that are intended to interfere with or modify the requirements of Title IV provisions. In particular, this permit does not restrict the flexibility under Title IV provisions of the owners and operators of this source to amend their Acid Rain compliance plan [Section 39.5(17)(h) of the Act].
- b. Where another applicable requirement of the CAA is more stringent than an applicable requirement of Title IV provisions, both requirements are incorporated into this permit and are enforceable and the owners and operators of the source shall comply with both requirements [Section 39.5(7)(h) of the Act].

7.0 UNIT SPECIFIC CONDITIONS

7.1 Coal Fired Boilers - Subject to NSPS, 40 CFR 60 Subpart D

7.1.1 Description

The Permittee operates two coal-fired boilers for electric generation. The boilers are ~~currently operated for base load generation, normally operating capable of operating in baseload or load-following modes, and typically operate~~ for weeks at a time between startups. The boilers, which were built in 1972 and 1975, have nominal capacities of ~~5,5006,000~~ mmBtu/hour each and ~~are~~ served by separate stacks. These boilers also have the capability to fire ~~at various modes such as a~~ combination of coal and fuel oil as their principal fuel. ~~In addition to coal, these~~The boilers ~~also~~ fire fuel oil as auxiliary fuel during startup and for flame stabilization. Periodically small amounts of used oil or boiler cleaning residue are fired with the coal in these boilers.

Nitrogen oxide (NO_x) emissions from the boilers are controlled by low-NO_x burners and overfire air systems. ~~In addition, boiler 2 is equipped with a duct burner for the primary air supply to facilitate control of NO_x.~~ Particulate matter (PM) emissions are controlled by electrostatic precipitators (ESP) equipped with Flue Gas Conditioning (FGC) systems. The FGC systems are operated on an as needed basis.

Note: The description in Condition 7.1.1 is for informational purposes only and implies no limits or constraints.

7.1.2 List of Emission Units and Air Pollution Control Equipment

These unit-specific conditions address the following emission units:

Boiler ID	Description	Emission Control Equipment
Boiler 1 NB-1	Coal-fired Boiler Nominal 5,500 mmBtu/hr	Low NO _x Burners with Overfire Air, and ESP with FGC
Boiler 2 NB-2	Coal-fired Boiler Nominal 5,500 mmBtu/hr	Primary Air Duct Burners, Low NO _x Burners with Overfire Air, and ESP with FGC

7.1.3 Applicability Provisions

- a. i. An "affected boiler" for the purpose of these unit-specific conditions is a boiler described in Conditions 7.1.1 and 7.1.2.

ii. The affected boilers are also "affected facilities" for purposes of the New Source Performance Standards (NSPS) for Fossil-Fuel Fired Steam Generators for Which Construction Is Commenced After August 17, 1971, pursuant to 40 CFR 60.40. As affected facilities, the boilers are also subject to applicable requirements of the NSPS, 40 CFR 60 Subpart D and related requirements in the NSPS, 40 CFR 60 Subpart A, General Provisions.

b. Startup Provisions

Subject to the following terms and conditions, the Permittee is authorized to operate an affected boiler in violation of the applicable standards in Condition 7.1.4(g) (35 IAC 212.122), Condition 7.1.4(b) (35 IAC 212.204), Condition 7.1.4(d) (35 IAC 216.121), and Condition 7.1.4(e) (35 IAC 217.121(d)) during startup. This authorization is provided pursuant to 35 IAC 201.149, 201.~~161-261~~ and 201.262, as the Permittee has applied for such authorization in its application, generally describing the efforts that will be used "...to minimize startup emissions, duration of individual startups and frequency of startups."

- i. This authorization does not relieve the Permittee from the continuing obligation to demonstrate that all reasonable efforts are made to minimize startup emissions, duration of individual startups and frequency of startups.
- ii. The Permittee shall conduct startup of an affected boiler in accordance with written procedures prepared by the Permittee and maintained in the control room for the boiler, that are specifically developed to minimize emissions from startups and that include, at a minimum, the following measures:
- A. Use of auxiliary fuel burners to heat the boiler prior to initiating burning of coal.
 - B. Timely energization of the electrostatic precipitator as soon as this may be safely accomplished without damage or risk to personnel or equipment.
- iii. The Permittee shall fulfill applicable recordkeeping and reporting requirements of

Conditions 7.1.9(e), ~~(e)~~ and ~~(g)~~ and 7.1.10-2(a).

- iv. As provided by 35 IAC 201.265, an authorization in a permit for excess emissions during startup does not shield a Permittee from enforcement for any violation of applicable emission standard(s) that occurs during startup and only constitutes a prima facie defense to such an enforcement action provided that the Permittee has fully complied with all terms and conditions connected with such authorization.

c. Malfunction and Breakdown Provisions

Subject to the following provisions, the Permittee is authorized to continue operation of an affected boiler in violation of the applicable requirements of Condition 7.1.4(g) (35 IAC 212.122), Condition 7.1.4(b) (35 IAC 212.204), Condition 7.1.4(d) (35 IAC 216.121), and Condition 7.1.4(e) (35 IAC 217.121(d)) in the event of a malfunction or breakdown of an affected boiler, including the coal pulverizer, the ash removal system, or the electrostatic precipitator (including flue gas conditioning). This authorization is provided pursuant to 35 IAC 201.149, 201.~~161-261~~ and 201.262, as the Permittee has applied for such authorization in its application, generally explaining why such continued operation would be required to provide essential service or to prevent injury to personnel or severe damage to equipment, and describing the measures that will be taken to minimize emissions from any malfunctions and breakdowns. This authorization supersedes the general prohibition in Condition 9.2.3 against continued operation in such circumstances.

- i. This authorization only allows such continued operation as necessary to provide essential service or to prevent injury to personnel or severe damage to equipment and does not extend to continued operation solely for the economic benefit of the Permittee.
- ii. Upon occurrence of excess emissions due to malfunction or breakdown, the Permittee shall as soon as practicable reduce boiler load, repair the affected boiler, remove the affected boiler from service or undertake other action so that excess emissions cease.
- iii. The Permittee shall fulfill applicable recordkeeping and reporting requirements of

Conditions 7.1.9(e), ~~(e)~~ and (h), ~~7.1.10-2(d)~~ and 7.1.10-3(a). For these purposes, time shall be measured from the start of a particular incident. The absence of excess emissions for a short period shall not be considered to end the incident if excess emissions resume. In such circumstances, the incident shall be considered to continue until corrective actions are taken so that excess emissions cease or the Permittee takes the boiler out of service.

- iv. Following notification to the Illinois EPA of a malfunction or breakdown with excess emissions, the Permittee shall comply with all reasonable directives of the Illinois EPA with respect to such incident, pursuant to 35 IAC 201.263.
- v. This authorization does not relieve the Permittee from the continuing obligation to minimize excess emissions during malfunction or breakdown. As provided by 35 IAC 201.265, an authorization in a permit for continued operation with excess emissions during malfunction and breakdown does not shield the Permittee from enforcement for any such violation and only constitutes a prima facie defense to such an enforcement action provided that the Permittee has fully complied with all terms and conditions connected with such authorization.

7.1.4 Applicable Emission Standards

a. Federal NSPS standards

- i. The affected boilers are subject to New Source Performance Standards (NSPS) for Fossil Fuel Fired Steam Generators, 40 CFR 60, Subparts A and D.
- ii. Pursuant to the NSPS, emissions from each affected boiler shall not exceed the following emission standards:

<u>Pollutant</u>	<u>(lb/mmBtu)</u>	<u>Standard Rule</u>
PM	0.10	40 CFR 60.42(a)(1)
SO ₂	1.20	40 CFR 60.43(a)(2)
NO _x	0.70	40 CFR 60.44(a)(3)

- iii. Opacity from each affected boiler shall not exceed 20 percent, as measured on a six minute average, except for one 6 minute period per

hour of not more than 27 percent pursuant to NSPS, 40 CFR 60.42(a)(2).

- iv. Pursuant to 40 CFR 60.8(c) and 60.11(c), the above emission limitations do not apply during startup, malfunction, and shutdown, as defined by 40 CFR 60.2. Notwithstanding this provision, pursuant to 40 CFR 60.7(b) and (c), exceedances of these limitations during startup, malfunction, and shutdown are still subject to recordkeeping and reporting requirements under the NSPS.
- b. The emissions of PM from each affected boiler shall not exceed 0.10 lb/mmBtu of actual heat input in any one hour period, pursuant to 35 IAC 212.204.
- c. The emissions of SO₂ from each affected boiler shall not exceed 1.2 lb/mmBtu of actual heat input, pursuant to 35 IAC 214.121(a).

Note: As is noted in 35 IAC 214.121(a), "This section [35 IAC 214.121(a)] was invalidated in Commonwealth Edison v. PCB, 25 Ill. App. 3d 271, 62 Ill.2d 494, 43 N.E.2d 459, 323 N.E.2d 84, Ashland Chemical Corp. v. PCB, 64 Ill. App. 3d 169, and Illinois State Chamber of Commerce v. PCB, 67 Ill. App. 3d 839, 384 N.E.2d 922, 78 Ill.2d 1, 398 N.E.2d 9."

Consequently, this condition is no longer applicable and the Agency plans to remove it in a later permitting action.

- d. The emissions of CO from each affected boiler shall not exceed 200 ppm, corrected to 50 percent excess air, pursuant to 35 IAC 216.121.
- e. The emissions of NO_x from each affected boiler shall not exceed 0.7 lb/mmBtu of actual heat input in any one hour period, pursuant to 35 IAC 217.121(d).
- f. The affected boilersEGUs at the source are each subject to the following requirements related to NO_x emissions pursuant to 35 IAC Part 217 Subpart V:
 - i. During each ozone control period (May 1 through September 30):
 - A. The emissions of NO_x from an affected boilereach EGU shall not exceed 0.25 lb/mmBtu of actual heat input based on an ozone control period average for that

~~unit~~EGU, pursuant to 35 IAC 217.706(a),
or

- B. Notwithstanding the requirement in 7.1.4(f)(i)(A), if the Permittee elects to participate in a NO_x averaging plan pursuant to 35 IAC 217.708(a), the average rate of emissions of NO_x from the Permittee's affected boilerEGUs and all other eligible EGUs that are participating in such NO_x averaging demonstration shall not exceed 0.25 lbs/mmBtu of actual heat input, as averaged for the ozone control period ~~for the EGU participating in the demonstration~~, pursuant to 35 IAC 217.708(a) and (b). For this purpose, ~~other~~ eligible ~~EGU~~EGUs include: (1) EGUs at this source, which are ~~also~~ authorized by this permit to participate in a NO_x averaging demonstration, and (2) any other EGU that ~~are~~is authorized to participate in a NO_x averaging plan by a CAAPP permit or other federally enforceable permit issued by the Illinois EPA to the owner or operator of ~~thesethat~~ EGU.

Note: Given the emission determination methods specified by 35 IAC 217.710, the emissions of NO_x for purposes of these standards are generally calculated in accordance with the federal Acid Rain Program and are different from the emissions determined for purposes of the NO_x Trading Program.

- ii. If the Permittee elects to have an affected boilerEGU comply by participation in a NO_x averaging demonstration as provided for and authorized above:
- A. The affected boilerEGU shall be included in only one NO_x averaging demonstration during an ozone control period, pursuant to 35 IAC 217.708(d).
- B. The NO_x averaging demonstration shall only include other ~~EGU~~EGUs that are authorized through a federally enforceable permit to participate in a NO_x averaging demonstration and for which the owner or operator of the EGU maintains the required records, data and reports and submits copies of such records, data, and

Formatted: Subscript

reports to the Illinois EPA upon request, pursuant to 35 IAC 217.708(c) and (g).

- C. The effect of failure of the NO_x averaging demonstration to show compliance shall be that the compliance status of the ~~affected boiler~~EGU shall be determined pursuant to Condition 7.1.4(f)(i)(A) as if the NO_x emission rates of the ~~affected boiler~~EGU ~~were~~was not averaged with other ~~EGU~~EGUs, pursuant to 35 IAC 217.708(~~g~~f).

Formatted: Subscript

Formatted: Subscript

Note: The above requirements also apply as a matter of rule to EGUs other than the ~~affected boiler~~EGUs if the owner or operator of such other EGUs elects to participate in a NO_x averaging demonstration.

Formatted: Subscript

- g. The affected boiler is subject to 35 IAC 212.122 which provides that no person shall cause or allow the opacity from a new fuel combustion emission unit with a heat input greater than 250 mmBtu/hr to exceed 20 percent, except as provided by 35 IAC 212.122(b).

7.1.5 Non-Applicability of Regulations of Concern

- a. i. This permit is issued based on the affected boilers not being subject to the NSPS standards for firing of oil, i.e., 40 CFR 60.43(a)(1) for SO₂ and 40 CFR 60.44(a)(2) for NO_x, when they are using coal or other solid fuel ~~(coal)~~ as their principal fuel and distillate fuel oil is only used in incidental amounts for specific purposes, such as startup, opacity reduction emission mitigation, flame stabilization, outage of a coal pulverizer, or other temporary interruption in solid fuel supply, as associated with routine firing of solid fuel.
- ii. If an affected boiler is not using coal or other solid fuel ~~(coal)~~ as its principal fuel, the boiler shall comply with the requirements of the following NSPS standards that address burning a combination of fuels:
 - A. For SO₂, 40 CFR 60.43(b). For this purpose, the applicable SO₂ standard for heat input from liquid fuel shall be 0.8 lb/mmBtu, pursuant to 40 CFR 60.43(a)(1) and (b).
 - B. For NO_x, 40 CFR 60.44(b). For this purpose, the applicable NO_x standards for heat input from natural gas and liquid fuel shall be 0.2 and 0.3 lb/mmBtu,

Formatted: Subscript

Formatted: Subscript

Formatted: Subscript

respectively, pursuant to 40 CFR 60.44(a)(1) and (2), respectively.

- b. i. The Permittee is shielded from the following rules for the affected boilers when the boilers are using coal or other solid fuel ~~(coal)~~ as their principal fuel. This is because incidental use of ~~other fuels~~ natural gas or liquid fuel generally serves as a good combustion practice for firing of solid fuel and does not provide a decrease in emissions that can be used to reduce the emission rate that must be achieved for the emissions associated with combustion of solid fuel.
 - A. 35 IAC 212.207
 - B. 35 IAC 214.162
 - C. 35 IAC 217.121(e)
- ii. If an affected boiler is not using coal or other solid fuel ~~(coal)~~ as its principal fuel, the affected boiler shall comply with the requirements of the following conditions. During such periods, for PM emissions, Condition 7.1.5(b)(ii)(A) shall substitute for Condition 7.1.4(b). For SO₂ emissions, Condition 7.1.5(b)(ii)(B), below, shall supplement Condition 7.1.4(c). For NO_x emissions, Condition 7.1.5(b)(ii)(C) shall substitute for Condition 7.1.4(e).
 - A. The emissions of PM from the affected boiler in any one hour period shall not exceed the amount, in lb/hr, allowed by the formula in 35 IAC 212.207. For this purpose, the applicable PM standard for heat input from liquid fuel shall be 0.1 lb/mmBtu, pursuant to 35 IAC 212.206 and 212.207.
 - B. The emissions of SO₂ from the affected boiler in any one hour period shall not exceed the amount, in lb/hr, allowed by the formula in 35 IAC 214.162. For this purpose, the applicable SO₂ standards for heat input from residual fuel oil and distillate fuel oil shall be 0.8 and 0.3, respectively, pursuant to 35 IAC 214.121(b)(1), 214.121(b)(2), and 214.162.

Formatted: Subscript

- C. The emissions of NO_x from the affected boiler shall not exceed the amount, in lb/hr, allowed by the formula in 35 IAC 217.121(e).
- iii. For the purpose of the above conditions, an affected boiler shall be considered to be using coal or other solid fuel ~~(coal)~~ as its principal fuel if the use of natural gas and/or fuel oil is incidental to the use of ~~coal~~ solid fuel, occurring for specific purposes associated with routine firing of solid fuel, such as startup, opacity reduction emission mitigation, flame stabilization, outage of a coal pulverizer, or other temporary interruption in solid fuel supply. A boiler shall not be considered to be using solid fuel as its principal fuel if the use of natural gas and/or fuel oil is more than incidental to the firing of ~~coal~~ solid fuel in the boiler or the use of ~~coal~~ solid fuel is incidental to the operation of the boiler.
- iv. The Permittee shall notify the Illinois EPA if the status of an affected boiler changes to or from using coal or other solid fuel ~~(coal)~~ as its principal fuel. This notification shall be provided at least 7 days in advance of such change in status unless the change results from a sudden event that precludes such advance notification, in which case notification shall be provided as soon as practicable prior to the change.
- c. Pursuant to 35 IAC 201.403(a), the Permittee is not subject to the requirements of 35 IAC Part 201 Subpart L for opacity monitoring because the Permittee ~~must conduct~~ conducts opacity monitoring ~~on~~ of the affected boilers in accordance with the provisions of the NSPS, as specified at 40 CFR 75.14 of the federal Acid Rain Program.
- d. The affected boilers are not subject to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for Major Stationary Sources for SO₂ and NO_x Acid Rain Requirements, because the affected boilers are subject to Acid Rain Program requirements, pursuant to 40 CFR 64.2(b)(1)(iii).
- e. The affected boilers are not subject to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for Major Stationary Sources for SO₂ and NO_x State Rule Requirements because the affected boilers are subject to an emission limitation or standard for which this CAAPP permit specifies a continuous compliance

determination method, pursuant to 40 CFR 64.2(b)(1)(vi).

f. The affected boilers are not subject to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for Major Stationary Sources for CO State Rule Requirements because the affected boilers do not use an add-on control device to achieve compliance with an emission limitation or standard.

7.1.6 Work Practices, Operational and Production Limits, and Emission Limitations

- a. i. At all times, the Permittee shall maintain and operate the affected boilers, including associated air pollution control equipment, in a manner consistent with good air pollution control practice for minimizing emissions, as required pursuant to the NSPS, 40 CFR 60.11(d).
- ii. As part of its operation and maintenance of the affected boilers, the Permittee shall perform ~~formal~~ "a combustion evaluation" on each boiler ~~on~~ at least ~~a quarterly basis~~ semi-annually, pursuant to Section 39.5(7)(d) of the Act. ~~These~~ This evaluation shall consist of ~~diagnostic process~~ measurements of the concentration of CO in the flue gas of the affected boiler, ~~with as well as any adjustments and/or preventative and corrective measures undertaken for the boiler's combustion systems to maintain efficient combustion of the boilers.~~
- ~~b. i. The only fuels fired in the primary air duct burners of affected boiler 2 shall be natural gas and distillate fuel oil. [T1]~~
- ~~ii. A. The fuel usage of the primary air duct burners of affected boiler 2 shall not exceed 250 gallons/hour, total. [T1]~~
- ~~B. The total annual fuel consumption by the primary air duct burners of affected boiler 2 shall not exceed 1,610,000 gallons. [T1]~~
- ~~C. For this purpose, if natural gas is burned, 1,000 standard cubic feet of gas shall be considered equivalent to 7.45 gallons of oil. [T1]~~

~~iii. The emissions of the primary air duct burners of affected boiler 2 shall not exceed the following limitations. [T]~~

<u>Pollutant</u>	<u>Limitation</u>	
	<u>Lb/Hr (Each)</u>	<u>Ton/Year (Total)</u>
NOx	5.0	16.1
CO	1.25	4.0
SO₂	9.94	32.0
PM	0.5	1.6

~~iv. Compliance with annual limitations shall be determined on a monthly basis from the sum of the data for the current month plus the preceding 11 months (running 12 month total). [T]~~

~~Note: The above requirements were established in Permit 01030065.~~

7.1.7 Testing Requirements

Pursuant to Section 39.5(7)(d)(ii) of the Act, the Permittee shall have the PM and CO emissions of each affected boiler measured as specified below:

- a. i. PM emission measurements shall be made no later than one year after the ~~effective date~~ effectiveness of this condition. (Measurements made after December 31, 2003 may satisfy this requirement.)
- ii. PM emission measurements shall be made within 90 days of operating an affected boiler for more than ~~30-72~~ hours total in a calendar quarter at a load* that is more than ~~215~~ percent higher than the greatest load on the boiler, during the most recent set of PM tests on the affected boiler in which compliance is shown (refer to Condition 7.1.7(e) ~~(iii)(D)~~), provided, however, that the Illinois EPA may upon request of the Permittee provide more time for testing (if such time is reasonably needed to schedule and perform testing or coordinate testing with seasonal conditions). Notwithstanding Condition 5.10, this condition shall take effect after the first complete quarter following the effectiveness of this condition.

* For this purpose, load shall be expressed in terms of either gross megawatt output or steam flow, consistent with the form

of the records kept by the Permittee pursuant to Condition 7.1.9(a).

- iii. Periodic PM emission measurements shall be made for the affected boilers within a time period determined from the compliance margin for the applicable PM emission standard, based on the results of the preceding PM measurement, as follows. For this purpose, the compliance margin is the extent to which the actual PM emissions as measured are lower than the applicable PM limit. For example, if the measured PM emissions of the affected boiler are 0.075 lb/mmBtu, the compliance margin for the applicable PM limit, 0.10 lb/mmBtu, would be 25 percent. $(0.100 - 0.075) / 0.100 = 0.25$, or 25 percent
 - A. If the compliance margin is less than 20 percent, within 15 months of the previous measurement.
 - B. If the compliance margin is between 20 and 40 percent, within 27 months of the previous measurement.
 - C. If the compliance margin is greater than 40 percent, within 39 months of the previous measurement.
- iv. Measurements of CO emissions shall be made as follows:
 - A. In conjunction with the initial measurements of PM emissions as required above by Condition 7.1.7(a)(i) (unless this PM measurement is conducted prior to the issuance of this permit), if a measurement of CO emissions is not otherwise performed earlier in conjunction with a relative accuracy test audit (RATA) for SO₂ or NO_x conducted under this permit.
 - B. In conjunction with each subsequent measurement of PM emissions made pursuant to Condition 7.1.7(a)(ii) or (iii) (or a RATA for SO₂ or NO_x preceding such measurement), provided, however, that if measured CO emissions are no more than 100 ppm at 50 percent excess air, CO measurements need not be performed with the next PM measurement (or preceding RATA) but shall be performed with the second measurement of PM emissions

Formatted: Subscript

Formatted: Subscript

following the measurement in which CO emissions were no more than 100 ppm (or a RATA preceding that PM measurement).

- v. A. If standard fuel (i.e., coal, fuel oil, and gas) is less than 97.0 percent by weight of the fuel ~~supply to~~ burned in a boiler during a calendar quarter, unless measurements for PM and CO emissions have already been conducted while burning alternative fuel or process waste at a percentage that is greater than or equal to the percent of those materials burned in that calendar quarter or at the maximum rate at which the systems that feed alternative fuel or process waste to the boiler will be operated, the Permittee shall have measurements of PM and CO emissions from the boiler made during the next calendar quarter ~~while firing~~ in which alternative fuel or process waste is burned in the boiler. Notwithstanding Condition 5.10, this condition shall take effect after the first complete quarter following the effectiveness of this condition.
- B. The Permittee shall conduct such measurements while firing the boiler ~~withat the lower of the following:~~ (i) at least 1.25 times the ~~greatest~~ percentage of alternative fuel material or process waste in the calendar quarter that triggered the testing. This percentage at which testing shall be conducted shall not exceed that allowed by; or (ii) at the maximum design capacity of rate at which the systems that feed alternative fuel ~~handling system~~ or process waste to the boiler will be operated. If the boiler has been ~~firing~~ burning a mix of alternative fuel materials or process wastes, the mix of fuel during such measurements shall be approved by the Illinois EPA.
- C. The Permittee shall repeat such measurements if the percentage of alternative fuel materials and process wastes burned in a boiler during a quarter is more than the percentage of such material ~~in the fuel supply to~~ being burned in the boiler when previous emission measurements were conducted.

- vi. Measurements of PM and CO emissions shall be made within 90 days (or such later date set by the Illinois EPA) following a request by the Illinois EPA for such measurements.
- b. i. These measurements shall be performed at the maximum operating loads of the affected boilers and other operating conditions that are representative of normal operation. In addition, the Permittee may perform measurements at other operating conditions to evaluate variation in emissions.
- ii. Measurements shall be taken at an appropriate location in the ductwork or stack associated with the affected boiler.
- iii. The following ~~test-Reference m~~Methods and procedures shall be used for these measurements. Refer to 40 CFR 60, Appendix A for USEPA Methods.

Location of Sample Points	USEPA Method 1
Gas Flow and Velocity	USEPA Method 2
Flue Gas Weight	USEPA Method 3
Moisture	USEPA Method 4
Particulate Matter (PM)	USEPA Methods 5- 6-202*
Carbon Monoxide (CO)	USEPA Method 10

Other test methods adopted by USEPA may be used in place of the above methods with the approval of the Illinois EPA.

~~* Measurements of condensable PM are also required by USEPA Method 202 (40 CFR Part 51, Appendix M) or other established test method approved by the Illinois EPA, except for a test conducted prior to issuance of this permit.~~

- c. Except for minor deviations in test methods, as defined by 35 IAC 283.130, emission testing shall be conducted in accordance with a test plan prepared by the testing service or the Permittee and submitted to the Illinois EPA for review prior to emission testing, and the conditions, if any, imposed by the Illinois EPA as part of its review and approval of the test plan, pursuant to 35 IAC 283.220 and 283.230.
- i. The Permittee shall submit this test plan ~~at least 60 days prior to~~within the actual date of testing time period provided in Condition 8.6.2 and the test plan shall include the information specified by Condition 8.6.2.

- ii. Notwithstanding the above, as provided by 35 IAC 283.220(d), the Permittee need not submit a test plan for emission testing that will be conducted in accordance with the procedures used for previous tests accepted by the Illinois EPA or the previous test plan submitted to and approved by the Illinois EPA, provided that the Permittee's notification for testing, as required below, contains the information specified by 35 IAC 283.220(d)(1)(A), (B) and (C).
- d. The Permittee shall notify the Illinois EPA prior to conducting emission tests to enable the Illinois EPA to observe testing. Notification for the expected test date shall be submitted a minimum of 30 days prior to the expected date of testing. Notification of the actual date and expected time of testing shall be submitted a minimum of 5 working days prior to the actual test date. The Illinois EPA may on a case-by case basis accept shorter advance notice if it would not interfere with the Illinois EPA's ability to observe testing.
- e. The Permittee shall submit the Final Report(s) for any required emission testing to the Illinois EPA within 45 days after the tests results are compiled and finalized but no later than 120 days after the date of testing. The Final Report shall include the information specified in Condition 8.6.3 and the following information:
 - i. Description of test method(s), including description of sampling points, sampling train, analysis equipment, and test schedule.
 - ii. A description of any minor deviations from the test plan, as provided by 35 IAC 283.230(a).
 - iii. Detailed description of operating conditions during testing, including:
 - A. Source(s) of fuel and specifications (ash, sulfur and heat content).
 - B. Boiler operating information, i.e., firing rate of the affected boiler(s) (mmBtu/hr), composition of fuel as burned (ash, sulfur and heat content), and fuel blending ratio (%), if a blend of fuels is burned.
 - C. Combustion system information, i.e., ~~settings for distribution of primary and~~

~~secondary combustion air, target level for of excess air O₂ in the flue gas, and levels of CO, CO₂ or O₂ in the flue gas, as determined by any diagnostic measurements.~~

- D. Control equipment ~~information, i.e., equipment condition and~~ operating parameters during testing including any use of the flue gas conditioning system.
- E. Load during testing (gross megawatt output and steam flow).

F. Information on the usage of alternative fuel materials or process wastes during testing, if testing was conducted to satisfy Condition 7.1.7(a)(v).

- iv. Data and calculations, including copies of all raw data sheets and records of laboratory analyses, sample calculations, and data on equipment calibration.
- v. The SO₂, NO_x, O₂ or CO₂, (hourly averages) and opacity data (6-minute averages) measured during testing.

Formatted: Subscript

7.1.8 Monitoring Requirements

- a. Pursuant to ~~NSPS,~~ 40 CFR 60.45, 40 CFR 75.14, and Section 39.5(7)(d)(iii) of the Act, the Permittee shall install, operate, calibrate and maintain continuous monitoring equipment for the measurement of opacity from the affected boilers.
 - i. The Permittee shall operate this equipment in accordance with the general provisions for opacity monitoring systems in 40 CFR 75.10.
 - ii. These monitors shall be the primary basis for reporting of exceedances of Conditions 7.1.4(a)(iii), in accordance with 40 CFR 60.7(c) and 60.45(g), and Condition 7.1.4(g). (See Conditions 7.1.10-2(a) and 7.1.10-3(a).)
- b. Pursuant to 40 CFR 60.45, 40 CFR 75.11, and Section 39.5(7)(d)(iii) of the Act, the Permittee shall install, operate, calibrate and maintain a continuous emission monitoring system (CEMS) for the measurement of SO₂ emissions from the affected boilers.
 - i. These CEMS shall be used to demonstrate compliance with the limits in Condition 7.1.4(c)

based on the average hourly SO₂ emission rate determined from monitored data from three-hour block averaging periods.

Note: This permit is issued based on the Permittee performing continuous emission monitoring for SO₂ rather than fuel sampling and analysis for sulfur content as allowed by 40 CFR 60.45(b)(2). In addition, the permit allows the use of an "Acid Rain Monitoring System", operated to comply with 40 CFR Part 75, in lieu of an "NSPS Monitoring System", as authorized by USEPA guidance from the Stationary Source Compliance Division of the Office of Air Quality Planning and Standards, as such monitoring is equivalent or more stringent.

c. Pursuant to 40 CFR 60.45, 40 CFR 75.12, 35 IAC 217.710(a), and Section 39.5(7)(d)(iii) of the Act, the Permittee, shall install, calibrate, maintain and operate a CEMS for the measurement of NO_x emissions from the affected boilers, in accordance with the requirements of 40 CFR 75 Subpart B.

Formatted: Subscript

d. Pursuant to Section 412 of the Clean Air Act and 40 CFR Part 75, the source is required to operate continuous monitors for the affected boilers for various parameters, including SO₂, NO_x, volumetric flow and opacity, along with a computerized data acquisition and handling system for collected data. (See also Condition 6.2.3) To the extent that applicable performance specifications and operating requirements for monitoring under 40 CFR Part 75 are inconsistent with the above requirements for monitoring, the procedures of 40 CFR Part 75 shall take precedence. (See also Condition 8.2.)

Formatted: Subscript

e. Compliance Assurance Monitoring (CAM) Requirements

The affected boilers are subject to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for Major Stationary Sources as addressed in Conditions 7.1.13-1 and 7.1.13-2.

~~The affected boilers are subject to 40 CFR Part 64, (2005), Compliance Assurance Monitoring (CAM) for Major Stationary Sources. The Permittee shall comply with the monitoring requirements of the CAM Plan described in Attachment 6, pursuant to 40 CFR Part 64 as submitted in the Permittee's CAM plan application. At all times, the owner or operator shall maintain the monitoring, including but not limited to, maintaining necessary parts for routine repairs of the monitoring equipment [40 CFR 64.7(a) and (b)].~~

i. Continued Operation [40 CFR 64.7(e)]

Except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the owner or operator shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant specific emissions unit is operating. Data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities shall not be used for purposes of this part, including data averages and calculations, or fulfilling a minimum data availability requirement, if applicable. The Permittee shall use all the data collected during all other periods in assessing the operation of the control device and associated control system. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

ii. Response to Excursions or Exceedances [40 CFR 64.7(d)]

A. Upon detecting an excursion or exceedance, the Permittee shall restore operation of the pollutant-specific emissions unit (including the control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in accordance with good air pollution control practices for minimizing emissions. The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion or exceedance (other than those caused by excused startup or shutdown conditions). Such actions may include initial inspection and evaluation, recording that operations returned to normal without operator action (such as through response by a computerized distribution control system), or any necessary follow up actions to return operation to within the indicator range, designated condition, or below the applicable emission limitation or standard, as applicable.

B. Determination of whether the Permittee has used acceptable procedures in response to an excursion or exceedance will be based on information available, which may include but is not limited to, monitoring

~~results, review of operation and maintenance procedures and records, and inspection of the control device.~~

7.1.9 Recordkeeping Requirements

a. Operational Records for Affected Boilers

Pursuant to Sections 39.5(7)(a) and (e) of the Act, the Permittee shall maintain the following operational records for the affected boilers:

- i. ~~Records of the occurrence and duration of any startup, shutdown, or malfunction in the operation of an affected facility; any malfunction of the air pollution control equipment; or any periods during which a continuous monitoring system or monitoring device is inoperative [40 CFR 60.7(b)].~~
- ~~i. An operating log for each affected boiler, which shall include the following information:~~
 - ~~A. Information for each startup and shutdown of the boiler, including date, time and duration, as required by 40 CFR 60.7(b). (See also Condition 7.1.9(g).)~~
 - ~~B. Information for any incident in which the operation of the affected boiler continued during malfunction or breakdown, including: date, time, and duration; a description of the incident; whether emissions exceeded or may have exceeded any applicable standard; a description of the corrective actions taken to reduce emissions and the duration of the incident; and a description of the preventative actions taken, as addressed by 40 CFR 60.7(b). (See also Condition 7.1.9(h).)~~
- ii.
 - A. Load (in terms of either gross megawatts output or steam flow) on an hourly basis for each affected boiler.
 - B. If the Permittee is relying on data for heat input for purposes of compliance with Condition 7.1.4(a)(ii), (b) or (c) that is different from that recorded pursuant to the federal Acid Rain Program, records of heat input (mmBtu, on an hourly basis) or the conversion factors that the Permittee relies upon to

convert from boiler load as recorded above to hourly heat input.

- iii. Records for each day when an alternative fuel (i.e., a fuel other than coal, gas or oil) or process waste was burned, including the estimated amount of each such material burned and the affected boiler(s) in which it was burned.
 - iv. Total operating hours (hours/quarter) for each affected boiler.
 - v.
 - A. Amount of coal consumed (tons/quarter).
 - B. Amount of each ~~other~~ alternative fuel ~~material~~ or process waste consumed (tons, gallons, cubic feet per quarter, as appropriate).
 - vi.
 - A. Records of agreements with suppliers of alternative fuel(s), including origin of material, specifications for heat and ash content, and representative data for elemental composition of such material, including mercury and other heavy metals, chlorine and fluorine.
 - B. Records for each load of such ~~material~~ fuel(s) received at the source, which at a minimum shall include date, supplier name, type of ~~material-fuel~~ and amount (tons).
 - vii. An operating log, maintenance and repair log, or other records for each affected boiler documenting the performance of the combustion evaluation required by Condition 7.1.6(a) (ii), including the date of the evaluation, the concentrations of CO measured at the start and conclusion of the evaluation, and a description of any adjustments and or ~~preventative and~~ corrective measures undertaken for the combustion systems of the boiler.
- b. Records for Control Equipment
- Pursuant to Sections 39.5(7) (a) and (e) of the Act, the Permittee shall maintain the following records for the air pollution control equipment on the affected boilers:

i. Maintenance and Repair Log

A maintenance and repair log for each control device, which shall list the activities performed, with date and description. (See also Condition 9.6.1, Control Equipment Maintenance Records.)

ii. Electrostatic Precipitators (ESP)

When an affected boiler served by the ESP is in operation:

- A. The status of each ESP-field in the ESP shall be recorded at least once per shift.
- B. The following numerical data shall be recorded at least once per day: (1) Primary voltages and currents; (2) Secondary voltages and currents; and (3) Sparking rates.

iii. Flue Gas Conditioning (FGC) Systems

- A. Manufacture/vendor or Permittee developed operating and maintenance procedures.
- B. Operating logs, including identification of conditioning agent and system settings.

Note: These ~~logs~~records only need to be maintained during periods when the Permittee operates these systems, which are operated at its discretion as needed to comply with applicable requirements.

c. Records for Continuous Opacity Monitoring Systems

Pursuant to Section 39.5(7)(e) of the Act, and the NSPS, 40 CFR 60.45, the Permittee shall maintain records for the opacity monitoring system on each affected boiler required by Condition 7.1.8(a) that as a minimum shall include the following:

- i. Operating records for each opacity monitoring system, including:
 - A. Opacity measurements (6-minute, one-hour and three-hour block averages).
 - B. ~~Continuous monitoring system performance~~Performance testing measurements.

~~C.~~ Performance and evaluations, calibration checks, and other quality assurance/control activities.

~~D.~~ Calibration checks.

~~EC.~~ Maintenance and adjustment performed.

~~FD.~~ Periods other than performance of quality assurance, calibration, and maintenance, as addressed above, when the monitor was inoperative, with reason.

~~GE.~~ Quarterly reports submitted in accordance with NSPS, 40 CFR 60.7(c), and Condition 7.1.10-2(a) and (d).

~~ii.~~ Records for each affected boiler that identify the upper bound of the 95% confidence interval (using a normal distribution and 1 minute averages) for opacity measurements from the boiler, considering an hour of operation, within which compliance with the PM limitations in Conditions 7.1.4(a)(ii) and 7.1.4(b) is assured, with supporting explanation and documentation, including results of historic emission tests. At a minimum, these records shall be reviewed and revised as necessary following performance of each subsequent PM emission test on the affected boiler. Copies of these records shall be submitted to the Illinois EPA in accordance with Condition 5.6.2(d).

~~iii.~~ Records to address compliance with Conditions 7.1.4(a)(ii), (iii), (b) and (g) including:

ii. Records to address compliance with Conditions 7.1.4(a), (b) and (g), including:

A. Each 6-minute period when the opacity was above the limitation of Conditions 7.1.4(a)(iii) and (g) (20 percent opacity) with date, time, whether it occurred during startup, malfunction, breakdown, or shutdown, and further explanation of the incident.

B. Each three-hour block averaging period when the measured average opacity of an the affected boilers was above the upper bound, as specified above in Condition 7.1.9(c)(ii) 20 percent, with date, time, measured opacity (three-hour block average),

operating condition if startup, malfunction, breakdown, or shutdown, further explanation description of the incident, and whether particulate matter if other information shows that the PM emissions of an affected boiler(s) may have exceeded or likely exceeded the limit of Conditions 7.1.4(a)(ii) and 7.1.4(b), a description of that information with explanation.

Note: For purposes of this Condition 7.1.9(c)(ii)(B), a three-hour block average is the average of three consecutive one-hour block averages.

d. Records for Continuous SO₂ Monitoring Systems

Pursuant to Section 39.5(7)(e) of the Act and the NSPS, 40 CFR 60.45, the Permittee shall maintain records for the SO₂ CEMS on ~~each~~ the affected boiler/boilers required by Condition 7.1.8(b) that as a minimum shall include the following:

- i. Operating records for each SO₂ CEMS, including:
 - A. SO₂ emission data ~~into~~ in the units of the applicable standards (lb/mmBtu) calculated in accordance with NSPS, 40 CFR 60.45(e).
 - B. ~~Continuous monitoring system performance~~ Performance testing measurements.
 - ~~C. Performance and evaluations, calibration checks,~~ and other quality assurance/control activities.
 - ~~D. Calibration checks.~~
 - EC. Maintenance and adjustments performed.
 - FD. Periods when the SO₂ CEMS was inoperative, with date, time and reason.
 - GE. Data reduction information.
 - HF. Quarterly reports submitted in accordance with NSPS, 40 CFR 60.7(c) and Condition 7.1.10-2(b).

- ii. Records to verify compliance with the limitation of Condition 7.1.4(a)(ii) and 7.1.4(c), including:
 - A. SO₂ emissions in the terms of the applicable standard (lb/mmBtu) from the affected boilers on an hourly basis, as derived from the data obtained by the SO₂ CEMS.
 - B. The date and time of any three-hour ~~rolling block~~ averaging period when the total SO₂ emission rate, as recorded above, exceeded 1.2 lb/mmBtu as allowed by Condition 7.1.4(a)(ii) and 7.1.4(c), with the calculated SO₂ emission rate. These records shall be prepared from the above records at least quarterly as needed to verify compliance with the limitation of Condition 7.1.4(a)(ii) and 7.1.4(c).

e. Records for Continuous NO_x Monitoring

Pursuant to 35 IAC 217.712(a), Section 39.5(7)(e) of the Act and the NSPS, 40 CFR 60.45, the Permittee shall maintain records for the NO_x CEMS on each affected boiler required by Condition 7.1.8(c) in accordance with the applicable recordkeeping requirements of 40 CFR 75, that as a minimum shall include the following:

- i. Operating records for each NO_x CEMS, including:
 - A. NO_x emission data ~~into~~ in the units of the applicable standards (lb/mmBtu) calculated in accordance with NSPS, 40 CFR 60.45(e).
 - B. ~~Continuous monitoring system p~~Performance testing measurements.
 - ~~C. Performance~~ Performance and evaluations, calibration checks, and other quality assurance/control activities.
 - ~~D. Calibration checks.~~
 - ~~EC~~ Maintenance and adjustments performed.
 - ~~FD~~ Periods when a NO_x CEMS was inoperative, with date, time and reason.
 - ~~GE~~ Data reduction information.

Formatted: Subscript

Formatted: Subscript

Formatted: Subscript

Formatted: Subscript

Formatted: Subscript

~~##E~~. Quarterly reports submitted in accordance with Condition 7.1.10-2(c).

ii. Records to verify compliance with the limitation of Conditions 7.1.4(a)(ii) and 7.1.4(e) including:

A. ~~NO_x emissions in the terms of the applicable standard (lb/mmBtu) from the affected boilers on an hourly basis, as derived from the data obtained by the NO_x CEMS.~~

Formatted: Subscript

B. The date and time of any three-hour ~~rolling block~~ averaging period when the total NO_x emission rate, as recorded above, exceeded 0.7 lb/mmBtu as allowed by Condition 7.1.4(a)(ii) and 7.1.4(e), with the calculated NO_x emission rate. These records shall be prepared from the above records at least quarterly as needed to verify compliance with the limitation of Condition 7.1.4(a)(ii) and 7.1.4(e).

Formatted: Subscript

Formatted: Subscript

Formatted: Subscript

f. Acid Rain Program

Records for the continuous emission monitoring required for the affected boilers by the Acid Rain Program should be kept by the Permittee in accordance with 40 CFR Part 75, including the General Recordkeeping Provisions; the General Recordkeeping Provisions for Specific Situations, if applicable; and Certification, Quality Assurance and Quality Control Record Provisions [See Condition 6.2.3].

g. Records for Startups of Affected Boilers, pursuant to Section 39.5(7)(b) of the Act

~~Pursuant to 35 IAC 201.263 and Sections 39.5(7)(a) and (c) of the Act, the Permittee shall maintain the following records related to startup of the affected boilers:~~

i. The Permittee~~s~~ shall maintain written startup procedures for each affected boiler, (as required by Condition 7.1.3(b)(ii))~~, accompanied by the Permittee's estimate of both total and excess opacity and emissions of PM and CO during typical startup(s) of each boiler, with supporting information and calculations.~~

- ii. ~~Records for each startup of an affected boiler that, at a minimum, include~~The Permittee shall maintain the following records related to startups of an affected boiler information:
- A. For all startups on each affected boiler.
- ~~1I.~~ Date, time, and duration and description of the startup.
- ~~2II.~~ A description of the startup, the reason(s) for the startup, and an indication of whether or not written
- ~~B. The elapsed time from initial firing of auxiliary fuel to achievement of stable operation of the boiler with the principal fuel and with boiler systems and control devices operating to enable compliance with applicable standards for opacity and emissions of PM and CO.~~
- ~~C. If this elapsed time is more than 8 hours for Boiler NB 1 or NB 2 or if the Permittee's startup procedures are not followed:~~
- ~~I. A detailed explanation why startup of the boiler was not completed sooner or startup procedures were not followed. If any procedures were not followed, the records shall include any departures from the established~~
- ~~II. Documentation for the startup procedures that were and the reason the procedure could not be followed.~~
- ~~III B. For each startup of an affected boiler where an exceedance of a relevant standard occurred during startup or the Permittee believes that compliance with the PM standard likely was not maintained during the startup, maintain the following additional records for such startups. The elapsed time from initial firing of auxiliary fuel until firing of the principal fuel was begun.~~

1. Identification of the applicable standard(s) that were or may have been exceeded.

I. An explanation of the nature of such exceedance(s), including the qualitative or, if available, quantitative magnitude of such excess emissions.

II. A description of the actions taken or to be taken to minimize the magnitude and duration of any excess emissions.

III. An explanation whether similar incidents could be prevented in the future and if so, a description of the actions taken or to be taken to prevent similar incidents in the future.

C. For each startup when the duration of startup from initial firing of fuel to stable operation of the generating unit at load exceeded 20 hours maintain the following additional records for such startups.

I. A description of the events that led up to the extended startup duration and reason(s) for the extended startup duration.

II. The actions taken to minimize emissions and the duration of the startup.

III. An explanation whether similar incidents might be prevented in the future and if so, the corrective actions taken or to be taken to prevent similar incidents.

h. Records for Continued Operation During Malfunctions and Breakdowns

Pursuant to 35 IAC 201.263 and Sections 39.5(7) (a) and (e) of the Act, the Permittee shall maintain the following records related to malfunction and breakdown of the affected boilers:

i. Maintenance and repair log(s) records for the affected boilers that, at a minimum, address

Formatted: Normal, Indent: Left: 3", Hanging: 0.5", No bullets or numbering, Allow hanging punctuation, Font Alignment: Auto, Tab stops: 1", Left + 1.75", Left + 2.63", Left + Not at 1.5" + 2.5"

aspects or components of the boilers for which malfunction or breakdown has resulted in excess emissions, which shall list the activities performed on such aspects or components, with date, description and reason for the activity. In addition, in the maintenance and repair ~~log(s) records~~ for control equipment required by Condition 7.21.9(b)(i), the Permittee shall also list the reason for the activities that are performed.

- ii. Records for each incident when operation of an affected boiler continued with excess opacity or emissions, ~~including during~~ malfunction or breakdown as addressed by Condition 7.1.3(c), that, ~~at a minimum, shall~~ include the following information:
 - A. Date, time, duration (i.e., the length of time during which operation continued with excess opacity or emissions until corrective actions were taken or the boiler was taken out of service), and description of the incident.
 - B. The corrective actions used to reduce the quantity of emissions and to reduce the duration of the incident.
 - C. Confirmation of fulfillment of the requirements of Condition 7.1.10-3(a), as applicable, including copies of any follow-up reports submitted pursuant to Condition 7.1.10-3(a)(ii).
 - D. If opacity during the incident exceeded the applicable standard for two or more hours ~~or~~, emissions exceeded ~~or may have exceeded~~ an applicable hourly standard, as listed in Condition 7.1.4, or the Permittee believes that compliance with the PM standard likely was not maintained, during the incident:
 - I. A detailed explanation why continued operation of the affected boiler was necessary.
 - II. The preventative measures that have been or will be taken to prevent similar incidents or reduce their frequency and severity, including any repairs to the affected boilers

and associated equipment and any changes to operating and maintenance procedures.

~~III. Estimates An explanation of the magnitude of whether emissions of PM and CO during the incident, as emissions may have exceeded any applicable hourly standard.~~

~~E. If PM emissions during the incident exceeded an applicable hourly standard, as listed in Condition 7.1.4, or the Permittee believes that compliance with the PM standard likely was not maintained, estimates of the magnitude of emissions of PM during the incident, with magnitude estimated on a qualitative or, if available, quantitative basis.~~

Formatted: Indent: Hanging: 0.37", Don't keep with next, Tab stops: 1.75", Left + Not at 1.69" + 2.16"

~~F. If CO emissions during the incident exceeded an applicable hourly standard, as listed in Condition 7.1.4, estimates of the magnitude of emissions of CO during the incident, with magnitude estimated on a qualitative or, if available, quantitative basis.~~

Formatted: Font: Courier New, 10 pt

~~i. Records for the Primary Air Duct Burners~~

Formatted: Font: Courier New, 10 pt

~~The Permittee shall keep the following records for affected boiler 2 as needed to demonstrate compliance with Condition 7.1.6(b):~~

- ~~i. The maximum fuel firing capacity of each duct burner, gallons/hour, and the associated maximum emission rates, lb/hour, with supporting documentation and calculations.~~
- ~~ii. Fuel usage by the duct burners, gallons/month and scf/month, either as determined directly from fuel meters or calculated from operating records kept for the duct burners, e.g., the product of the operating hours of the duct burners and their maximum firing rates.~~
- ~~iii. An inspection and maintenance log for the duct burners.~~
- ~~iv. Emissions of the duct burners, tons/month and tons/year, calculated with appropriate emission factors from AP-42, based on the above records, with supporting calculations.~~

7.1.10-1 Reporting Requirements - Reporting of Deviations

a. ~~Prompt Reporting of Deviations~~

For each affected boiler, the Permittee shall promptly notify the Illinois EPA of deviations from permit requirements as ~~follows specified below. At a minimum, these~~ These notifications shall include a description of such deviations, including whether they occurred during startup or malfunction/breakdown, and a discussion of the ~~possible~~ probable cause of such deviations, any corrective actions taken and any preventative measures taken [Section 39.5(7)(f)(ii) of the Act].

i. ~~For those breakdown or malfunction PM or opacity events that require Nnotification and reporting as specified in pursuant to Condition 7.1.10-3(a) for certain deviations from the PM limits in Condition 7.1.4(a)(ii) and (b)-,~~

~~ii. Nnotification and reporting as specified in shall be provided pursuant to Condition 7.1.10-3(a) for certain deviations from the opacity limits in Condition 7.1.4(a)(iii) and (g) rather than 7.1.10-2(d).~~

~~iii. Notification with the quarterly or annual reports required by Conditions 7.1.10-2(b), (c), (d) and (e) for deviations from ConditionConditions 7.1.4(a), (b), (c), (e), (f) and (g) and from the requirements of Condition 7.1.8 for emissions monitoring, unless notification and reporting for that deviation is required pursuant to Condition 7.1.10-3(a).~~

~~iv. Notification within 30 days for a deviation from Condition 7.1.6(b), with a copy of applicable records for such incident or description of the incident and a discussion of the probable cause of such deviation, the corrective actions taken, and the preventative measures taken.~~

~~viii. Notification with the quarterly reports required by Condition 7.1.10-2(a) for deviations not addressed above by Condition 7.1.10-1(a)(i), (ii), (iii), or (iv), including deviations from other applicable requirements, e.g., the applicable CO emission standard, work practice requirements, and recordkeeping requirements.~~

b. Periodic Reporting of Deviations

The quarterly reports required by Condition 7.1.10-2(a) shall include the following information for the affected boilers related to deviations from permit requirements during the quarter [Sections 39.5(7) (a) and (f)(i) of the Act].

- i. A listing of all notifications and reports for instances of deviations that have been reported provided in writing to the Illinois EPA as provided by pursuant to Condition 7.1.10-3(a)1(a)(i), (ii) and (iv), including identification of each such written notification or report. For this purpose, the Permittee need not resubmit copies of these previous notifications or reports but may elect to supplement such material.
- ii. Detailed information, as required by Condition 7.1.10-1(a)(~~iiii~~) or (~~iviii~~), for all other deviations not addressed in the above listing.

7.1.10-2 Reporting Requirements - Periodic Reports

a. Quarterly Reports

In place of the semi-annual monitoring reports otherwise required by Condition 8.6.1, the Permittee shall submit quarterly reports to the Illinois EPA pursuant to Sections 39.5(7) (a) and (f) of the Act.

- i. These reports shall include the following information for operation of each affected boiler during the quarter:
 - A. The total operating hours for each affected boiler, as also reported in accordance with 40 CFR Part 75.
 - B. The greatest hourly load achieved by each affected boiler (steam flow or gross megawatts).
 - C. A discussion of significant changes in the fuel supply to the affected boilers, if any, including changes in the source of coal, the introduction of new fuel materials other than coal, gas and oil, and changes in the source of such other fuel materials or the maximum rate at which they will be fired.
 - D. A list of the startups of each affected boiler, including the date, duration and

description of each startup, accompanied by a copy of the records pursuant to Condition 7.1.9(g)(ii)(C) for each startup for which such records were required.

~~E. A copy of the records required by Condition 7.1.9(c)(iii)(B) identifying the date and time that the upper bound, as specified above in Condition 7.1.9(e)(ii), was exceeded, with operating condition if startup, malfunction, breakdown, or shutdown; with further explanation of the incident and whether particulate matter emissions may have exceeded the PM limit.~~

ii. These reports shall include the information specified in Conditions 7.1.10-2(b), (c) and (d) for SO₂, NO_x, and PM emissions and opacity from the affected boilers during the quarter and for the operation of required continuous monitoring systems specified by Conditions 7.1.10-2(b), (c) and (d) during the quarter.

iii. A. These reports shall be submitted after the end of every calendar quarter as follows, except as provided for in Condition 7.1.10-2(a)(iii)(B):

Monitoring Period	Submittal Deadline
January - March	April 30 <u>May 15</u>
April - June	July 30 <u>August 15</u>
July - September	October 30 <u>November 15</u>
October - December	January 30 <u>February 15</u>

B. Notwithstanding the above, the first quarterly report required pursuant to this permit shall be submitted in accordance with Condition 5.10(f), and the next three quarterly reports shall be submitted no later than 60 days after the end of each calendar quarter.

b. Reporting of SO₂ Emissions

Pursuant to Section 39.5(7) ~~(e)~~ (a) and (f) of the Act and the NSPS 40 CFR 60.45(g), the Permittee shall report the following information to the Illinois EPA in accordance with 40 CFR 60.7(c) for the affected

Formatted: Subscript

boilers with its quarterly reports pursuant to Condition 7.1.10-2(a):

- i. Summary information on the performance of the SO₂ CEMS, including the information for a "Summary Report" specified by 40 CFR 60.7(d). When the SO₂ CEMS was not inoperative, repaired or adjusted ~~except for zero and span checks, this~~ such information shall be stated in the report as specified by 40 CFR 60.7(c)(4).
- ii. If specifically requested by the Illinois EPA or the CEMS downtime was more than 5 percent of the total operating time for the affected ~~boiler~~boilers: the date and time identifying each period during which the CEMS was inoperative except for zero and span checks, and the nature of CEMS repairs or adjustments and a summary of quality assurance data consistent with 40 CFR Part 75, i.e., the dates and results of the Linearity Test(s) and any Relative Accuracy Test Audit(s) during the quarter, a listing of any days when a required daily calibration was not performed, and the date and duration of any periods when the CEMS was "out-of-control" as addressed by 40 CFR 75.24.
- iii. The following information for each period when SO₂ emissions were in excess of the applicable standards specified in Condition 7.1.4(a)(ii) and 7.1.4(c)**. When there were no such exceedances, this shall be stated in the report.
 - A. The starting date and time of the SO₂ excess emissions.
 - B. The duration of the excess emissions.
 - C. ~~A copy of the records~~The one-hour and three-hour average (lb/mmBtu) for the each three-hour block average of excess emissions, as maintained pursuant to Condition 7.1.9(d)(ii), including the measured emission rate.
 - D. A detailed explanation of the cause of the excess emissions if known, including whether such excess emissions occurred during startup, malfunction or breakdown of the boiler.

E. A detailed explanation of any corrective actions ~~and actions taken to lessen the emissions.~~

** For ~~the purpose of reporting excess~~ SO₂ emissions, the averaging period is a three-hour ~~rolling block~~ average, as used to determine compliance with the limitations of Condition 7.1.4(a)(ii) and 7.1.4(c). The records for excess emissions shall consist of three-hour ~~rolling block~~ emission averages during which the limitation was exceeded.

c. Reporting of NO_x Emissions

Formatted: Subscript

Pursuant to Sections 39.5(7)(a) and (f) of the Act and the NSPS 40 CFR 60.45(g), the Permittee shall report the following information for the affected boilers to the Illinois EPA in accordance with 40 CFR 60.7(c) with its quarterly reports pursuant to Condition 7.1.10-2(a):

i. Summary information on the performance of the NO_x CEMS, including the information for a "Summary Report" specified by 40 CFR 60.7(d). When the NO_x CEMS was not inoperative, repaired or adjusted ~~except for zero and span checks, this such information~~ shall be stated in the report as specified by 40 CFR 60.7(c)(4).

Formatted: Subscript

Formatted: Subscript

ii. If specifically requested by the Illinois EPA or the CEMS downtime was more than 5 percent of the total operating time for the affected boiler: the date and time identifying each period during which the CEMS was inoperative except for zero and span checks, and the nature of CEMS repairs or adjustments and a summary of quality assurance data consistent with 40 CFR Part 75, i.e., the dates and results of the Linearity Test(s) and any Relative Accuracy Test Audit(s) during the quarter, a listing of any days when a required daily calibration was not performed, and the date and duration of any periods when the CEMS was out-of-control as addressed by 40 CFR 75.24.

iii. The following information for each period when NO_x emissions were in excess of the limitation in Condition 7.1.4(a)(ii) and 7.1.4(e)**. When there were no such exceedances, this shall be stated in the report.

Formatted: Subscript

A. The starting date and time of the NO_x excess emissions.

Formatted: Subscript

B. The duration of the excess emissions.

C. ~~A copy of the records for the excess emissions, as maintained pursuant to Condition 7.1.9(c)(ii), including the measured emission rate. The one-hour and three-hour average (lb/mmBtu) for each three-hour block average of excess emissions.~~

D. A detailed explanation of the cause of the excess emissions if known, including whether such excess emissions occurred during startup, malfunction or breakdown of the boiler.

E. A detailed explanation ~~of any~~ corrective actions ~~and actions taken to lessen the emissions.~~

** For ~~the purpose of reporting excess~~ NO_x emissions, the averaging period is a three-hour ~~rolling block~~ average, as used to determine compliance with the limitations of Condition 7.1.4(a)(ii) and 7.1.4(e). The records for excess emissions shall consist of three-hour ~~rolling block~~ emission averages during which the limitation was exceeded.

Formatted: Subscript

d. Reporting of Opacity and PM Emissions

Pursuant to Sections 39.5(7)(b) and (f) of the Act and the NSPS, 40 CFR 60.45(g), the Permittee shall report the following information for each affected boiler to the Illinois EPA with its quarterly reports pursuant to Condition 7.1.10-2(a):

i. ~~Summary information~~ Information on the performance of the opacity monitoring system and excess emissions, as required for a "Summary Report" ~~in accordance with~~ specified by 40 CFR 60.7(d). When no excess opacity occurred or the continuous opacity monitoring system ~~was~~ has not ~~been~~ inoperative, repaired or adjusted ~~except for zero and span checks,~~ this ~~such information~~ shall be stated in the report as specified by 40 CFR 60.7(c)(4).

ii. If the total duration of excess opacity during the calendar quarter is 1 percent or greater

of the total operating time for an affected boiler during the quarter or if the opacity monitoring system downtime was more than 5 percent of the total operating time for an affected boiler during the quarter then, in addition to the "Summary Report" required by Condition 7.1.10-2(d)(i) and the information required by Condition 7.1.10-2(d)(iii), the quarterly report must include:

A. The total operating time of the affected boiler; and

B. The operating status of the opacity monitoring system, including the dates and times of any periods during which it was inoperative except for zero and span checks. ~~if requested by the Illinois EPA or the opacity monitoring system downtime was more than 5 percent of the total operating time for an affected boiler during the quarter.~~

iii. The following information for each period when opacity was in excess of the applicable standards specified in Conditions 7.1.4(a)(iii) and (g).

A. A summary of information for each period of excess opacity that includes:

~~A~~I. The starting dates and time of the ~~exceedance~~excess opacity.

~~B~~II. The duration of the excess opacity.

~~C~~III. The magnitude of excess opacity, based on six minute average opacity, including:

~~1~~1. The percent opacity for each six-minute period in excess of the limitation.

~~2~~2. The start and stop time of each six-minute period in excess of ~~20 percent~~the limitation.

~~D~~IV. ~~A detailed explanation of the~~The cause of excess opacity, if known, including whether such excess opacity occurred during startup, malfunction or breakdown of the boiler.

Formatted: Normal, Indent: Left: 2.63", Hanging: 0.37", No bullets or numbering, Tab stops: 1.75", Left + Not at 1.63"

Formatted: Font: Courier New, 10 pt

EV. ~~A detailed explanation of the~~Any corrective actions ~~and actions~~ taken ~~to lessen the opacity.~~

FVI. Identification of ~~the~~any previous report for the incidents during the quarter submitted to the Illinois EPA pursuant to Condition 7.1.10-3(a)(ii). For this purpose, the Permittee need not resubmit copies of such report but may elect to supplement such material.

GVII. ~~A summary of the records~~Information required by ~~Condition~~Conditions 7.1.9(~~gh~~) (ii) (A), (B), and (D) (I) for incidents when operation of an affected boiler continued during malfunction or breakdown with excess ~~emissions~~opacity that are not addressed by individual reports submitted pursuant to Condition 7.1.10-3(a)(ii).

Note 1: While the NSPS provides that one six-minute period per hour during which the average opacity of emissions exceeds 20 percent opacity, but not more than 27 percent opacity need not be reported (40 CFR 60.45(g)(1)), such a provisions does not accompany 35 IAC 212.122.

Note 2: Because the Permittee is ~~subject to the~~reporting in accordance with the requirements of the NSPS, 40 CFR 60.7(c) and (d) for an affected boiler for opacity, pursuant to the federal Acid Rain ~~p~~Program, as included above, the Permittee is not subject to reporting pursuant to 35 IAC 201.405 ~~+~~[35 IAC 201.403(a)~~+~~].

iv. The following information for periods when PM emissions were in excess of the limitation in Conditions 7.1.4(a)(ii) and 7.1.4(b). If there were no such ~~exceedance~~periods of excess emissions during the reporting period, the quarterly report shall so state.

A. A summary of information for each period of ~~exceedance~~excess emissions that includes:

I. The starting date and time of the ~~exceedance~~excess emissions.

- II. The duration of the ~~exceedance~~excess emissions.
 - III. The qualitative or, if available, quantitative magnitude of the ~~exceedance~~excess emissions.
 - IV. The ~~percent opacity measured for each six minute period during the exceedance.~~
 - V. ~~The~~ means by which the ~~exceedance~~excess emissions ~~was~~were indicated or identified, ~~in addition to~~if other than the level of opacity.
 - VI. A detailed explanation of the cause of the ~~exceedance~~excess emissions ~~if known,~~ including whether ~~the exceedance~~such excess emissions occurred during startup, malfunction or breakdown.
 - VII. A detailed explanation of any corrective actions ~~and actions~~ taken ~~to lessen the emissions.~~
 - VIII. Identification of the previous reports for the incidents submitted to the Illinois EPA pursuant to Condition 7.1.10-3(a)(ii), if any. For this purpose, the Permittee need not resubmit copies of such report but may elect to supplement such material.
- v. The following ~~summary~~further information related to opacity ~~exceedances or groups of and PM~~opacity exceedances during the quarter that resulted from the same or similar cause(s):
- A. For opacity exceedances or groups of exceedances with "recurring" cause(s) (i.e., cause(s) that also resulted in exceedances(s) during the previous quarter) Further information for each type of recurring opacity exceedance that occurred during the quarter, including: a discussion an explanation of any particular circumstances or events/factors during the current quarter that generally

affected the number or magnitude of such exceedances; a discussion of any additional understanding of the causes for such exceedances gained during the quarter, including the role of component failure or degradation, maintenance practices, and operating procedures; a general discussion of the effectiveness of the changes in the corrective actions that were taken in response to such exceedances during the current quarter as compared to the previous quarter; and a general discussion of further actions that are being considered to address such exceedances and a discussion of any additional preventative measures that were taken during the current quarter to reduce the number or magnitude of exceedance(s).

- B. ~~For Further information for any new type(s) of opacity exceedances or groups of exceedances with "new" cause(s) (i.e., cause(s) that did not result in opacity exceedance(s) that occurred during the previous quarter) including: an explanation of the cause(s) or probable cause(s) of such exceedance(s), to the extent known; a discussion of any particular circumstances or factors during the quarter that resulted in such exceedance(s); the corrective action(s) taken, if any, with explanation of how those action(s) functioned to end the exceedance(s); and a discussion of any preventive measures taken to reduce the number or magnitude of exceedance(s).~~ a general narrative description for the type(s) of exceedance; a general explanation of the cause(s) for such exceedances, including the role of component failure or degradation, maintenance practices, and operating procedures; a detailed explanation of the corrective actions that have been taken for such exceedances, including the reasons that the selected actions were taken, the effectiveness of those actions, and the likelihood of future occurrence of similar exceedances; and a general discussion of possible further actions that could be taken to address such exceedances. For this purpose, new type(s) of exceedance are ones that have

~~not been addressed in the preceding four quarterly opacity reports.~~

~~C. Other information relevant to generally explaining the number and magnitude of opacity and PM exceedances during the quarter, e.g., a further discussion of specific events or circumstances that occurred that affected the number of magnitude or exceedances during the quarter.~~

~~D. Information describing actions taken during the quarter that should generally act to significantly reduce the number or magnitude of future opacity or PM exceedances, e.g., a summary of relevant upgrades or replacements of components that were completed, with a description of such actions, an explanation of their relationship to exceedances, and a discussion of their anticipated effect on future exceedances.~~

vi. A glossary of ~~common-specialized~~ technical terms commonly used by the Permittee in its reports pursuant to this Condition 7.1.10-2(d), ~~including the definitions for the categories used by the Permittee to classify exceedance events.~~

e. Reporting of NO_x Emissions for the Ozone Control Period

Formatted: Subscript

The Permittee shall submit a report to the Illinois EPA by November 30 of each year that demonstrates whether the affected boilers ~~has~~ have complied with Condition 7.1.4(f), pursuant to 35 IAC 217.712(d) and (e).

i. If the Permittee is demonstrating compliance on a unit-specific basis with Condition 7.1.4(f) (i) (A), this report shall contain the information specified by 35 IAC 217.712(d) including the heat input and NO_x emissions of the unit for the ozone control period.

Formatted: Subscript

ii. If the Permittee is demonstrating compliance by means of "NO_x averaging" as authorized by Condition 7.1.4(f) (ii) (B), this report shall contain the information specified by 35 IAC 217.712(e) and other related information as follows:

Formatted: Subscript

A. In all cases, for each affected boiler ~~or~~ ~~unit~~ covered by this permit that is participating in a NO_x averaging demonstration, the Permittee shall report the following:

Formatted: Font: Courier New, 10 pt, Subscript

- I. Identification of the other ~~EGUs~~ EGUEGUs that are participating in the demonstration, including identification of the source that is the lead party for the demonstration and that is also taking responsibility for submitting the information required by Condition 7.1.10-2(e) (ii) (B) below.
- II. A statement confirming that the unit is eligible to participate in an averaging demonstration, i.e., the unit is included in only one demonstration [35 IAC 217.708(d)] and the Permittee is complying with applicable recordkeeping and reporting requirements for the unit, pursuant to 35 IAC 217.708(c) and (g).
- III. The average NO_x ~~emission rate for~~ emission rate for the unit, with calculations and supporting information, as required by 35 IAC 217.712(e) (2) and (3), including the heat input and NO_x emissions of the unit for the ozone control period.
- IV. A statement whether the unit would show compliance on its own in the absence of averaging.

Formatted: Subscript

Formatted: Subscript

B. If the Permittee is the lead party for a NO_x averaging demonstration that includes units operated by other companies, the Permittee shall report the following:

Formatted: Font: Courier New, 10 pt, Subscript

- I. Copies of the information ~~submitted~~ provided by other parties to the lead party for the EGU participating in the demonstration, which include all material required by Condition 7.1.10-2(e) (ii) (A) above (unless or except as this information is provided with the submittal by a person who is a responsible official for the EGU

participating in the demonstration).

II. The averaged NO_x emission rate for all EGUGUs participating in the demonstration, with complete supporting calculations, as required by 35 IAC 217.712(e) (1).

Formatted: Subscript

III. A statement whether the demonstration shows compliance.

f. Submittal of Supplemental Information Related to NO_x Emissions during the Ozone Control Period

Formatted: Subscript

The Permittee shall submit copies of any records and data required by 35 IAC 217.712 to the Illinois EPA within 30 days after receipt of a written request by the Illinois EPA [35 IAC 217.712(g)].

g. Acid Rain Program Reporting

Pursuant to Section 412 of the Clean Air Act and 40 CFR Parts 72 and 75, the source is subject to the reporting requirements of 40 CFR Part 75, which includes General Provisions; Notifications; Initial Certification or Recertification Application; Quarterly Reports; and Opacity Reports. [See Condition 6.2.3] Pursuant to Section 39.5(17)(m) of the Act, the designated representative of the source must concurrently submit to the Illinois EPA in the same electronic format specified by the USEPA, the data and information submitted to USEPA on a quarterly basis pursuant to 40 CFR 75.64.

7.1.10-3 Reporting Requirements - Notifications

a. Reporting ~~of~~When Continued Operation Occurred During Malfunctions and Breakdowns

Pursuant to 35 IAC 201.263 and Sections 39.5(7)(a) and (f) of the Act, the Permittee shall provide the following notifications and reports to the Illinois EPA, Compliance Section and Regional Office, ~~concerning~~for incidents when operation of an affected boiler continued with excess emissions, ~~including continued operation or excess opacity~~ during malfunction or breakdown as addressed by Condition 7.1.3(c). These requirements do not apply to such excess emissions, if any, that occur during startup or shutdown of an affected boiler.

i. The Permittee shall immediately notify the Illinois EPA's Regional Office, by telephone

~~(voice, facsimile, or electronic) mail~~ for each incident in which the ~~applicable PM emissions standard (Condition 7.1.4(b)) could be exceeded or in which the~~ opacity from an affected boiler exceeds 20 percent for ~~five~~ eight or more 6-minute averaging periods within a two-hour period unless the Permittee has begun the shutdown of an affected boiler by such time. (Otherwise, ~~as related to opacity,~~ if opacity during an incident only exceeds 20 percent for no more than ~~five~~ seven 6-minute averaging periods, the Permittee need only report the incident in the quarterly report, in accordance with Conditions 7.1.10-1 ~~(ab)-(iii)~~ and 7.1.10-2(d).)

- ii. Upon conclusion of each incident in which the applicable PM emission standard ~~was or may have been~~ was exceeded or in which ~~exceedances~~ an exceedance of the opacity standard ~~are~~ was two hours or more in duration, the Permittee shall submit a follow-up report to the Illinois EPA, Compliance Section and Regional Office, within 15 days ~~that includes:~~ a detailed description of the incident and its cause(s); an explanation why continued operation of an affected boiler was necessary; the length of time during which operation continued under such conditions, until repairs were completed or the boiler was taken out of service; a description of the measures taken to minimize and correct deficiencies with chronology; and a description of the preventative measures that have been and are being taken providing a copy of the records for the incident required by Condition 7.1.9(h)(ii)(A), (B) and (D).

7.1.11 Anticipated Operating Scenarios/Operating Flexibility

The Permittee is authorized to make the following operational changes with respect to each affected boiler without prior notification to the Illinois EPA or revision of this permit, pursuant to Section 39.5(7)(a) and (l) of the Act. This condition does not affect the Permittee's obligation to continue to comply with applicable requirements; to properly obtain a construction permit in a timely manner for any activity constituting construction or modification as defined in 35 IAC 201.102 or, as applicable, 40 CFR 52.21(a)(2) or 35 IAC 203.207; and to comply with other legal requirements that apply to such a change:

- a. Operation of additional air pollution control equipment, which is addressed by a separate construction permit.
- b. ~~Firing~~Burning of coal or a mix of coal from different suppliers.
- c. ~~Firing~~Burning of the following materials in conjunction with ~~firing~~burning of standard fuels, provided that such materials can be accommodated with the existing fuel handling system and the burners in the affected boilers, and that such materials do not make up more than 10 percent by weight of the fuel supply to the boiler on a quarterly basis:
 - i. Other process wastes generated at the source in addition to used oil and boiler cleaning residue.
 - ii. Alternative fuels that do not constitute waste and were not generated from municipal waste or hazardous waste, provided that such fuels are shipped to the source in homogeneous form prepared for use as fuel (e.g., a shipment of tire derived fuel). Such alternative fuels include materials such as petroleum coke, tire derived fuel (as defined at Section 54.10b of the Act), clean lumber and wood waste (as defined at 40 CFR 60.2265), shredded polyethylene agricultural containers, and seed corn, ~~provided that such materials are shipped to the source in homogeneous form prepared for use as fuel (e.g., a shipment of tire derived fuel).~~

Note: Other requirements unrelated to air pollution control may apply to ~~firing~~burning of alternative fuels, such as Standards for Management of Used Oil, 35 IAC Part 739.

7.1.12 Compliance Procedures

- a. Compliance with the opacity limitation of Conditions 7.1.4(a)(iii) and 7.1.4(g) (20 percent opacity) is addressed by the average opacity calculated from six-minute periods of opacity measurements from the continuous opacity monitoring system operated in accordance with the requirements of Condition 7.1.8(a) and the recordkeeping requirements of Condition 7.1.9.
- b. Compliance with the PM emission limitation of Conditions 7.1.4(a)(ii) and 7.1.4(b) is addressed by continuous opacity monitoring in accordance with Condition 7.1.8(a), PM testing in accordance with

Condition 7.1.7, and the recordkeeping required by Condition 7.1.9.

- c. Compliance with the SO₂ emission limitation of Condition 7.1.4(a)(ii) and 7.1.4(c) is addressed by continuous emission monitoring in accordance with Condition 7.1.8(b) and the recordkeeping required by Condition 7.1.9(d).
- d. Compliance with the CO emission limitation of Condition 7.1.4(d) is addressed by the required work practices in Condition 7.1.6(a), emission testing in accordance with Condition 7.1.7, and the recordkeeping required by Condition 7.1.9.
- e. Compliance with the NO_x emission limitations of Conditions 7.1.4(a)(ii), 7.1.4(e) and 7.1.4(f) is addressed by the continuous emission monitoring in accordance with Condition 7.1.8(c) and the recordkeeping required by Condition 7.1.9(e).
- f. Compliance with the work practice and operating practice requirements of Condition 7.1.6(a) is addressed by the recordkeeping required by Condition 7.1.9.
- ~~g. Compliance with the requirements of Condition 7.1.6(b) is addressed by the recordkeeping required by Condition 7.1.9(i).~~

Formatted: Font: Courier New, 10 pt

Note: This condition is included in this permit pursuant to Section 39.5(7)(p)(v) of the Act.

7.1.13-1 Conditional Approval of Compliance Assurance Monitoring Plan

- a. Due to lack of existing unit-specific performance data for PM emissions, the Permittee must conduct PM emissions testing, prior to use of any approved monitoring for purposes of 40 CFR Part 64, Compliance Assurance Monitoring. The Permittee has submitted an application for a CAM Plan that contains the following:
 - i. The indicators to be monitored to satisfy 40 CFR 64.3(a)(1).
 - ii. The process by which these indicators/ranges shall be established.
 - iii. The performance criteria for the monitoring to satisfy 40 CFR 64.3(b), including for the Continuous Opacity Monitoring System (COMS), pursuant to 40 CFR 64.3(d).

- iv. A justification for the proposed elements of the monitoring and the appropriateness of such elements.
- b. Pursuant to 40 CFR 64.6(b) and (d) and Section 39.5(7)(a) of the Act, the Permittee shall comply with the following with respect to implementation of CAM:
 - i. The Permittee shall comply with the following schedule, which contains appropriate milestones for completing necessary testing for PM emissions, consistent with the requirements in 40 CFR 64.4(e). The approval of this implementation plan and schedule by the Illinois EPA is authorized by 40 CFR 64.4(d)(1) and (e).

<u>Commitment</u>	<u>Timing</u>
<u>Submit a CAM Testing Protocol to Illinois EPA</u>	<u>At least 30 days prior to CAM Testing.</u>
<u>Complete CAM Testing</u>	<u>Within 120 days of issuance of this permit.</u>
<u>Submit CAM Testing results to Illinois EPA</u>	<u>Within 45 days of completing the testing.</u>
<u>Begin Implementation of Compliance Assurance Monitoring</u>	<u>Within 180 days of issuance of this permit.</u>

- ii. The Permittee shall, in no case later than 60 days following completion of CAM testing, submit an application to the Illinois EPA for a proposed modification to this permit to incorporate information for the opacity value that was derived from testing, thereby addressing all of the requirements of 40 CFR 64.3, 64.4, and 64.5.
- iii. Pursuant to 40 CFR 64.6(b) and Section 39.5(7)(a) of the Act, the Permittee shall promptly notify the Illinois EPA upon start of monitoring in accordance with Condition 7.1.13-2(a) and Tables 7.1.13a and 7.1.13b.

7.1.13-2 Compliance Assurance Monitoring Requirements

- a. Pursuant to 40 CFR 64.7(a), the Permittee shall comply with the CAM requirements in Table 7.1.13 below not later than the date specified in Condition 7.1.13-1(b) above.
- b. Pursuant to 40 CFR 64.5(d), upon start of the monitoring in accordance with Condition 7.1.13-2(a), recordkeeping pursuant to Condition 7.1.9(c)(ii)(B) shall be discontinued.

c. Pursuant to 40 CFR 64.7(a), the Permittee shall comply with the following CAM requirements and the requirements in Condition 7.1.13-2(d) through (g) not later than the date specified in Condition 7.1.13-1(b) above for implementation of compliance assurance monitoring.

i. Proper Maintenance and Continued Operation

A. Pursuant to 40 CFR 64.7(b), at all times, the Permittee shall maintain the monitoring, including but not limited to, maintaining necessary parts for routine repairs of the monitoring equipment.

B. Pursuant to 40 CFR 64.7(c), except for, as applicable, monitoring malfunctions, associated repairs, and required quality assurance or control activities (including, as applicable, calibration checks and required zero and span adjustments), the Permittee shall conduct all monitoring in continuous operation (or shall collect data at all required intervals) at all times that the pollutant-specific emissions unit (PSEU) is operating. Data recorded during monitoring malfunctions, associated repairs, and required quality assurance or control activities shall not be used for purposes of 40 CFR Part 64, including data averages and calculations, or fulfilling a minimum data availability requirement, if applicable. The Permittee shall use all the data collected during all other periods in assessing the operation of the control device and associated control system. A monitoring malfunction is any sudden, infrequent, not reasonably preventable failure of the monitoring to provide valid data. Monitoring failures that are caused in part by poor maintenance or careless operation are not malfunctions.

ii. Response to Excursions

A. Pursuant to 40 CFR 64.7(d)(1), upon detecting an excursion, the Permittee shall restore operation of the PSEU (including the control device and associated capture system) to its normal or usual manner of operation as expeditiously as practicable in

accordance with good air pollution control practices for minimizing emissions. The response shall include minimizing the period of any startup, shutdown or malfunction and taking any necessary corrective actions to restore normal operation and prevent the likely recurrence of the cause of an excursion (other than those caused by excused startup or shutdown conditions). Such actions may include initial inspection and evaluation, recording that operations returned to normal without operator action (such as through response by a computerized distributed control system), or any necessary follow-up actions to return operation to within the indicator range, designated condition, or below the applicable emission limitation or standard, as applicable.

B. Pursuant to 40 CFR 64.7(d)(2), determination of whether the Permittee has used acceptable procedures in response to an excursion will be based on information available, which may include but is not limited to, monitoring results, review of operation and maintenance procedures and records, and inspection of the control device, associated capture system, and the process.

d. Recordkeeping

Pursuant to 40 CFR 64.9(b)(1), the Permittee shall maintain records of the monitoring data, monitor performance data, corrective actions taken, monitoring equipment maintenance, any written quality improvement plan required pursuant to 40 CFR 64.8 and any activities undertaken to implement a quality improvement plan, and other supporting information required to be maintained under Conditions 7.1.9(c)(i), 7.1.13-1, or 7.1.13-2 (such as data used to document the adequacy of monitoring, or records of monitoring maintenance or corrective actions).

e. Reporting

Pursuant to Sections 39.5(7)(b) and (f) of the Act, the Permittee shall submit the following as part of the Quarterly Monitoring Reports required by Condition 7.1.10-2.

- i. Summary information on the number, duration, and cause of excursions, and the corrective actions taken, pursuant to 40 CFR 64.6(c)(3), 40 CFR 64.9(a)(2)(i), and Condition 7.1.10-2(d)(iv), except as otherwise provided in 40 CFR Part 64, including 64.7(d).
- ii. Summary information on the number, duration, and cause for monitoring equipment downtime incidents, other than downtime associated with calibration checks, pursuant to 40 CFR 64.6(c)(3), 40 CFR 64.9(a)(2)(ii), and Condition 7.1.10-2(d)(i) and (ii).

f. Quality Improvement Plans (QIP)

Pursuant to 40 CFR 64.8, based on the results of any future determination made under 40 CFR 64.7(d)(2), the Administrator or the Illinois EPA may require the Permittee to develop and implement a QIP under separate permit action, as appropriate, under Sections 39.5(14), (15), or (16).

g. Need for Improved Monitoring

Pursuant to 40 CFR 64.7(e), if the Permittee identifies a failure to achieve compliance with an emission limitation or standard for which the approved monitoring did not provide an indication of an excursion or exceedance while providing valid data, or the results of compliance or performance testing document a need to modify the existing indicator ranges or designated conditions, the Permittee shall promptly notify the Illinois EPA within 30 days of identification and, if necessary, submit to the Illinois EPA a proposed modification to this permit to address the necessary monitoring changes. Such a modification may include, but is not limited to, reestablishing indicator ranges or designated conditions, modifying the frequency of conducting monitoring and collecting data, or the monitoring of additional parameters.

Table 7.1.13a CAM Plan for Boilers- 35 IAC 212.203

PSEU Designation:		Boiler 1 (NB-1)
Pollutant:		Particulate (PM) Emissions
Indicators:	#1) Opacity	#2)
General Criteria		
<u>The Monitoring Approach Used to Measure the Indicators:</u>	Opacity is measured using a transmissometer. The transmissometer measures the opaqueness of the flue gas exhaust using a beam of light that traverses the stack diameter, which generates an electrical signal that is proportional to the opacity.	
<u>The Indicator Range Which Provides a Reasonable Assurance of Compliance:</u>	Opacity less than [*]% averaged over a 3 hour period is an indicator of proper ESP operation and provides reasonable assurance of meeting the 0.10 lb/mmBtu PM limit.	
<u>Quality Improvement Plan (QIP) Threshold Levels:</u>	A QIP is not being considered at the time of this CAM Plan submission. Currently, there is no indication of any deficiencies in the monitoring approach selected. The COMs monitoring requirements provide the specific QA/QC procedures for data collection, recordkeeping and reporting for determining "reasonable" assurance of compliance with the applicable PM limitation.	
Performance Criteria		
<u>The Specifications for Obtaining Representative Data:</u>	The COMs are installed at representative locations in the exhaust stack per 40 CFR Part 60, Appendix B, PS-1 requirements.	
<u>Verification Procedures to Confirm the Operational Status of the Monitoring:</u>	N/A. The COMs were installed and qualified for use to determine compliance with state opacity standards. Verification Procedures are not necessary.	
<u>Quality Assurance and Quality Control (QA/QC) Practices that Ensure the Validity of the Data:</u>	40 CFR Part 60, Appendix B, Performance Specification 1 and 40 CFR Part 75 QA/QC procedures.	
<u>The Monitoring Frequency:</u>	Opacity is measured continuously. Opacity data is reduced in accordance with procedures in 40 CFR 60.13.	
<u>The Data Collection Procedures That Will Be Used:</u>	The three hour average is calculated and reported in the CEM Data Acquisition System. Alarm set points are established to alert operators of problems.	
<u>The Data Averaging Period For Determining Whether an Excursion Has Occurred:</u>	3 hour block averages	

[*] - Indicator values to be determined pursuant to Condition 7.1.13-1(a).

Table 7.1.13b CAM Plan for Boilers- 35 IAC 212.203

PSEU Designation:		Boiler 2 (NB-2)
Pollutant:		Particulate (PM) Emissions
Indicators:	#1) Opacity	#2)
General Criteria		
The Monitoring Approach Used to Measure the Indicators:	Opacity is measured using a transmissometer. The transmissometer measures the opaqueness of the flue gas exhaust using a beam of light that traverses the stack diameter, which generates an electrical signal that is proportional to the opacity.	
The Indicator Range Which Provides a Reasonable Assurance of Compliance:	Opacity less than [*]% averaged over a 3 hour period is an indicator of proper ESP operation and provides reasonable assurance of meeting the 0.10 lb/mmBtu PM limit.	
Quality Improvement Plan (QIP) Threshold Levels:	A QIP is not being considered at the time of this CAM Plan submission. Currently, there is no indication of any deficiencies in the monitoring approach selected. The COMs monitoring requirements provide the specific QA/QC procedures for data collection, recordkeeping and reporting for determining "reasonable" assurance of compliance with the applicable PM limitation.	
Performance Criteria		
The Specifications for Obtaining Representative Data:	The COMs are installed at representative locations in the exhaust stack per 40 CFR Part 60, Appendix B, PS-1 requirements.	
Verification Procedures to Confirm the Operational Status of the Monitoring:	N/A. The COMs were installed and qualified for use to determine compliance with state opacity standards. Verification Procedures are not necessary.	
Quality Assurance and Quality Control (QA/QC) Practices that Ensure the Validity of the Data:	40 CFR Part 60, Appendix B, Performance Specification 1 and 40 CFR Part 75 QA/QC procedures.	
The Monitoring Frequency:	Opacity is measured continuously. Opacity data is reduced in accordance with procedures in 40 CFR 60.13.	
The Data Collection Procedures That Will Be Used:	The three hour average is calculated and reported in the CEM Data Acquisition System. Alarm set points are established to alert operators of problems.	
The Data Averaging Period For Determining Whether an Excursion Has Occurred:	3 hour block averages	

[*] - Indicator values to be determined pursuant to Condition 7.1.13-1(a).

7.2 Coal Handling Equipment

7.2.1 Description

The Permittee transfers and stores coal in a series of operations, including railcar and truck unloading, various conveyor belts (with associated hoppers, diverters, and transfer points), storage piles (with stackers and feeders), and bunkers. As a part of handling, the coal may be passed through “crackers” designed to break apart frozen coal. Particulate matter (PM) emissions associated with these operations are controlled by various measures ~~including such as~~ the moisture content of the coal, ~~application of~~ dust suppression ~~on~~ ~~to the coal~~, enclosures and covers, and dust collection devices.

Note: The description in Condition 7.2.1 is for informational purposes only and implies no limits or constraints.

7.2.2 List of Emission Units ~~and Air Pollution Control Equipment~~

~~Coal Receiving Operations~~
~~Railcar Unloading~~
~~Truck Unloading~~
~~Coal Transfer Conveyors~~
~~Dust Suppressant Application System, Dust Collection Devices, Enclosures and Covers~~
~~Coal Transfer Operations~~
~~Coal Transfer Conveyors~~
~~Enclosures and Covers~~
~~Coal Storage Operations~~
~~Outdoor Storage Piles~~
~~Bucket Wheel Stacker/Reclaimer~~
~~Coal Transfer Conveyors~~
~~Coal Storage Bunkers~~
~~Dust Suppressant Application System, Enclosures and Covers~~
~~Coal Transfer Conveyors~~
~~Coal Storage Piles~~
~~Coal Storage Bunkers~~
Truck Unloading
Railcar Unloading
Stacker/Reclaimer

7.2.3 Applicability Provisions

- a. The “affected operations” for the purpose of these unit-specific conditions, are the emission units that are used solely for the purpose of transferring coal or other solid fuel from one location to another or for storage of coal or other solid fuel, without changing the size of the fuel, e.g., by crushing or

screening, as described in Conditions 7.2.1 and 7.2.2.

- b. Subject to the following provisions, the Permittee is authorized to continue operation of an affected operation in violation of the applicable requirements of Condition 7.2.4(b) (35 IAC 212.123) in the event of a malfunction or breakdown of an affected operation. This authorization is provided pursuant to 35 IAC 201.149, 201.~~161-261~~ and 201.262, as the Permittee has applied for such authorization in its application, generally explaining why such continued operation would be required to provide essential service or to prevent injury to personnel or severe damage to equipment, and describing the measures that will be taken to minimize emissions from any malfunctions and breakdowns. This authorization supersedes the general prohibition in Condition 9.2.3 against continued operation in such circumstances.
- i. This authorization only allows such continued operation as related to the operation of the coal-fired boilers as necessary to provide essential service or to prevent injury to personnel or severe damage to equipment and does not extend to continued operation solely for the economic benefit of the Permittee.
 - ii. Upon occurrence of excess emissions due to malfunction or breakdown, the Permittee shall as soon as practicable repair the affected operation, remove the affected operation from service or undertake other action so that excess emissions cease.
 - iii. The Permittee shall fulfill applicable recordkeeping and reporting requirements of Conditions 7.2.9(~~fe~~) and 7.2.10(b). For these purposes, time shall be measured from the start of a particular incident. The absence of excess emissions for a short period shall not be considered to end the incident if excess emissions resume. In such circumstances, the incident shall be considered to continue until corrective actions are taken so that excess emissions cease or the Permittee takes the affected operation out of service.
 - iv. Following notification to the Illinois EPA of a malfunction or breakdown with excess emissions, the Permittee shall comply with all reasonable directives of the Illinois EPA with

respect to such incident, pursuant to 35 IAC 201.263.

- v. This authorization does not relieve the Permittee from the continuing obligation to minimize excess emissions during malfunction or breakdown. As provided by 35 IAC 201.265, an authorization in a permit for continued operation with excess emissions during malfunction and breakdown does not shield the Permittee from enforcement for any such violation and only constitutes a prima facie defense to such an enforcement action provided that the Permittee has fully complied with all terms and conditions connected with such authorization.

7.2.4 Applicable Emission Standards

- a. Fugitive emissions, as defined by 35 IAC 211.2490, of the affected operations shall comply with the standard in Condition 5.2.2(a), which addresses visible emissions of fugitive particulate matter, as defined by 35 IAC 211.2490, from the affected operations, pursuant to 35 IAC 212.301.
- b. The affected operations shall comply with the standard, i.e., 30 percent opacity, in Condition 5.2.2(b), which addresses the opacity of the emission of smoke or other particulate matter from the affected operations, pursuant to 35 IAC 212.123.

7.2.5 Non-Applicability of Regulations of Concern

- a. The affected operations are not subject to 35 IAC 212.321 or 212.322 because of the disperse nature of the operations, as generally addressed by 35 IAC 212.323.
- b. The affected operations are not subject to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for Major Stationary Sources for PM because the affected operations do not have potential pre-control device emissions of the applicable regulated air pollutant that equals or exceeds major source threshold levels.

7.2.6 Work Practices, Operational and Production Limits, and Emission Limitations

- a. i. The Permittee shall implement and maintain the control measures for the affected operations, such as enclosure, natural surface moisture, application of dust suppressant ~~or water spray~~, and use of dust collection devices,

~~that minimize visible~~for emissions of particulate matter ~~and provide assurance of compliance with~~to support periodic monitoring ~~for~~ the applicable ~~emission control~~ requirements in Conditions 7.2.4 and 7.2.6(b), pursuant to Section 39.5(7) (a) of the Act.

- ii. The ~~Permittee shall operate and maintain each affected operation with the~~ control measures ~~implemented and maintained shall be~~ identified ~~and operated in conformance with~~ the records required by Condition 7.2.9(b) (i) to satisfy Condition 7.2.6(a) (i).
- b. i. The amount of coal received shall not exceed 6.0 million tons per year [T1].
- ii. The amount of coal placed on the storage piles shall not exceed 2.25 million tons per year [T1].
- iii. The affected operations shall not exceed the following PM emission limits [T1]:

<u>Operation</u>	<u>PM Emissions (Tons/Year)</u>
Railcar Unloading	3.0
Modified Transfer System	37.5
Storage Pile - Stack Out	19.0
Storage Pile - Reclaiming	22.5
Sample House - Conveyor Room	<u>30.0</u>
Total:	102.0

- iv. Compliance with annual limitations shall be determined on a monthly basis from the sum of the data for the current month plus the preceding 11 months (running 12 month total) [T1].
- c. The upgraded coal handling system shall be operated in accordance with good operating practices to minimize particulate matter emissions including the following [T1]:
 - i. Enclosures shall be maintained in good condition and dust suppressant shall be applied as needed whenever coal is being moved past a point of application.
 - ii. The preferred method of handling coal shall be immediate storage in the bunkers. Coal shall only be placed in the storage pile as

necessary, e.g., lack of bunker space, maintenance of the reserve fuel supply or rotation of this reserve, breakdown of the transfer system to the bunker, etc.

- iii. The bucket wheel stacker/reclaimer shall be used as the principal means for transfer of coal to and from the storage pile and shall be maintained and operated to minimize dust emission.
- iv. The telescopic chute stack out system and pit reclaim shall be maintained and operated to minimize dust emissions, including localized application of suppressant to coal being reclaimed as needed to prevent visible emission during reclaiming.
- v. Remedial actions shall be taken if visible emissions are observed outside of any enclosure or building.

Note: The above limitations were established in ~~Permits 79020027 and~~ Construction Permit 98080051.

7.2.7 Opacity ~~Testing-Observation~~ Requirements

- a. i. The Permittee shall have the opacity of the emissions from the affected operations during representative ~~weather and~~ operating conditions determined by a qualified observer in accordance with ~~USEPA TestReference~~ Method 9, as further specified below, pursuant to Section 39.5(7)(d) of the Act.
 - A. For each affected operation, ~~testing observations~~ shall be conducted ~~at least annually. For this purpose, testing shall first be conducted within three months of the effective date not later than two years after the effectiveness of this Condition~~ condition 7.2.7(a).
 - B. Thereafter, for each affected operation, observations shall be conducted every third year.
 - ~~BC.~~ Upon written request by the Illinois EPA, such ~~testing observations~~ shall be conducted for specific affected operation(s) ~~within not later than 45 calendar days of after the Permittee has received~~ the request or on the such later

date agreed ~~upon to~~ by the Illinois EPA,
~~whichever is later.~~

- ii. The duration of opacity observations for each test shall be at least 30 minutes (five 6-minute averages) unless the average opacities for the first 12 minutes of observations (two six-minute averages) are ~~both less~~each not greater than 10.0 percent.
- iii. A. ~~For each set of observations required by Conditions 7.2.7(a)(i)(A), (B), and (C), the~~ Permittee shall notify the Illinois EPA at least 7 days in advance of the date ~~and time of these tests, in order to allow the Illinois EPA to witness testing. This notification shall include the name and employer of the qualified observer of the first~~ observation(s).
B. The Permittee shall promptly notify the Illinois EPA of any changes in the ~~time or date for testing of the first~~ observation(s).
- iv. The Permittee shall provide a copy of its observer's readings to the Illinois EPA at the time of ~~testing the~~ observation(s), if Illinois EPA personnel are present.
- v. The Permittee shall submit a written report for ~~this testing these observations within not later than 15-30 days after the date of completion of each set of opacity observations required by Conditions 7.2.7(a)(i)(A), (B), and (C). The report shall include a copy of the current Reference Method 9 certification of each observer and shall identify the observer's current employer. of the date of testing.~~ This report shall also include the following for each observation:
 - A. Identification of the affected operation for which observations were conducted.
 - B. Date and time of testing observations.
 - ~~B. Name and employer of qualified observer.~~
 - ~~C. Copy of current certification.~~
 - ~~DC.~~ Description of observation condition, including recent weather.

ED. Description of the operating conditions of the affected operations.

FE. Raw data.

GF. Opacity determinations.

HG. Conclusions.

7.2.8 Inspection Requirements

- a. Pursuant to 39.5(7)(a) of the Act, the following inspection requirements for the coal handling system equipment including enclosures and dust suppressant application devices supersede the compliance requirements in Condition 7a of Construction Permit 98080051, issued November 23 1998:

The Permittee shall perform inspections of the affected operations on at least a monthly basis, ~~including associated control measures, while the affected operations are in use,~~ to confirm compliance with the requirements of Condition 7.2.6(a). If an affected operation is not in use during an inspection, this shall be noted in the inspection record. These ~~The records required by Condition 7.2.9(d) for these inspections shall be performed with signed off by supervisory or management personnel not directly involved in the day-to-day operation of the affected operations and may be scheduled so that only a number of affected operations are reviewed during each inspection, provided however, that all affected operations that are in routine service shall be inspected at least once during each calendar month [Sections 39.5(7)(a) and (d) of the Act]~~ [TIR].

- b. As part of the inspections required by Condition 7.2.8(a), the Permittee shall perform observations of the affected operation(s) for visible emissions in accordance with 35 IAC 212.107 to demonstrate compliance with the requirements of Condition 7.2.4(b), unless the Permittee elects to perform Reference Method 9 observations in accordance with Condition 7.2.7(a). These observations may be scheduled so that only a number of affected operations are reviewed during each inspection, provided, however, that all affected operations that are in routine service shall be observed at least once during each calendar year in which it is in use. If visible emissions are observed, the Permittee shall take corrective action within 2 hours to return the status of the operations to no visible emission or shall conduct observations of opacity by Reference

~~Method 9 within one week in accordance with Condition 7.2.7(a). If the Permittee performs Reference Method 9 observations under this Condition 7.2.8(b), such observations are not subject to the notice and reporting requirements of Condition 7.2.7(a) (iii) through (v) [Sections 39.5(7) (a) and (d) of the Act]. The Permittee shall perform detailed inspections of the dust collection equipment for the affected operations at least every 15 months while the processes are out of service, with an initial inspection performed before any maintenance and repair activities are conducted during the period the process is out of service and a follow-up inspection performed after any such activities are completed. [Sections 39.5(7) (a) and (d) of the Act]~~

- c. The Permittee shall perform and document an inspection of the railcar unloader baghouses to confirm proper condition and operation prior to commencing unloading of each train set (i.e., a coal unit train). This inspection shall include recording and verifying that the monitored baghouse differential pressure is within the operating range specified in the record required by Condition 7.2.9(b)(i) and that visible emissions are not observed in the baghouse exhaust [Sections 39.5(7) (a) and (d) of the Act].

7.2.9 Recordkeeping Requirements

- a. The Permittee shall maintain records of the following for the affected operations, pursuant to Sections 39.5(7) (a) and (e) of the Act:
 - ~~a. The Permittee shall keep a record of the following file(s) and log(s):~~
 - ~~i. File(s) containing the following information for the affected operations, with supporting information, which information shall be kept up to date:~~
 - ~~A. Information related to the dust collection equipment associated with the affected operations, including design control efficiency or performance specifications and maximum design particulate matter emissions, gr/dscf.~~
 - ~~B. The i. Maximum operating capacity of each affected operation, (~~ton~~tons/hour).~~
 - ii. Information related to any baghouses associated with the affected operations,

including available design control efficiency or performance specifications and maximum design particulate matter emissions, gr/dscf., with supporting information, which information shall be kept up to date.

iiii. Maintenance and repair log(s) for the air pollution control equipment associated with the affected operations, including dust suppressant application systems, which log(s) shall list the activities performed on each item of equipment or system, with date and description. (See also Condition 9.6.1, Control Equipment Maintenance Records.)

- b. i. The Permittee shall maintain a record, which shall be kept up to date, to reflect any changes that the Permittee may elect to make, that contains the following for each affected operation for which a control measure(s) must be implemented for the different affected operations and maintained pursuant to Condition 7.2.6(a)(i). These control measures, as defined by the Permittee through these records, are referred to as the "established control measures" in this subsection of this permit. Copies of these records shall be submitted to the Illinois EPA in accordance with Condition 5.6.2(d).
- A. The type of emission unit (conveyor, storage pile, etc.) and the Permittee's designation for each emission unit with a description of the emission points on the emission unit;
 - B. Whether the emission unit is considered to be an "affected facility" for purposes of the NSPS, with copies of supporting documentation;
 - C. Description of the primary control measures that are utilized, with a description of the control measure and estimated frequency of application, if not continuous. If the primary control device is a baghouse, identification of the normal operating range for the differential pressure across the baghouse; and
 - D. Description of any secondary control measures that would be used based on

circumstances (freezing temperatures, recent rain, dry weather, etc.) with identification of the circumstances in which they would be used and whether they would take the place of or supplement the primary control measures.

- ii. Accompanying this record, the Permittee shall maintain a demonstration that confirms that the ~~above established~~ control measures identified in the record required by Condition 7.2.9(b)(i) are sufficient to assure compliance with the emission limitations in Condition 7.2.6(b)(iii) (tons/year), with supporting emission calculations and documentation for the emission factors and the efficiency of the control measures being relied upon by the Permittee. ~~Except as addressed by Condition 7.2.9(a)(i)(A), t~~This demonstration shall include the information addressed by Condition 7.2.9(a)(i) and (ii), be developed using emission factors for uncontrolled PM emissions, ~~efficiency of control measures, and/or~~ controlled PM emissions published by USEPA or other credible sources.
 - iii. A copy of the record required by Condition 7.2.9(b)(i) shall be submitted to the Illinois EPA not later than 60 days after the effectiveness of Condition 7.2.9(b)(i). Any subsequent revisions to this record related to control measures or affected operations, including their method of operation, shall be submitted not later than 30 days after the date of the revision. Upon request by the Illinois EPA, the Permittee shall submit other relevant information related to the control measures. Copies of these records shall be submitted to the Illinois EPA in accordance with Condition 5.6.2(d).
- c. The Permittee shall maintain the following operating records:
- i. The Permittee shall maintain a record of the~~The~~ amount of coal ~~and other solid fuels~~ received at the source, by type of fuel (tons/month and tons/year).
 - ii. The Permittee shall maintain a record of the~~The~~ amount of coal ~~and other solid fuels~~ sent to the outdoor storage piles, by type of fuel (tons/month and tons/year).

d. The Permittee shall maintain records of the following for the inspections required by Condition 7.2.8:

~~i. For the inspections required by Condition 7.2.8(a) for each affected operation:~~

~~Ai. Date and time the inspection was performed, and name(s) of inspection personnel, and specific affected operation(s) inspected.~~

~~Bii. The observed condition of the control measures identified in the record required by Condition 7.2.9(b)(i) for each inspected for each affected operation, including the presence of any visible emissions or atypical accumulations of coal fines in the vicinity of the operations.~~

~~Ciii. A description of any maintenance or repair of equipment associated with established the control measures identified in the record required by Condition 7.2.9(b)(i) that is recommended as a result of the inspection (and associated work order ticket number(s)) a review of outstanding recommendations for maintenance or repair from previous inspection(s), i.e., whether recommended action has been taken, is yet to be performed or no longer appears to be required.~~

~~Div. A description of any corrective action taken if visible emissions were observed including whether corrective action took place within 2 hours of the observation and whether the status of the operation returned to no visible emissions. A summary of the observed implementation or status of actual control measures, as compared to the established control measures.~~

~~v. For the baghouse inspection in Condition 7.2.8(c), a record of the actual differential pressure observed prior to unloading a Unit train and upon completion of the unloading of a Unit train.~~

~~ii. For the inspections required by Condition 7.2.8(b) for the dust collection equipment for affected operations:~~

~~A. Date and time the inspection was performed and name(s) of inspection personnel.~~

~~B. The observed condition of the equipment.~~

~~C. A summary of the maintenance and repair that is to be or was conducted on the equipment.~~

~~D. A description of any maintenance or repair that is recommended as a result of the inspection and a review of outstanding recommendations for maintenance or repair from previous inspection(s), i.e., whether recommended action has been taken, is yet to be performed or no longer appears to be required.~~

~~E. A summary of the observed condition of the equipment as related to its ability to reliably and effectively control emissions.~~

- e. The Permittee shall maintain records of the following for each incident when any affected operation ~~operated~~ was in use without the control measure(s) required pursuant to the record required by Condition 7.2.9(b)(i) and each incident when an affected operation continued to operate during malfunction or breakdown with excess emissions or excess opacity as addressed by Condition 7.2.3(b) ~~established control measures~~:
- i. The date of the incident and identification of the affected operation(s) that ~~were~~ was involved.
 - ii. A description of the incident, including the ~~established~~ control measures that were not present or operated as required by the record identified in Condition 7.2.9(b)(i) ~~implemented~~; the established control measures that were present, if any; other control measures or mitigation measures that were implemented ~~operated~~, if any; the measures taken to minimize and correct deficiencies with chronology; and an explanation whether the magnitude of the PM emissions or opacity during the incident exceeded any applicable emission or opacity standard, as listed in Condition 7.2.4.
 - iii. The time at and means by which the incident was identified, e.g., scheduled inspection or observation by operating personnel.

- iv. The length of time after the incident was identified that the affected operations continued to operate before ~~established the control measures identified in the record required by Condition 7.2.9(b)(i)~~ were in place or the operations were shut down (to resume operation only after ~~established such control measures were in place~~); an explanation of why continued operation was necessary; and, if this time was more than one hour, an explanation of why this time was not shorter, including a description of any mitigation measures that were implemented during the incident.
 - v. The estimated total duration of the incident, i.e., the total length of time that the affected operations ran without ~~established control measures the control measure(s) required pursuant to the record required by Condition 7.2.9(b)(i)~~ and the estimated amount of coal handled during the incident.
 - vi. A discussion of the probable cause of the incident and any preventative measures taken.
 - ~~vii. A discussion whether any applicable emission standards, as listed in Condition 7.2.4, or the PM emission limits in Condition 7.2.6(b) may have been violated during the incident, with an estimate of the amount of any additional or excess PM emissions (lb) from the incident, with supporting explanation as needed.~~
- f. Pursuant to 35 IAC 201.263 and Sections 39.5(7)(a) and (c) of the Act, the Permittee shall maintain records, related to malfunction and breakdown for affected operations that as a minimum, shall include:
- ~~i. Maintenance and repair log(s) for the affected operations that, at a minimum, address aspects or components of such operations for which malfunction or breakdown has resulted in excess emissions, which shall list the activities performed on such aspects or components, with date, description and reason for the activity. In addition, in the maintenance and repair log(s) for control equipment required by Condition 7.2.9(a)(ii), the Permittee shall also list the reason for the activities that are performed.~~

~~ii. Records for each incident when operation of an affected process continued during malfunction or breakdown, including continued operation with excess emissions as addressed by Condition 7.2.3(b) that include the following information:~~

~~A. Date and duration of malfunction or breakdown.~~

~~B. A description of the malfunction or breakdown.~~

~~C. The corrective actions used to reduce the quantity of emissions and the duration of the incident.~~

~~D. Confirmation of fulfillment of the requirements of Condition 7.2.10(b)(i), as applicable, including copies of follow up reports submitted pursuant to Condition 7.2.10(b)(i)(B).~~

~~E. If excess emissions occurred for two or more hours:~~

~~I. A detailed explanation why continued operation of the affected operation was necessary.~~

~~II. A detailed explanation of the preventative measures planned or taken to prevent similar malfunctions or breakdowns or reduce their frequency and severity.~~

~~III. An estimate of the magnitude of excess emissions occurring during the incident.~~

~~gf. The Permittee shall keep records for all opacity measurements-observations made in accordance with USEPA Reference Method 9 for the affected operations that it conducts or that are conducted ~~on~~ at its behest by individuals who are qualified to make such observations. For each occasion on which such measurements-observations are made, these records shall include the formal report for the measurements-observations if conducted pursuant to Condition 7.2.7 (Opacity Observation Requirements), or otherwise the identity of the observer, a description of the measurements-observations that were made, the operating condition of the affected operation(s), the~~

observed opacity, ~~and~~ copies of the raw data sheets for the observations, and the reason for the opacity observations, e.g., Reference Method 9 opacity observations required by Condition 7.2.7(a)(i), written request by the Illinois EPA, or any required Reference Method 9 opacity observations following observations of visible emissions under Condition 7.2.8(b) measurements.

- hg. To demonstrate compliance with Condition 7.2.6(b), the Permittee shall keep records of amount of coal received, amount of coal handled, and PM emissions (tons/month and tons/year) for the operations listed in 7.2.6(b)(iii), based on the ~~above records, with supporting calculations required by Condition 7.2.9(b)(ii).~~

7.2.10 Reporting Requirements

a. Reporting of Deviations

The Permittee shall promptly notify the Illinois EPA of deviations from permit requirements for the affected operations, as follows. Such notifications shall include a description of each incident and a discussion of the probable cause of deviation, any corrective actions taken, and any preventative measures taken, pursuant to Section 39.5(7)(f)(ii) of the Act.

- i. ~~For those breakdown or malfunction opacity events that require notification and reporting pursuant to Condition 7.2.10(b)(i), notification and reporting shall be provided pursuant to Condition 7.2.10(b)(i) rather than 7.2.10(a). Notification and reporting as specified in Condition 7.2.10(b) for certain deviations from Condition 7.2.4(b).~~
- ii. ~~Within 30 days after the conclusion of an incident in which the Permittee continued to operate an affected operation for more than 12 operating hours after discovering that emission control measures required by the record identified in Condition 7.2.9(b)(i) were not present or operating, the Permittee shall submit written notice to the Illinois EPA. Such notifications shall be accompanied by a copy of the records for the incident required by Condition 7.2.9(e). Notification within 30 days for operation of an affected operation that was not in compliance with applicable requirements in Conditions 7.2.6(a) that continued for more than 12 operating~~

~~hours from the time that it was identified. Such notifications shall be accompanied by a copy of the records for the incident required by Condition 7.2.9(c).~~

- iii. A. ~~Except for events and incidents for which notification or reporting is required by Condition 7.2.10(a)(ii) or 7.2.10(b)(i), as referenced in 7.2.10(a)(i), all other notifications shall be submitted with the quarterly reports required by Condition 7.2.10(b)(ii). Notification with the quarterly reports required by Condition 7.2.10(b)(ii) for other deviations, including deviations from applicable emission standards, inspection requirements and recordkeeping requirements.~~

- B. With the quarterly report, the Permittee shall also address deviations that occurred during the quarter that have been separately reported to the Illinois EPA, with a summary of such deviations. For this purpose, the Permittee need not resubmit the detailed information provided in prior notifications and reports for such deviations.

- b. Reporting ~~of~~ When Continued Operation Occurred During Malfunctions and Breakdowns

Pursuant to 35 IAC 201.263 and Sections 39.5(7)(a) and (f) of the Act, the Permittee shall provide the following notifications and reports to the Illinois EPA, ~~concerning for~~ incidents when operation of affected operation(s) continued with ~~excess emissions, including continued operation or excess opacity~~ during malfunction or breakdown as addressed by Condition 7.2.3(b).

- i. A. ~~The Permittee shall immediately notify the Illinois EPA's Regional Office, by telephone, facsimile or electronic mail, for each incident in which the opacity from an affected operation exceeds 30 percent for eight or more 6-minute averaging periods within a two hour period unless the Permittee has begun the shutdown by such time. (Otherwise, if opacity during an incident only exceeds 30 percent for no more than seven 6-minute averaging periods, the Permittee need only report the incident in the~~

~~quarterly report, in accordance with Condition 7.2.10(b)(ii).) The Permittee shall immediately notify the Illinois EPA's Regional Office, by telephone (voice, facsimile or electronic) for each incident in which the opacity from an affected operation exceeds or may have exceeded the applicable opacity standard for five or more 6 minute averaging periods. (Otherwise, if opacity during a malfunction or breakdown incident only exceeds or may have exceeded the applicable standard for no more than five 6-minute averaging periods, the Permittee need only report the incident in accordance with Condition 7.2.10(b)(ii).)~~

B. Upon conclusion of each incident that is two hours or more in duration, the Permittee shall submit a written follow-up notice to the Illinois EPA, Compliance Section and Regional Office, within 15 days providing a ~~detailed description of the incident and its cause(s), an explanation why continued operation was necessary, the length of time during which operation continued under such conditions, the measures taken by the Permittee to minimize and correct deficiencies with chronology, and when the repairs were completed or the affected operation was taken out of service~~ copy of the records for the incident required by Condition 7.2.9(e).

ii. The Permittee shall submit quarterly reports to the Illinois EPA that include the following information for incidents during the quarter in which affected operations continued to operate during malfunction or breakdown with excess emissions or excess opacity. These reports shall be submitted with the quarterly reports submitted for the coal-fired boiler pursuant to Condition 7.1.10-2(a).

A. A listing of such incidents, in chronological order, that includes:

~~(1)~~ I. ~~The~~ date, time, and duration of each incident,

~~(2)~~ II. ~~The~~ identity of the affected operation(s) involved in the incident, and

~~(3)~~ III. ~~Whether~~ whether a follow-up notice was submitted for the incident pursuant to Condition 7.2.10(b)(i)(B), with the date of the notice.

- B. A description of the incident, discussion of probable cause of the incident, corrective actions taken, and any preventative measures taken; provided, however, that the Permittee need not resubmit information provided in a prior report for an incident, as identified above, but may elect to supplement the prior submittal.~~The detailed information for each such incident required pursuant to Condition 7.2.10(a) (as each incident constitutes a deviation) and Condition 7.2.10(b)(i)(B). For this purpose, the Permittee need not resubmit information provided in a prior report for an incident, as identified above, but may elect to supplement the prior submittal.~~
- C. The ~~aggregate sum~~ duration of all incidents during the quarter.
- D. If there have been no such incidents during the calendar quarter, this shall be stated in the report.

7.2.11 Operational Flexibility/Anticipated Operating Scenarios

The Permittee is authorized to make the following physical or operational ~~change~~changes with respect to the affected operations without prior notification to the Illinois EPA or revision of this permit, pursuant to Section 39.5(7)(a) and (1) of the Act. This condition does not affect the Permittee's obligation to continue to comply with applicable requirements or to properly obtain a construction permit in a timely manner for any activity constituting a modification as defined by 40 CFR 52.21 ~~or 35 IAC 203.207, as applicable,~~ or for an activity for which a permit is required pursuant to 35 IAC 201.142.

- a. Handling of solid fuels other than coal.
- b. Operation of additional dust suppressant systems.
- c. Operation of additional dust collection equipment.

- d. Operation of replacement dust suppression systems or dust collection equipment that is of equal or greater effectiveness in controlling PM-visible emissions than the device(s) being replaced, as recognized in a Construction Permit for such system or equipment.

7.2.12 Compliance Procedures

- a. Compliance with Conditions 7.2.4 is addressed by the ~~control, testing, inspection~~observations, inspections, and recordkeeping required by Conditions ~~7.2.6(a), 7.2.7(a), 7.2.8 and 7.2.9~~, respectively.
- b. Compliance with Condition 7.2.6(a) is addressed by the ~~testing, inspection, inspections~~ and recordkeeping required by Conditions ~~7.2.7, 7.2.8~~ and 7.2.9, respectively.
- c. Compliance with Condition 7.2.6(b) is addressed by the ~~control, testing, testing~~, inspections, and recordkeeping required by Conditions ~~7.2.6(a), 7.2.7(b)~~, 7.2.8 and 7.2.9, respectively.

Note: This condition is included in this permit pursuant to Section 39.5(7)(p)(v) of the Act.

7.3 Fly Ash Equipment

7.3.1 Description

The Permittee operates a dry fly ash removal system that handles and stores fly ash collected at the coal-fired boilers. Associated particulate matter (PM) emissions are controlled by various control measures including such as moisture content of the fly ash, enclosures and covers, and dust collection devices.

Note: The description in Condition 7.3.1 is for informational purposes only and implies no limits or constraints.

7.3.2 List of Emission Units and Air Pollution Control Equipment

The following is a list of the fly ash equipment and associated emission control systems at the source:

Emission Unit Description	Emission Control Equipment/ <u>Measures</u>
Fly Ash Conveying System	Dust Collection Devices, Enclosures and Covers
Fly Ash <u>Storage Silos and Loadouts (NM FAS, FAS)</u>	Dust Collection Devices, Enclosures and Covers (SDC1, SDC2)
<u>Dry Fly Ash Loadout</u>	<u>Dust Collection Devices, Dust Suppression, Enclosures and Covers</u>
Fly Ash Batch Mixer and Truck <u>Conditioned Ash</u> Loadout	Wet Process, <u>Enclosures and Chutes</u>

7.3.3 Applicability Provisions

- a. An "affected process" for the purpose of these unit-specific conditions, is an individual process emission unit that handles fly ash as described in Conditions 7.3.1 and 7.3.2.
- b. Subject to the following terms and conditions, the Permittee is authorized to continue operation of an affected process in violation of the applicable requirements of Condition 7.3.4(b) (35 IAC 212.123) and Condition 7.3.4(c) (35 IAC 212.321(a)) in the event of a malfunction or breakdown of an affected process. This authorization is provided pursuant to 35 IAC 201.149, 201.~~161~~261, and 201.262, as the Permittee has applied for such authorization in its application, generally explaining why such operation would be required to provide essential service or to prevent injury to personnel or severe damage to equipment, and describing the measures that will be

taken to minimize emissions from any malfunctions and breakdowns. This authorization supersedes the general prohibition in Condition 9.2.3 against continued operation in such circumstances.

- i. This authorization only allows such continued operation as related to the operation of the coal-fired boilers as necessary to provide essential service or to prevent injury to personnel or severe damage to equipment and does not extend to continued operation solely for the economic benefit of the Permittee.
- ii. Upon occurrence of excess emissions due to malfunction or breakdown, the Permittee shall as soon as practicable repair the affected process, remove the affected process from service, or undertake other action so that excess emissions cease.
- iii. The Permittee shall fulfill applicable recordkeeping and reporting requirements of ~~Condition~~Conditions 7.3.9(~~fe~~) and 7.3.10(b). For these purposes, time shall be measured from the start of a particular incident. The absence of excess emissions for a short period shall not be considered to end the incident if excess emissions resume. In such circumstances, the incident shall be considered to continue until corrective actions are taken so that excess emissions cease or the Permittee takes the affected process out of service.
- iv. Following notification to the Illinois EPA of a malfunction or breakdown with excess emissions, the Permittee shall comply with all reasonable directives of the Illinois EPA with respect to such incident, pursuant to 35 IAC 201.263.
- v. This authorization does not relieve the Permittee from the continuing obligation to minimize excess emissions during malfunction or breakdown. As provided by 35 IAC 201.265, an authorization in a permit for continued operation with excess emissions during malfunction and breakdown does not shield the Permittee from enforcement for any such violation and only constitutes a prima facie defense to such an enforcement action provided that the Permittee has fully complied with all terms and conditions connected with such authorization.

7.3.4 Applicable Emission Standards

- a. Fugitive emissions, as defined by 35 IAC 211.2490, of ~~the~~ affected processes shall comply with the standard in Condition 5.2.2(a), which addresses visible emissions of fugitive particulate matter, ~~as defined by 35 IAC 211.2490, from the affected processes,~~ pursuant to 35 IAC 212.301.
- b. The affected processes shall comply with the standard, i.e., 30 percent opacity, in Condition 5.2.2(b), which addresses the opacity of the emission of smoke or other particulate matter from the affected processes, pursuant to 35 IAC 212.123.
- c. The affected processes shall comply with 35 IAC 212.321(a), ~~which provides that:~~ "no person shall cause or allow the emission of particulate matter into the atmosphere in any one hour period from any new process emission unit which, either alone or in combination with the emission of particulate matter from all other similar process emission units for which construction or modification commenced on or after April 14, 1972, at a source or premises, exceeds the allowable emission rates specified in subsection (c) of [35 IAC 212.321(b) and (e)]". (See also Attachment 1.) [35 IAC 212.321(a)]

7.3.5 Non-Applicability of Regulations of Concern

- a. The affected processes are not subject to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for Major Stationary Sources for PM, because the affected processes do not have potential pre-control device emissions of the applicable regulated air pollutant that equal or exceed major source threshold levels.

~~None~~

7.3.6 Work Practices, ~~Operational and Production Limits,~~ and Emission Limitations

- a. i. The Permittee shall implement and maintain the control measures for the affected processes, ~~including such as enclosure and filtration type dust collection devices, that minimize visible,~~ for emissions of particulate matter ~~and provide assurance of compliance with~~ to support periodic monitoring for the applicable ~~emission standards control requirements~~ in Conditions 7.3.4 ~~and 7.3.6(b)~~, pursuant to Section 39.5(7)(a) of the Act.

ii. The ~~Permittee shall operate and maintain each affected process with the~~ control measures implemented and maintained shall be identified and operated in conformance with the records record required by Condition 7.3.9(b) (i) to satisfy Condition 7.3.6(a) (i).

b. PM emissions from the fly ash batch mixer shall not exceed 1.0 pound per hour and 4.4 tons per year. Compliance with this annual limitation shall be determined as a running total of 12 months of data, i.e., from the sum of the data for the current month plus the preceding 11 months [T1].

Note: The above limitations were established in Permit 02120049.

7.3.7 Opacity Observations and Emission Testing Requirements

a. i. The Permittee shall have the opacity of the emissions from the affected processes during representative ~~weather and~~ operating conditions determined by a qualified observer in accordance with ~~USEPA TestReference~~ Method 9, as further specified below, pursuant to Section 39.5(7) (d) of the Act.

A. For each affected process, ~~testing observations~~ shall be conducted at least annually. For this purpose, testing shall first be conducted within three months after the effective date not later than two years after the effectiveness of this Condition 7.3.7(a) condition.

B. Thereafter, for each affected process, observations shall be conducted every third year.

C. Upon written request by the Illinois EPA, such ~~testing~~ observations shall be conducted for specific affected process(es) ~~within~~ not later than 45 calendar days after the Permittee has received the request or on such later date agreed to by the Illinois EPA.

ii. The duration of opacity observations for each test shall be at least 30 minutes (five 6-minute averages) unless the average opacities for the first 12 minutes of observations (two six-minute averages) are ~~both less~~ each not greater than ~~5-0~~ 10.0 percent.

- iii. A. For each set of observations required by Conditions 7.3.7(a)(i)(A), (B), and (C), the Permittee shall notify the Illinois EPA at least 7 days in advance of the date of the first observation(s) and time of these tests, in order to allow the Illinois EPA to witness testing. This notification shall include the name and employer of the qualified observer(s).
 - B. The Permittee shall promptly notify the Illinois EPA of any changes in the time or date of the first observation(s) for testing.
- iv. The Permittee shall provide a copy of its observer's readings to the Illinois EPA at the time of testing the observation(s), if Illinois EPA personnel are present.
- v. The Permittee shall submit a written report for these observations not later than 30 days after the date of completion of each set of opacity observations required by Conditions 7.3.7(a)(i)(A), (B), and (C). The report shall include a copy of the current Reference Method 9 certification of each observer and shall identify the observer's current employer. This report shall also include the following for each observation~~The Permittee shall submit a written report for this testing within 15 days of the date of testing. This report shall include:~~
 - A. Identification of the affected process for which observations were conducted.
 - B. Date and time of testing observations.
 - ~~B. Name and employer of qualified observer.~~
 - ~~C. Copy of current certification.~~
 - BC. Description of observation conditions, including recent weather.
 - ED. Description of the operating conditions of the affected processes.
 - FE. Raw data.
 - GE. Opacity determinations.

~~H~~G. Conclusions.

- b. i. Within 90 days ~~of~~after the Permittee has received a written request from the Illinois EPA, the Permittee shall have the PM emissions at the stacks or vents of the affected processes, as specified in such request, measured during representative operating conditions, as set forth below, pursuant to Section 39.5(7)(d) of the Act.
- ii. A. Testing shall be conducted using appropriate ~~USEPA Reference Test~~ Methods, including Method 5 or 17 for PM emissions.
- B. Compliance may be determined from the average of three valid test runs, subject to the limitations and conditions contained in 35 IAC Part 283.
- iii. The Permittee shall submit a test plan as required to the Illinois EPA at least 60 days prior to testing, which plan shall include the information specified by Condition 8.6.2.
- iv. The Illinois EPA shall be notified prior to these tests to enable the Illinois EPA to observe these tests. Notification of the expected date of testing shall be submitted a minimum of 30 days prior to the expected date. Notification of the actual date and expected time of testing shall be submitted a minimum of 5 working days prior to the actual date of the test. The Illinois EPA may, at its discretion, accept notification with shorter advance notice provided that the Illinois EPA will not accept such notification if it interferes with the Illinois EPA's ability to observe the testing.
- v. The Permittee shall expeditiously submit complete ~~F~~final Report(s) for required emission testing to the Illinois EPA, no later than 90 days after the date of testing. These reports shall include the information specified in Condition 8.6.3 and a detailed description of the operating conditions of those affected processes during testing, including operating rate (tons/hr) and the control devices being used.~~the following information:~~
- ~~A. A summary of results.~~

- ~~B. Detailed description of test method(s), including description of sampling points, sampling train, analysis equipment, and test schedule.~~
- ~~C. Detailed description of the operating conditions of the affected process during testing, including operating rate (tons/hr) and the control measures being used.~~
- ~~D. Detailed data and calculations, including copies of all raw data sheets and records of laboratory analyses, sample calculations, and data on equipment calibration.~~
- ~~E. Representative opacity data (6 minute average) measured during testing.~~

7.3.8 Inspection Requirements

- a. ~~The Permittee shall perform inspections of the affected processes on at least a weekly basis, including associated control measures, while the affected processes are in use, as follows to confirm compliance with the requirements of Condition 7.3.6(a). These inspections shall be performed by personnel who are not directly involved in the day-to-day operation of the affected processes. [Sections 39.5(7)(a) and (d) of the Act].~~
 - i. Affected processes other than loadout operations shall be inspected on at least a monthly basis.
 - ii. Affected loadout operations shall be inspected on at least a weekly basis.
 - iii. If an affected process is not in operation during an inspection, this shall be noted in the inspection record.
 - iv. The records required by Condition 7.3.9(d) for these inspections shall be signed off by supervisory or management personnel.
- b. ~~As part of the inspections of Condition 7.3.8(a), the Permittee shall perform observations of the affected processes for visible emissions in accordance with 35 IAC 212.107 to demonstrate compliance with the requirements of Condition 7.3.4(b), unless the Permittee elects to perform Reference Method 9 observations in accordance with~~

Condition 7.3.7(a). These observations may be scheduled so that only a number of affected processes are reviewed during each inspection, provided, however, that each affected process that is in routine service shall be observed at least once during each calendar year in which it is operating other than loadout operations, which shall each be observed at least once during each calendar quarter in which such loadout operation is operating [Sections 39.5(7)(b) and (d) of the Act].

- c. If visible emissions are observed, the Permittee shall take corrective action within 2 hours to return the status of the process to no visible emission or shall conduct observations of opacity by Reference Method 9 within one week in accordance with Condition 7.3.7(a). If the Permittee performs Reference Method 9 observations under this Condition 7.3.8(b), such observations are not subject to the notice requirements of Condition 7.3.7(a)(iii) through (v) [Sections 39.5(7)(b) and (d) of the Act].

~~The Permittee shall perform detailed inspections of the dust collection equipment for affected processes at least every nine months while the processes are out of service, with an initial inspection performed before any maintenance and repair activities are conducted during the period the process is out of service and a follow up inspection performed after any such activities are completed. [Sections 39.5(7)(a) and (d) of the Act]~~

- d. The Permittee shall perform and document an inspection of the fly ash transport baghouses to confirm proper condition and operation at least once per week. This inspection shall include recording and verifying that the monitored baghouse differential pressure is within the operating range specified in the record required by Condition 7.3.9(b)(i) and that visible emissions are not observed in the baghouse exhaust [Sections 39.5(7)(a) and (d) of the Act].

7.3.9 Recordkeeping Requirements

- a. The Permittee shall maintain records of the following ~~items for the affected processes~~, pursuant to Sections 39.5(7)(a) and (e) of the Act:

~~a. The Permittee shall keep the following file(s) and log(s):~~

- ~~i. File(s) containing the following information for the affected processes, with supporting~~

~~information, which information shall be kept up to date.~~

~~A. Information related to the dust collection equipment associated with the affected processes, including the performance specifications for filter material and maximum design particulate matter emissions, gr/dscf.~~

~~B. The i. Maximum operating capacity of each affected process (tons/hour).~~

~~ii. Information related to any baghouses associated with the affected processes, including available design control efficiency or performance specifications and maximum design particulate matter emissions, gr/dscf., with supporting information, which information shall be kept up to date.~~

~~iii. Maintenance and repair log(s) for the air pollution control equipment associated with the affected processes, including dust suppressant application systems, which log(s) shall list the activities performed on each item of equipment or system, with date and description. (See also Condition 9.6.1, Control Equipment Maintenance Records.)~~

b. i. ~~The Permittee shall maintain a record, which shall be kept up to date to reflect any changes that the Permittee may elect to make, that contains the following for each affected process for which a control measure must be implemented and maintained pursuant to Condition 7.3.6(a)(i). The Permittee shall maintain a record, which shall be kept up to date, of the control measures currently being implemented for the affected processes pursuant to Condition 7.3.6(a). These control measures, as defined by the Permittee through these records, are referred to as the "established control measures" in this section of this permit.~~

~~A. The type of emission unit (pneumatic transfer system, silos, etc.) and the Permittee's designation for each emission unit with a description of the emission points on the emission unit;~~

~~B. Description of the primary control measures that are utilized, with a~~

description of the control measure and estimated frequency of application, if not continuous. If the primary control device is a baghouse, identification of the normal operating range for the differential pressure across the baghouse; and

C. Description of any secondary control measures that would be used based on circumstances (freezing temperatures, recent rain, dry weather, etc.) with identification of the circumstances in which they would be used and whether they would take the place of or supplement the primary control measures.

- ii. Accompanying this record, the Permittee shall maintain a demonstration that confirms that the ~~above established~~ control measures identified in the record required by Condition 7.3.9(b)(i) are sufficient to assure compliance with Condition 7.3.4(c) at the maximum process weight rate at which each affected process can be operated (tons material/fly ash/hour) and the emission limits in Condition 7.3.6(b), with supporting emission calculations and documentation for the emission factors and the efficiency of the control measures being relied upon by the Permittee. Except as addressed by Condition 7.3.9(a)(i)(A) or testing of an affected process is conducted in accordance with Condition 7.3.7(b), ~~This demonstration shall include the information addressed by Conditions 7.3.9(a)(i) and (ii), results of any testing conducted in accordance with 7.3.7(b), be developed using~~ emission factors for uncontrolled PM emissions, ~~efficiency of control measures, and/or~~ controlled PM emissions published by USEPA or other credible sources.
- iii. A copy of the record required by Condition 7.3.9(b)(i) shall be submitted to the Illinois EPA not later than 60 days after the effectiveness of Condition 7.3.9(b)(i). Any subsequent revisions to this record related to control measures or affected processes, including their method of operation, shall be submitted not later than 30 days after the date of the revision. Upon request by the Illinois EPA, the Permittee shall submit other relevant information related to the control

~~measures. Copies of these records shall be submitted to the Illinois EPA in accordance with Condition 5.6.2(d).~~

- c. The Permittee shall maintain a record of the amount of fly ash handled by the affected processes (tons/month and tons/year).
- d. The Permittee shall maintain records of the following for the inspections required by Condition 7.3.8:
 - ~~i. For the inspections required by Condition 7.3.8(a) for each affected process:~~
 - Ai. Date and time the inspection was performed, ~~and name(s) of inspection personnel, and specific affected process(es) inspected.~~
 - Bii. The observed condition of the control measures ~~for each identified in the record required by Condition 7.3.9(b)(i) for each inspected~~ affected process, including the presence of any visible emissions or atypical accumulations of fly ash in the vicinity of the process.
 - Eiii. A description of any maintenance or repair of equipment associated with ~~established~~ control measures identified in the record required by Condition 7.3.9(b)(i) that is recommended as a result of the inspection and ~~a review of outstanding recommendations for maintenance or repair from previous inspection(s), i.e., whether recommended action has been taken, is yet to be performed or no longer appears to be required~~ associated work order number(s).
 - Div. A description of any corrective action taken if visible emissions were observed, including whether corrective action took place within 2 hours of the observation and whether the status of the process returned to no visible emissions. A summary of the observed implementation or status of actual control measures, as compared to the established control measures.
 - v. For the baghouse inspection in Condition 7.3.8(d), a record of the actual differential pressure observed.
 - ~~ii. For the inspections required by Condition 7.3.8(b) for the dust collection equipment for affected processes:~~

- ~~A. Date and time the inspection was performed and name(s) of inspection personnel.~~
 - ~~B. The observed condition of the equipment.~~
 - ~~C. A summary of the maintenance and repair that is to be or was conducted on the equipment.~~
 - ~~D. A description of any maintenance or repair that is recommended as a result of the inspection and a review of outstanding recommendations for maintenance or repair from previous inspection(s), i.e., whether recommended action has been taken, is yet to be performed or no longer appears to be required.~~
 - ~~E. A summary of the observed condition of the equipment as related to its ability to reliably and effectively control emissions.~~
- e. The Permittee shall maintain records of the following for each incident when any affected process operated without the control measure(s) required pursuant to the record required by Condition 7.3.9(b)(i) and each incident when an affected process continued to operate during malfunction or breakdown with excess emissions or excess opacity as addressed by Condition 7.3.3(b):
 - i. The date of the incident and identification of the affected process(es) that was involved.
 - ii. A description of the incident, including the control measure(s) that was not present or operated as required by the record identified in Condition 7.3.9(b)(i); other control measures that were operated, if any; the measures taken to minimize and correct deficiencies with chronology; and an explanation whether the emissions or opacity during the incident exceeded any applicable emission or opacity standard, as listed in Condition 7.3.4.
 - iii. The time at and means by which the incident was identified, e.g., scheduled inspection or observation by operating personnel.

- iv. The length of time after the incident was identified that the affected processes continued to operate before the control measures required by the record identified in Condition 7.3.9(b)(i) were in place or the processes were shut down (to resume operation only after such control measures were in place); an explanation of why continued operation was necessary; and, if this time was more than one hour, an explanation of why this time was not shorter, including a description of any mitigation measures that were implemented during the incident.
- v. The estimated total duration of the incident, i.e., the total length of time that the affected processes ran without the control measure(s) required pursuant to the record required by Condition 7.3.9(b)(i) and the estimated amount of fly ash handled during the incident.
- vi. A discussion of the probable cause of the incident and any preventative measures taken.

~~The Permittee shall maintain records of the following for each incident when any affected process operated without the established control measures:~~

- ~~i. The date of the incident and identification of the affected process(es) that were involved.~~
- ~~ii. A description of the incident, including the established control measures that were not present or implemented; the established control measures that were present, if any; other control measures or mitigation measures that were implemented, if any; and the magnitude of the PM emissions during the incident.~~
- ~~iii. The time at and means by which the incident was identified, e.g., scheduled inspection or observation by operating personnel.~~
- ~~iv. The length of time after the incident was identified that the affected process(es) continued to operate before established control measures were in place or the operations were shutdown (to resume operation only after established control measures were in place) and, if this time was more than one hour, an explanation why this time was not shorter, including a description of any mitigation measures that were implemented during the incident.~~

- ~~v. The estimated total duration of the incident, i.e., the total length of time that the affected process(es) ran without established control measures and the estimated amount of material processed during the incident.~~
- ~~vi. A discussion of the probable cause of the incident and any preventative measures taken.~~
- ~~vii. A discussion whether any applicable emission standards, as listed in Condition 7.3.4 or the PM emission limit (lb/hr) in Condition 7.3.6(b) may have been violated during the incident, with an estimate of the amount of any additional or excess PM emissions (lb) from the incident, with supporting explanation.~~
- ~~f. Pursuant to 35 IAC 201.263 and Sections 39.5(7)(a) and (e) of the Act, the Permittee shall maintain records, related to malfunction and breakdown for an affected process that as a minimum, shall include:
 - ~~i. Maintenance and repair log(s) for the affected processes that, at a minimum, address aspects or components of such processes for which malfunction or breakdown has resulted in excess emissions, which shall list the activities performed on such aspects or components, with date, description and reason for the activity. In addition, in the maintenance and repair log(s) for control equipment required by Condition 7.3.9(a)(ii), the Permittee shall also list the reason for the activities that are performed.~~
 - ~~ii. Records for each incident when operation of an affected process continued during malfunction or breakdown, including continued operation with excess emissions as addressed by Condition 7.3.3(b) that include the following information:
 - ~~A. Date and duration of the incident.~~
 - ~~B. A description of the incident.~~
 - ~~C. The corrective actions used to reduce the quantity of emissions and the duration of the incident.~~
 - ~~D. Confirmation of fulfillment of the requirements of Condition 7.3.10(b), as applicable, including copies of follow-up~~~~~~

~~reports submitted pursuant to Condition 7.3.10(b)(ii).~~

~~E. If excess emissions occurred for one hour (60 minutes) or more:~~

~~I. A detailed explanation why continued operation of the affected process was necessary.~~

~~II. A detailed explanation of the preventative measures planned or taken to prevent similar malfunctions or breakdowns or reduce their frequency and severity.~~

~~III. An estimate of the magnitude of excess emissions occurring during the incident.~~

~~gf. The Permittee shall keep records for all opacity measurements-observations made in accordance with USEPA Reference Method 9 for the affected processes that it conducts or that are conducted ~~on~~ at its behalf ~~behest~~ by individuals who are qualified to make such observations. For each occasion on which such measurements-observations are made, these records shall include the formal report for the measurements observations if conducted pursuant to Condition 7.3.7 (Opacity Observation and Emission Testing Requirements),~~7~~ or otherwise the identity of the observer, a description of the measurements observations that were made, the operating condition of the affected process(es), the observed opacity, ~~and~~ copies of the raw data sheets for the measurements observations, and the reason for the opacity observations, e.g., Reference Method 9 opacity observations required by Condition 7.3.7(a)(i), written request by the Illinois EPA, or any required Reference Method 9 opacity observations following observations of visible emissions under Condition 7.3.8(b).~~

~~hg. To demonstrate compliance with Condition 7.3.6(b), the Permittee shall keep records for PM emissions of the fly ash batch mixer (tons/month and tons/year) based on the above records, with supporting calculations required by Condition 7.3.9(b)(ii).~~

7.3.10 Reporting Requirements

a. Reporting of Deviations

The Permittee shall promptly notify the Illinois EPA of deviations from permit requirements for the affected processes, as follows. Such notifications shall include a description of each deviation and a discussion of the probable cause of deviation, any corrective actions taken, and any preventative measures taken, pursuant to Section 39.5(7)(f)(ii) of the Act.

i. For those breakdown or malfunction PM and opacity events that require notification and reporting pursuant to Condition 7.3.10(b)(i), notification and reporting shall be provided pursuant to Condition 7.3.10(b)(i) rather than 7.3.10(a).

ii. Within 30 days after the conclusion of an incident in which the Permittee continued to operate an affected process for more than 12 operating hours after discovering that emission control measures required by the record identified in Condition 7.3.9(b)(i) were not present or operating, the Permittee shall submit written notice to the Illinois EPA. Such notifications shall be accompanied by a copy of the records for the incident required by Condition 7.3.9(e).

iii. A. Except for events and incidents for which notification or reporting is required by Condition 7.3.10(a)(ii) or 7.3.10(b)(i), as referenced in 7.3.10(a)(i), all other notifications shall be submitted with the quarterly reports required by Condition 7.3.10(b)(ii).

B. With the quarterly report, the Permittee shall also address deviations that occurred during the quarter that have been separately reported to the Illinois EPA, with a summary of such deviations. For this purpose, the Permittee need not resubmit the detailed information provided in prior notifications and reports for such deviations.

b. Reporting When Continued Operation Occurred During Malfunctions and Breakdowns

Pursuant to 35 IAC 201.263 and Sections 39.5(7)(a) and (f) of the Act, the Permittee shall provide the following notifications and reports to the Illinois EPA for incidents when operation of an affected process(es) continued with excess emissions or excess

opacity during malfunction or breakdown as addressed by Condition 7.3.3(b).

- i. A. The Permittee shall immediately notify the Illinois EPA's Regional Office, by telephone, facsimile, or electronic mail, for each incident in which the opacity from an affected process exceeds 30 percent for eight or more 6-minute averaging periods within a two hour period unless the Permittee has begun the shutdown by such time. (Otherwise, if opacity during an incident only exceeds 30 percent for no more than seven 6-minute averaging periods, the Permittee need only report the incident in the quarterly report, in accordance with Condition 7.3.10(b)(ii).)
- B. Upon conclusion of each incident that is two hours or more in duration, the Permittee shall submit a written follow-up notice to the Illinois EPA, Compliance Section and Regional Office, within 15 days providing a copy of the records for the incident required by Condition 7.3.9(e).
- ii. The Permittee shall submit quarterly reports to the Illinois EPA that include the following information for incidents during the quarter in which affected processes continued to operate during malfunction or breakdown with excess emissions or excess opacity. These reports shall be submitted with the quarterly reports submitted for the coal-fired boiler pursuant to Condition 7.1.10-2(a).
 - A. A listing of such incidents, in chronological order, that includes:
 - ~~(1)~~I. ~~†~~The date, time, and duration of each incident;
 - ~~(2)~~II. ~~†~~The identity of the affected process(es) involved in the incident; and
 - ~~(3)~~III. ~~‡~~Whether a follow-up notice was submitted for the incident pursuant to Condition 7.3.10(b)(i)(B), with the date of the notice.

B. A description of the incident, discussion of probable cause of the incident, corrective actions taken, and any preventative measures taken; provided, however, that the Permittee need not resubmit information provided in a prior report for an incident, as identified above, but may elect to supplement the prior submittal.

C. The sum duration of all incidents during the quarter.

D. If there have been no such incidents during the calendar quarter, this shall be stated in the report.

~~a. Reporting of Deviations~~

~~The Permittee shall promptly notify the Illinois EPA of deviations from permit requirements for affected processes, as follows. Such notifications shall include a description of each deviation and a discussion of the probable cause, any corrective actions taken, and any preventative measures taken, pursuant to Section 39.5(7)(f)(ii) of the Act.~~

~~i. Notification and reporting as specified in Condition 7.3.10(b)(i) for certain deviations from Condition 7.3.4(b).~~

~~ii. Notification within 30 days for operation of an affected process that was not in compliance with applicable requirements in Condition 7.3.6(a) that continued for more than four operating hours from the time that it was identified. Such notifications shall be accompanied by a copy of the records for the incident required by Condition 7.3.9(c).~~

~~iii. A. Notification with the quarterly reports required by Condition 7.3.10(b)(ii) for other deviations, including deviations from applicable emission standards, inspection requirements and recordkeeping requirements.~~

~~B. With these report, the Permittee shall also address deviations that occurred during the quarter that have been separately reported to the Illinois EPA, with a summary of such deviations. For this purpose, the Permittee need not resubmit the detailed information~~

~~provided in prior notifications and reports for such deviations.~~

~~b. Reporting of Continued Operation During Malfunctions And Breakdowns~~

~~Pursuant to 35 IAC 201.263 and Sections 39.5(7)(a) and (f) of the Act, the Permittee shall provide the following notifications and reports to the Illinois EPA for incidents when operation of affected process(es) continued with excess emissions, including continued operation during malfunction or breakdown as addressed by Condition 7.3.3(b).~~

~~i. A. The Permittee shall immediately notify the Illinois EPA's Regional Office, by telephone (voice, facsimile or electronic) for each incident in which the opacity from an affected process exceeds or may have exceeded the applicable opacity standard for four or more 6-minute averaging periods. (Otherwise, if opacity during a malfunction or breakdown incident only exceeds or may have exceeded the applicable standard for no more than three 6 minute averaging periods, the Permittee need only report the incident in accordance with Condition 7.3.10(b)(ii).)~~

~~B. Upon conclusion of each incident that is two hours or more in duration, the Permittee shall submit a written follow-up notice to the Illinois EPA, Compliance Section and Regional Office, within 15 days providing a detailed description of the incident and its cause(s), an explanation why continued operation was necessary, the length of time during which operation continued under such conditions, the measures taken by the Permittee to minimize and correct deficiencies with chronology, and when the repairs were completed or the affected process was taken out of service.~~

~~ii. The Permittee shall submit quarterly reports to the Illinois EPA that include the following information for incidents during the quarter in which affected processes continued to operate during malfunction or breakdown with excess emissions. These reports shall be submitted with~~

~~the quarterly reports submitted for the coal-fired boiler pursuant to Condition 7.1.10-2(a).~~

- ~~1. A listing of such incidents, in chronological order, that includes: (1) the date, time, and duration of each incident, (2) the identity of the affected process(es) involved in the incident, and (3) whether a follow up notice was submitted for the incident pursuant to Condition 7.3.10(b)(i)(B), with the date of the notice.~~
- ~~B. The detailed information for each such incident required pursuant to Condition 7.3.10(a) (as each incident constitutes a deviation) and Condition 7.3.10(b)(i)(B). For this purpose, the Permittee need not resubmit information provided in a prior report for an incident, as identified above, but may elect to supplement the prior submittal.~~
- ~~C. The aggregate duration of all incidents during the quarter.~~
- ~~D. If there have been no such incidents during the calendar quarter, this shall be stated in the report.~~

7.3.11 Operational Flexibility/Anticipated Operating Scenarios

The Permittee is authorized to make the following physical or operational ~~change~~changes with respect to the affected processes without prior notification to the Illinois EPA or revision of this permit, pursuant to Section 39.5(7)(a) and (1) of the Act. This condition does not affect the Permittee's obligation to continue to comply with applicable requirements or to properly obtain a construction permit in a timely manner for any activity constituting a modification as defined by 40 CFR 52.21 ~~or 35 IAC 203.207, as applicable,~~ or for an activity for which a permit is required pursuant to 35 IAC 201.142.

- a. Operation of additional dust ~~suppressant systems~~control measures.
- ~~b. Operation of additional dust collection equipment.~~
- ~~eb.~~ Operation of replacement dust ~~suppression systems or dust collection equipment~~control measures that ~~is~~are of equal or greater effectiveness in controlling PM visible emissions than the ~~device(s)~~measures being

replaced, as recognized in a Construction Permit for such ~~system or equipment~~measures.

7.3.12 Compliance Procedures

- a. Compliance with Condition~~s~~ 7.3.4 is addressed by the ~~control, testing, inspection, observations, inspections,~~ and recordkeeping required by Conditions 7.3.67(a), ~~7.3.7,~~ 7.3.8, and 7.3.9, respectively.
- b. Compliance with Condition~~s~~ 7.3.6(~~b~~) is addressed by the ~~control, testing, inspections,~~ and recordkeeping required by Conditions ~~7.3.6(a), 7.3.7,~~ 7.3.8, and 7.3.9, respectively.
- ~~c. Compliance with Condition 7.3.6(a) is addressed by the testing, inspection, and recordkeeping required by Conditions 7.3.7, 7.3.8, and 7.3.9, respectively.~~

Note: This condition is included in this permit pursuant to Section 39.5(7)(p)(v) of the Act.

7.4 Storage Tank

7.4.1 Description

The storage tank is associated with non-retail dispensing of gasoline for plant vehicles.

Note: The description in Condition 7.4.1 is for informational purposes only implies no limits or constraints.

7.4.2 List of Emission Units and Air Pollution Control Equipment

<u>Emission Unit</u>	<u>Emission Unit Description</u>	<u>Emission Control Equipment/Measures</u>
Gasoline Storage Tank NCT-1	Gasoline Storage Tank (1,000 Gallon)	Submerged Loading Pipe

7.4.3 Applicability Provisions

An "affected storage tank" for the purpose of these unit-specific conditions, is a storage tank described in Conditions 7.4.1 and 7.4.2.

7.4.4 Applicable Emission Standards

a. The affected storage tanks ~~are~~ is subject to 35 IAC 215.122(b) and 215.583(a)(1), which provides that:

- i. No person shall cause or allow the loading of any organic material into any stationary tank having a storage capacity of greater than 946 l (250 gal), unless such tank is equipped with a permanent submerged loading pipe, submerged fill, or an equivalent device approved by the Illinois EPA according to the provisions of 35 IAC 201 or unless such tank is a pressure tank as described in 35 IAC 215.121(a) or is fitted with a recovery system as described in 35 IAC 215.121(b)(2) [35 IAC 215.122(b)].

Note: The exception to this standard at 35 IAC 215.122(c) is not applicable because the vapor pressure of gasoline is greater than 17.24 kPa (2.5 psia) at 294.3°K (70°F).

- ii. No person shall cause or allow the transfer of gasoline from any delivery vessel into any stationary storage tank at a gasoline dispensing facility unless the tank is equipped with a submerged loading pipe [35 IAC 215.583(a)(1)].

7.4.5 Non-Applicability of Regulations of Concern

- a. This permit is issued based on the affected storage tank not being subject to the New Source Performance Standards (NSPS) for Volatile Organic Liquid Storage Vessels (Including Petroleum Liquid Storage Vessels), 40 CFR Part 60, Subpart Kb, because the capacity of the tank is less than 40 cubic meters (10,566 gallons).
- b. This permit is issued based on each affected storage tank not being subject to 35 IAC 215.121, because ~~each~~the capacity of the affected storage tank is less than 40,000 gallons.
- c. This permit is issued based on each affected storage tank not being subject to 35 IAC 215.122(a), because ~~each~~the capacity of the affected storage tank is less than 40,000 gallons.
- d. The requirements of 35 IAC 215.583(a)(2) do not apply to transfers of gasoline to the affected storage tank because the storage tank is not located in any of the following counties: Boone, Peoria, Rock Island, Tazewell, or Winnebago [35 IAC 215.583(b)].
- e. The affected gasoline storage tank is not subject to 40 CFR Part 64, Compliance Assurance Monitoring (CAM) for Major Stationary Sources for VOM because the affected storage tank does not use add-on controls to achieve compliance with any applicable emission limits.

7.4.6 Work Practices, Operational and Production Limits, and Emission Limitations

- a. The affected storage tanks shall be equipped and operated with a submerged loading pipe or an equivalent device approved by the Illinois EPA, pursuant to 35 IAC 215.122(b) and 215.583(a). (The Illinois EPA has not approved use of other equivalent equipment in lieu of a submerged loading pipe.)

7.4.7 Emission Testing Requirements

None

7.4.8 Inspection Requirements

On an annual basis, ~~in the period between March 1 and April 30~~by May 1st of each year, the Permittee shall conduct an ~~Inspection~~inspection of the affected ~~storage~~ tank ~~and to review~~ its physical condition and ability to

comply with the applicable equipment requirements of Conditions 7.4.6(a), pursuant to Sections 39.5(7)(a) and (d) of the Act.

7.4.9 Recordkeeping Requirements

The Permittee shall maintain records of the following items for the affected storage tanks, pursuant to Section 39.5(7)(a) and (e) of the Act:

- a. Design information for the capacity of the tank and the presence of a permanent submerged loading pipe.
- b. Operating log(s) or other records for the affected tank that at a minimum, shall include the following:
 - i. Information documenting performance of the inspections that are required by Condition 7.4.8, including date and description of the inspection, confirmation of the adequacy of the specific features of the tank required for control of emissions, and identification of any such features that are not in proper working order or otherwise deficient, with recommendations for maintenance, repair or replacement.
 - ii. Information identifying deviations from applicable equipment requirements, with a detailed description and explanation.
- c. Maintenance and repair records for the affected storage tanks, as related to the repair or replacement of the loading pipe.
- d. Records for each shipment of material loaded into the affected storage tank, including type of material and amount.
- e. Throughput of material, gal/mo and gal/yr, by type of material.

7.4.10 Reporting Requirements

For the affected storage tank, the Permittee shall promptly notify the Illinois EPA of deviations from permit requirements as follows. Such notifications shall include a description of each incident and a discussion of the probable cause of deviation, any corrective actions taken and any preventative measures taken, pursuant to Section 39.5(7)(f)(ii) of the Act:

- a. NotificationThe Permittee shall submit written notice to the Illinois EPA within 30 days ~~for~~after any

filling of an affected storage tank that was not in compliance with the requirements of Conditions 7.4.4 or 7.4.6, i.e., that was conducted without a submerged loading pipe.

- b. ~~Notification with~~The Permittee shall notify the Illinois EPA through the quarterly reports required by Condition 7.1.10-2(a) for ~~other deviations, including~~ deviations from applicable recordkeeping requirements.

7.4.11 Operational Flexibility/Anticipated Operating Scenarios

The Permittee is authorized to make the following physical or operational change with respect to the affected storage tanks without prior notification to the Illinois EPA or revision of this permit, pursuant to Section 39.5(7)(a) and (l) of the Act. This condition does not affect the Permittee's obligation to continue to comply with applicable requirements or to properly obtain a construction permit in a timely manner for any activity constituting a modification as defined by 40 CFR 52.21 ~~or 35 IAC 203.207, as applicable,~~ or for any activity constituting construction or modification as defined in 35 IAC 201.102.

- a. Changes to components related to the submerged loading pipe, including addition of new components and repair and replacement of components.
- b. Changes in the material stored in the affected storage tanks.

7.4.12 Compliance Procedures

- a. Compliance with Condition 7.4.4(a) is addressed by the use of a submerged loading pipe as required in Condition 7.4.6(a) and by the inspections and recordkeeping required by Conditions 7.4.8 and 7.4.9.
- b. Compliance with Condition 7.4.6 is addressed by the inspections and the recordkeeping required by Conditions 7.4.8 and 7.4.9, respectively.

Note: This condition is included in this permit pursuant to Section 39.5(7)(p)(v) of the Act.

8.0 GENERAL PERMIT CONDITIONS

8.1 Permit Shield

Pursuant to Section 39.5(7)(j) of the Act, the Permittee has requested and has been granted a permit shield. This permit shield provides that compliance with the conditions of this permit shall be deemed compliance with applicable requirements which were applicable as of the date the proposed permit for this source was issued, provided that either the applicable requirements are specifically identified within this permit, or the Illinois EPA, in acting on this permit application, has determined that other requirements specifically identified are not applicable to this source and this determination (or a concise summary thereof) is included in this permit.

8.2 Applicability of Title IV Requirements (Acid Deposition Control)

This source is an affected source under Title IV of the CAA and is subject to requirements pursuant to Title IV of the CAA as specified in Section 6.2. To the extent that the federal regulations promulgated under Title IV of the CAA, are inconsistent with the requirements of this permit, the federal regulations promulgated under Title IV of the CAA shall take precedence pursuant to Section 39.5(17)(j) of the Act.

8.3 Emissions Trading Programs

No permit revision shall be required for increases in emissions allowed under any USEPA approved economic incentives, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for elsewhere in this permit and that are authorized by the applicable requirement [Section 39.5(7)(o)(vii) of the Act].

8.4 Operational Flexibility/Anticipated Operating Scenarios

8.4.1 Changes Specifically Addressed by Permit

Physical or operational changes specifically addressed by the Conditions of this permit that have been identified as not requiring Illinois EPA notification may be implemented without prior notice to the Illinois EPA.

8.4.2 Changes Requiring Prior Notification

The Permittee is authorized to make physical or operational changes that contravene express permit terms without applying for or obtaining an amendment to this permit, provided that [Section 39.5(12)(a)(i) of the Act]:

- a. The changes do not violate applicable requirements;

- b. The changes do not contravene federally enforceable permit terms or conditions that are monitoring (including test methods), recordkeeping, reporting, or compliance certification requirements;
- c. The changes do not constitute a modification under Title I of the CAA;
- d. Emissions will not exceed the emissions allowed under this permit following implementation of the physical or operational change; and
- e. The Permittee provides written notice to the Illinois EPA, Division of Air Pollution Control, Permit Section, at least 7 days before commencement of the change. This notice shall:
 - i. Describe the physical or operational change;
 - ii. Identify the schedule for implementing the physical or operational change;
 - iii. Provide a statement of whether or not any New Source Performance Standard (NSPS) is applicable to the physical or operational change and the reason why the NSPS does or does not apply;
 - iv. Provide emission calculations which demonstrate that the physical or operational change will not result in a modification; and
 - v. Provide a certification that the physical or operational change will not result in emissions greater than authorized under the Conditions of this permit.

8.5 Testing Procedures

Tests conducted to measure composition of materials, efficiency of pollution control devices, emissions from process or control equipment, or other parameters shall be conducted using standard test methods if applicable test methods are not specified by the applicable regulations or otherwise identified in the condition of this permit. Documentation of the test date, conditions, methodologies, calculations, and test results shall be retained pursuant to the recordkeeping procedures of this permit. Reports of any tests conducted as required by this permit or as the result of a request by the Illinois EPA shall be submitted as specified in Conditions 8.6.3 and 8.6.4.

8.6 Reporting Requirements

8.6.1 Monitoring Reports

Reports summarizing required monitoring as specified in the conditions of this permit shall be submitted to the Illinois EPA every six months as follows, unless more frequent submittal of such reports is required in Section 7 of this permit [Section 39.5(7)(f) of the Act]:

<u>Monitoring Period</u>	<u>Report Due Date</u>
January - June	September 1
July - December	March 1

All instances of deviations from permit requirements must be clearly identified in such reports. All such reports shall be certified in accordance with Condition 9.9.

8.6.2 Test Notifications

Unless otherwise specified elsewhere in this permit, a written test plan for any test required by this permit shall be submitted to the Illinois EPA for review at least 60 days prior to the testing pursuant to Section 39.5(7)(a) of the Act. The notification shall include at a minimum:

- a. The name and identification of the affected unit(s);
- b. The person(s) who will be performing sampling and analysis and their experience with similar tests;
- c. The specific conditions under which testing will be performed, including a discussion of why these conditions will be representative of maximum emissions and the means by which the operating parameters for the source and any control equipment will be determined;
- d. The specific determinations of emissions and operation that are intended to be made, including sampling and monitoring locations;
- e. The test method(s) that will be used, with the specific analysis method, if the method can be used with different analysis methods;
- f. Any minor changes in standard methodology proposed to accommodate the specific circumstances of testing, with justification; and

- g. Any proposed use of an alternative test method, with detailed justification.

8.6.3 Test Reports

Unless otherwise specified elsewhere in this permit, the results of any test required by this permit shall be submitted to the Illinois EPA within 60 days of completion of the testing. The test report shall include at a minimum [Section 39.5(7)(e)(i) of the Act]:

- a. The name and identification of the affected unit(s);
- b. The date and time of the sampling or measurements;
- c. The date any analyses were performed;
- d. The name of the company that performed the tests and/or analyses;
- e. The test and analytical methodologies used;
- f. The results of the tests including raw data, and/or analyses including sample calculations;
- g. The operating conditions at the time of the sampling or measurements; and
- h. The name of any relevant observers present including the testing company's representatives, any Illinois EPA or USEPA representatives, and the representatives of the source.

8.6.4 Reporting Addresses

- a. Unless otherwise specified in the particular provision of this permit or in the written instructions distributed by the Illinois EPA for particular reports, reports and notifications shall be sent to the Illinois EPA - Air Compliance Section with a copy sent to the Illinois EPA - Air Regional Field Office.
- b. As of the date of issuance of this permit, the addresses of the offices that should generally be utilized for the submittal of reports and notifications are as follows:

i. Illinois EPA - Air Compliance Section

Illinois Environmental Protection Agency
Bureau of Air
Compliance & Enforcement Section (#MC 40)
[1021 North Grand Avenue East](#)
P.O. Box 19276
Springfield, Illinois 62794-9276

ii. Illinois EPA - Air Regional Field Office

Illinois Environmental Protection Agency
Division of Air Pollution Control
2009 Mall Street
Collinsville, Illinois 62234

iii. USEPA Region 5 - Air Branch

USEPA (AR - 17J)
Air & Radiation Division
77 West Jackson Boulevard
Chicago, Illinois 60604

- c. Permit applications should be addressed to the Air Permit Section. As of the date of issuance of this permit, the address of the Air Permit Section is as follows:

Illinois Environmental Protection Agency
Division of Air Pollution Control
Permit Section (MC 11)
[1021 North Grand Avenue East](#)
P.O. Box 19506
Springfield, Illinois 62794-9506

8.7 Title I Conditions

Notwithstanding the expiration date on the first page of this CAAPP permit, Title I conditions in this permit, which are identified by a T1, T1N, or T1R designation, remain in effect until such time as the Illinois EPA takes action to revise or terminate them in accordance with applicable procedures for action on Title I conditions. This is because these conditions either: (a) incorporate conditions of earlier permits that were issued by the Illinois EPA pursuant to authority that includes authority found in Title I of the Clean Air Act (T1 conditions), (b) were newly established in this CAAPP permit pursuant to authority that includes such Title I authority (T1N conditions), or (c) reflect a combination of conditions of such previous permits and revisions to those conditions established in this CAAPP permit (T1R conditions). (See also Condition 1.5.)

9.0 STANDARD PERMIT CONDITIONS

9.1 Effect of Permit

- 9.1.1 The issuance of this permit does not release the Permittee from compliance with State and Federal regulations which are part of the Illinois State Implementation Plan, as well as with other applicable statutes and regulations of the United States or the State of Illinois or applicable ordinances, except as specifically stated in this permit and as allowed by law and rule [Section 39.5(7)(j)(iv) of the Act].
- 9.1.2 In particular, this permit does not alter or affect the following:
- a. The provisions of Section 303 (emergency powers) of the CAA, including USEPA's authority under that Section;
 - b. The liability of an owner or operator of a source for any violation of applicable requirements prior to or at the time of permit issuance;
 - c. The applicable requirements of the acid rain program consistent with Section 408(a) of the CAA; and
 - d. The ability of USEPA to obtain information from a source pursuant to Section 114 (inspections, monitoring, and entry) of the CAA.
- 9.1.3 Notwithstanding the conditions of this permit specifying compliance practices for applicable requirements, any person (including the Permittee) may also use other credible evidence to establish compliance with, or violation of, any applicable requirement to the extent authorized by law. Nothing in this permit shall be construed to waive any defenses otherwise available to the Permittee, including, but not limited to, challenging the use of the USEPA's credible evidence rule in the context of any future proceeding consistent with *Clean Air Implementation Project v. EPA*, 150 F3d 1200 (D.C. Circuit 1998).

9.2 General Obligations of Permittee

9.2.1 Duty to Comply

The Permittee must comply with all terms and conditions of this permit. Any permit noncompliance constitutes a violation of the CAA and the Act, and is grounds for any or all of the following: enforcement action, permit termination, revocation and reissuance, modification, or

denial of a permit renewal application. [Section 39.5(7)(o)(i) of the Act]

The Permittee shall meet applicable requirements that become effective during the permit term in a timely manner unless an alternate schedule for compliance with the applicable requirement is established.

9.2.2 Duty to Maintain Equipment

The Permittee shall maintain all equipment covered under this permit in such a manner that the performance or operation of such equipment shall not cause a violation of applicable requirements.

9.2.3 Duty to Cease Operation

No person shall cause, threaten or allow the continued operation of any emission unit during malfunction or breakdown of the emission unit or related air pollution control equipment if such operation would cause a violation of an applicable emission standard, regulatory requirement, ambient air quality standard or permit limitation unless this permit provides for such continued operation consistent with the Act and applicable Board regulations. [Section 39.5(6)(c) of the Act]

9.2.4 Disposal Operations

The source shall be operated in such a manner that the disposal of air contaminants collected by the equipment operations, or activities shall not cause a violation of the Act or regulations promulgated thereunder.

9.3 Obligation to Allow Illinois EPA Surveillance

Pursuant to Sections 4(b), 39.5(7)(a), and 39.5(7)(p)(ii) of the Act, upon presentation of credentials and other documents as may be required by law and in accordance with constitutional limitations, the Permittee shall allow the Illinois EPA, or an authorized representative to perform the following. Upon presentation of proper credentials and other documents, the Permittee shall allow the Illinois EPA, or an authorized representative to perform the following. [Sections 4 and 39.5(7)(a) and (p)(ii) of the Act]

- a. Enter upon the Permittee's premises where the emission unit(s) are located, or emissions-related activity is conducted, or where records must be kept under the conditions of this permit. Enter upon the Permittee's premises where an actual or potential emission unit is located; where any regulated equipment, operation, or

~~activity is located or where records must be kept under the conditions of this permit.~~

- b. Have access to and copy, at reasonable times, any records that must be kept under the conditions of this permit.
- c. Inspect ~~during hours of operation~~ at reasonable times any ~~sources~~ facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit.
- d. Sample or monitor any substances or parameters at any location:
 - i. ~~As authorized by the Clean Air Act, at~~ At reasonable times, for the purposes of assuring ~~permit~~ compliance with this CAAPP permit or applicable requirements; or
 - ii. As otherwise authorized by the ~~CAA or the Act~~.
- ~~e. Obtain and remove samples of any discharge or emission of pollutants authorized by this permit; and~~
- fe. Enter and utilize any photographic, recording, testing, monitoring, or other equipment for the purposes of preserving, testing, monitoring, or recording any activity, discharge or emission at the source authorized by this permit.

9.4 Fees

The Permittee shall pay fees to the Illinois EPA consistent with the fee schedule approved pursuant to Section 39.5(18) of the Act, and submit any information relevant thereto [Section 39.5(7)(o)(vi) of the Act]. Fees shall be paid by check sent to the Fiscal Services Section, Illinois Environmental Protection Agency, P.O. Box 19276, Springfield, Illinois, 62794-9276.

9.5 Property Rights

This permit does not convey any property rights of any sort, or any exclusive privilege [Section 39.5(7)(o)(iv) of the Act].

9.6 Recordkeeping

9.6.1 Control Equipment Maintenance Records

A maintenance record shall be kept on the premises for each item of air pollution control equipment. As a minimum, this record shall show the dates of performance and nature of preventative maintenance activities.

9.6.2 Records of Changes in Operation

A record shall be kept describing changes made at the source that result in emissions of a regulated air pollutant subject to an applicable requirement, but not otherwise regulated under this permit, and the emissions resulting from those changes [Section 39.5(12)(b)(iv) of the Act].

9.6.3 Retention of Records

- a. Records of all monitoring data and support information shall be retained for a period of at least 5 years from the date of the monitoring sample, measurement, report, or application. Support information includes all calibration and maintenance records, original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit [Section 39.5(7)(e)(ii) of the Act].
- b. Other records required by this permit including any logs, plans, procedures, or instructions required to be kept by this permit shall be retained for a period of at least 5 years from the date of entry unless a longer period is specified by a particular permit provision.

9.7 Annual Emissions Report

The Permittee shall submit an annual emissions report to the Illinois EPA, ~~Compliance~~Air Quality Planning Section no later than May 1 of the following year, as required by 35 IAC Part 254 and Section 4(b) of the Act.

9.8 Requirements for Compliance Certification

Pursuant to Section 39.5(7)(p)(v) of the Act, the Permittee shall submit annual compliance certifications. The compliance certifications shall be submitted no later than May 1 or more frequently as specified in the applicable requirements or by permit condition. The compliance certifications shall be submitted to: (1) the Illinois EPA, Air Compliance Section, (2) the Illinois EPA, Air Regional Field Office, and (3) USEPA Region 5 - Air Branch. (The addresses for the submittal of these compliance certifications are provided in Condition 8.6.4.)

- a. The certification shall include the identification of each term or condition of this permit that is the basis of the certification; the compliance status; whether compliance was continuous or intermittent; the method(s) used for determining the compliance status of the source, both currently and over the reporting period consistent with the conditions of this permit.

- b. All compliance certifications shall be submitted to USEPA Region 5 in Chicago as well as to the Illinois EPA.
- c. All compliance reports required to be submitted shall include a certification in accordance with Condition 9.9.

9.9 Certification

Any document (including reports) required to be submitted by this permit shall contain a certification by a responsible official of the Permittee that meets the requirements of Section 39.5(5) of the Act. [Section 39.5(7)(p)(i) of the Act] An example Certification by a Responsible Official is included as an attachment to this permit.

9.10 Defense to Enforcement Actions

9.10.1 Need to Halt or Reduce Activity Not a Defense

It shall not be a defense for the Permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of this permit [Section 39.5(7)(o)(ii) of the Act].

9.10.2 Emergency Provision

- a. An emergency shall be an affirmative defense to an action brought for noncompliance with the technology-based emission limitations under this permit if the following conditions are met through properly signed, contemporaneous operating logs, or other relevant evidence:

- i. An emergency occurred as provided in Section 39.5(7)(k) of the Act and the Permittee can identify the cause(s) of the emergency;

Note: For this purpose, emergency means a situation arising from sudden and reasonably unforeseeable events beyond the control of the source, as further defined by Section 39.5(7)(k)(iv) of the Act.

- ii. The permitted source was at the time being properly operated;
- iii. The Permittee submitted notice of the emergency to the Illinois EPA within two working days of the time when emission limitations were exceeded due to the emergency. This notice must contain a

detailed description of the emergency, any steps taken to mitigate emissions, and corrective actions taken; and

iv. During the period of the emergency the Permittee took all reasonable steps to minimize levels of emissions that exceeded the emission limitations, standards, or regulations in this permit.

b. This provision is in addition to any emergency or upset provision contained in any applicable requirement. This provision does not relieve a Permittee of any reporting obligations under existing federal or state laws or regulations.

9.11 Permanent Shutdown

This permit only covers emission units and control equipment while physically present at the indicated source location(s). Unless this permit specifically provides for equipment relocation, this permit is void for the operation or activity of any item of equipment on the date it is removed from the permitted location(s) or permanently shut down. This permit expires if all equipment is removed from the permitted location(s), notwithstanding the expiration date specified on this permit.

9.12 Reopening and Reissuing Permit for Cause

9.12.1 Permit Actions

This permit may be modified, revoked, reopened and reissued, or terminated for cause in accordance with applicable provisions of Section 39.5 of the Act. The filing of a request by the Permittee for a permit modification, revocation and reissuance, or termination, or of a notification of planned changes or anticipated noncompliance does not stay any permit condition [Section 39.5(7)(o)(iii) of the Act].

9.12.2 Reopening and Revision

This permit must be reopened and revised if any of the following occur [Section 39.5(15)(a) of the Act]:

- a. Additional requirements become applicable to the equipment covered by this permit and three or more years remain before expiration of this permit;
- b. Additional requirements become applicable to an affected source for acid deposition under the acid rain program;

- c. The Illinois EPA or USEPA determines that this permit contains a material mistake or that inaccurate statement were made in establishing the emission standards or limitations, or other terms or conditions of this permit; and
- d. The Illinois EPA or USEPA determines that this permit must be revised or revoked to ensure compliance with the applicable requirements.

9.12.3 Inaccurate Application

The Illinois EPA has issued this permit based upon the information submitted by the Permittee in the permit application. Any misinformation, false statement or misrepresentation in the application shall be grounds for revocation and reissuance under Section 39.5(15) of the Act, pursuant to Sections 39.5(5)(e) and (i) of the Act.

9.12.4 Duty to Provide Information

The Permittee shall furnish to the Illinois EPA, within a reasonable time specified by the Illinois EPA any information that the Illinois EPA may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating this permit, or to determine compliance with this permit. Upon request, the Permittee shall also furnish to the Illinois EPA copies of records required to be kept by this permit, or for information claimed to be confidential, the Permittee may furnish such records directly to USEPA along with a claim of confidentiality [Section 39.5(7)(o)(v) of the Act].

9.13 Severability Clause

The provisions of this permit are severable. In the event of a challenge to any portion of this permit, other portions of this permit may continue to be in effect. Should any portion of this permit be determined to be illegal or unenforceable, the validity of the other provisions shall not be affected and the rights and obligations of the Permittee shall be construed and enforced as if this permit did not contain the particular provisions held to be invalid and the applicable requirements underlying these provisions shall remain in force [Section 39.5(7)(i) of the Act].

9.14 Permit Expiration and Renewal

Upon the expiration of this permit, if the source is operated, it shall be deemed to be operating without a permit unless a timely and complete CAAPP application has been submitted for renewal of this permit. However, if a timely and complete application to

renew this CAAPP permit has been submitted, the terms and all conditions of this CAAPP permit will remain in effect until the issuance of a renewal permit [Sections 39.5(5)(l) and (o) of the Act].

Note: Pursuant to Sections 39.5(5)(h) and (n) of the Act, upon submittal of a timely and complete renewal application, the permitted source may continue to operate until final action is taken by the Illinois EPA on the renewal application, provided, however, that this protection shall cease if the applicant fails to submit any additional information necessary to evaluate or take final action on the renewal application as requested by the Illinois EPA in writing. For a renewal application to be timely, it must be submitted no later than 9 months prior to the date of permit expiration.

9.15 General Authority for the Terms and Conditions of this Permit

The authority for terms and conditions of this permit that do not include a citation for their authority is Section 39.5(7)(a) of the Act, which provides that the Illinois EPA shall include such provisions in a CAAPP permit as are necessary to accomplish the purposes of the Act and to assure compliance with all applicable requirements. Section 39.5(7)(a) of the Act is also another basis of authority for terms and conditions of this permit that do include a specific citation for their authority.

Note: This condition is included in this permit pursuant to Section 39.5(7)(n) of the Act.

10.0 ATTACHMENTS

10.1 Attachment 1 Emissions of Particulate Matter from New Process Emission Units

35 IAC 212.321 - Process Emission Units ~~For~~ Which Construction or Modification Commenced On or After April 14, 1972

~~a.)~~ Except as further provided in this Part, no person shall cause or allow the emission of particulate matter into the atmosphere in any one hour period from any new process emission unit which, either alone or in combination with the emission of particulate matter from all other similar process emission units for which construction or modification commenced on or after April 14, 1972, at a source or premises, exceeds the allowable emission rates specified in subsection (c) of this Section~~35 IAC 212.321 [35 IAC 212.321(a)]~~.

~~b.)~~ Interpolated and extrapolated values of the data in subsection (c) of ~~35 IAC 212.321~~this Section shall be determined by using the equation ~~[35 IAC 212.321(b)]~~:

$$E = A(P)^B$$

Where:

P = Process weight rate; and
E = Allowable emission rate; and,

~~ii.1)~~ Up to process weight rates of 408 Mg/hr (450 T/hr):

	Metric	English
P	Mg/hr	T/hr
E	kg/hr	lbs/hr
A	1.214	2.54
B	0.534	0.534

~~ii.2)~~ For process weight rate greater than or equal to 408 Mg/hr (450 T/hr):

	Metric	English
P	Mg/hr	T/hr
E	kg/hr	lbs/hr
A	11.42	24.8
B	0.16	0.16

c-1) Limits for Process Emission Units For Which Construction or Modification Commenced On or After April 19, 1972 ~~35 IAC 212.321(e)~~;

Metric		English	
P	E	P	E
Mg/hr	kg/hr	T/hr	lbs/hr
0.05	0.25	0.05	0.55
0.1	0.29	0.10	0.77
0.2	0.42	0.20	1.10
0.3	0.64	0.30	1.35
0.4	0.74	0.40	1.58
0.5	0.84	0.50	1.75
0.7	1.00	0.75	2.40
0.9	1.15	1.00	2.60
1.8	1.66	2.00	3.70
2.7	2.1	3.00	4.60
3.6	2.4	4.00	5.35
4.5	2.7	5.00	6.00
9.0	3.9	10.00	8.70
13.0	4.8	15.00	10.80
18.0	5.7	20.00	12.50
23.0	6.5	25.00	14.00
27.0	7.1	30.00	15.60
32.0	7.7	35.00	17.00
36.0	8.2	40.00	18.20
41.0	8.8	45.00	19.20
45.0	9.3	50.00	20.50
90.0	13.4	100.00	29.50
140.0	17.0	150.00	37.00
180.0	19.4	200.00	43.00
230.0	22.0	250.00	48.50
270.0	24.0	300.00	53.00
320.0	26.0	350.00	58.00
360.0	28.0	400.00	62.00
408.0	30.1	450.00	66.00
454.0	30.4	500.00	67.00

where:

P = Process weight rate in metric or T/hr, and
E = Allowable emission rate in kg/hr or lbs/hr.

10.2 Attachment 2 Emissions of Particulate Matter from Existing Process Emission Units

35 IAC 212.322 - Process Emission Units ~~For~~ Which Construction or Modification Commenced Prior to April 14, 1972

~~a-)~~ Except as further provided in this Part, No person shall cause or allow the emission of particulate matter into the atmosphere in any one hour period from any process emission unit for which construction or modification commenced prior to April 14, 1972, which, either alone or in combination with the emission of particulate matter from all other similar process emission units at a source or premises, exceeds the allowable emission rates specified in subsection (c) of this Section~~35 IAC 212.322 [35 IAC 212.322(a)]~~.

~~b-)~~ Interpolated and extrapolated values of the data in subsection (c) of this Section~~35 IAC 212.322~~ shall be determined by using the equation ~~[35 IAC 212.322(b)]~~:

$$E = C + A(P)^B$$

Where:

P = Process weight rate; and
E = Allowable emission rate; and,

~~i-1)~~ Up to~~For~~ process weight rates up to 27.2 Mg/hr (30 T/hr):

	Metric	English
P	Mg/hr	T/hr
E	kg/hr	lbs/hr
A	1.985	4.10
B	0.67	0.67
C	0	0

~~i-2)~~ For process weight rates in excess of 27.2 Mg/hr (30 T/hr):

	Metric	English
P	Mg/hr	T/hr
E	kg/hr	lbs/hr
A	25.21	55.0
B	0.11	0.11
C	-18.4	-40.0

c-1) Limits for Process Emission Units For Which Construction or Modification Commenced Prior to April 14, 1972-~~35~~
IAC 212.322(e)-

<u>Metric</u>	<u>Metric</u>	English	
P	E	P	E
Mg/hr	kg/hr	T/hr	lbs/hr
0.05	0.27	0.05	0.55
0.1	0.42	0.10	0.87
0.2	0.68	0.20	1.40
0.3	0.89	0.30	1.83
0.4	1.07	0.40	2.22
0.5	1.25	0.50	2.58
0.7	1.56	0.75	3.38
0.9	1.85	1.00	4.10
1.8	2.9	2.00	6.52
2.7	3.9	3.00	8.56
3.6	4.7	4.00	10.40
4.5	5.4	5.00	12.00
9.0	8.7	10.00	19.20
13.0	11.1	15.00	25.20
18.0	13.8	20.00	30.50
23.0	16.2	25.00	35.40
27.2	18.15	30.00	40.00
32.0	18.8	35.00	41.30
36.0	19.3	40.00	42.50
41.0	19.8	45.00	43.60
45.0	20.2	50.00	44.60
90.0	23.2	100.00	51.20
140.0	25.3	150.00	55.40
180.0	26.5	200.00	58.60
230.0	27.7	250.00	61.00
270.0	28.5	300.00	63.10
320.0	29.4	350.00	64.90
360.0	30.0	400.00	66.20
400.0	30.6	450.00	67.70
454.0	31.3	500.00	69.00

where:

P = Process weight rate in Mg/hr or T/hr, and

E = Allowable emission rate in kg/hr or lbs/hr.

10.3 Attachment 3 - Example Certification by a Responsible Official

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Signature: _____

Name: _____

Official Title: _____

Telephone No.: _____

Date Signed: _____

10.4 Attachment 4 - Guidance

The Illinois has prepared guidance for sources on the Clean Air Act Permit Program (CAAPP) that is available on the Internet site maintained by the Illinois EPA, www.epa.state.il.us. This guidance includes instructions on applying for a revision or renewal of the CAAPP permit.

Guidance On Revising A CAAPP Permit:

www.epa.state.il.us/air/caapp/caapp-revising.pdf

Guidance On Renewing A CAAPP Permit:

www.epa.state.il.us/air/caapp/caapp-renewing.pdf

The application forms prepared by the Illinois EPA for the CAAPP are also available from the Illinois EPA's Internet site:

www.epa.state.il.us/air/caapp/index.html

These CAAPP application forms should also be used by a CAAPP source when it applies for a construction permit. For this purpose, the appropriate CAAPP application forms and other supporting information, should be accompanied by a completed Application For A Construction Permit Form (CAAPP Form-199).

Application For A Construction Permit Form (CAAPP Form-199):

www.epa.state.il.us/air/caapp/199-caapp.pdf

10.5 Attachment 5 - Acid Rain Program Permit

217-782-2113

**ACID RAIN PROGRAM
PERMIT**

~~Ameren Energy Generating Co./Ameren Services~~ Illinois Power
Generating Company

Attn: ~~Mr. Daniel F. Cole~~ Alan Bogardus, Designated Representative
~~1901 Chouteau Avenue~~ 1500 Eastport Plaza Drive
~~P.O. Box 66149, MC 07~~
~~St. Louis, Missouri 63166-6149~~ Collinsville, Illinois 62234

Oris No.: 6017
IEPA I.D. No.: 079808AAA
Source/Unit: Newton ~~Power Station~~ Energy Center/ Units 1 and
2
Date Received: July 2, 2004
Date Issued: March 18, 2005
Effective Date: January 1, 2005
Expiration Date: December 31, 2009

STATEMENT OF BASIS:

In accordance with Titles IV and V of the Clean Air Act, the Illinois Environmental Protection Agency is issuing this Acid Rain Program Permit to ~~Ameren Energy~~ Illinois Power Generating Company for its Newton ~~Power Station~~ Energy Center.

**SULFUR DIOXIDE (SO₂) ALLOCATIONS AND NITROGEN OXIDES (NO_x) LIMITS
FOR EACH AFFECTED UNIT:**

UNIT 1	SO ₂ Allowances, under Tables 2, 3, or 4 of 40 CFR Part 73*	2005	2006	2007	2008	2009
		15,625	15,625	15,625	15,625	15,625
	NO _x Limit	See Provisions for NO _x Averaging Plan, Below				

* Also includes return of repowering deduction of 5 allowances, which were returned by USEPA on October 30, 2000.

UNIT 2	SO ₂ Allowances, under Tables 2, 3, or 4 of 40 CFR Part 73*	2005	2006	2007	2008	2009
		13,932	13,932	13,932	13,932	13,932
	NO _x Limit	See Provisions for NO _x Averaging Plan, Below				

* Also includes return of repowering deduction of 4 allowances, which were returned by USEPA on October 30, 2000.

NO_x EMISSIONS AVERAGING PLAN

Pursuant to 40 CFR 76.11, the Illinois EPA approves a NO_x emissions averaging plan that includes the Newton Units 1 and 2, effective for calendar years 2005 through 2009 (attached). Under this plan, except as provided below, the NO_x emissions of Newton Units 1 and 2 each shall not exceed the annual average alternative contemporaneous emission limitation of 0.45 lb/mmBtu.

Under this plan, the actual Btu-weighted annual average NO_x emission rate for the units in the plan shall be less than or equal to the Btu-weighted annual average NO_x emission rate for the same units had they each been operated during that calendar year in compliance with the applicable emission limitation under 40 CFR 76.5, 76.6, or 76.7. If the designated representative demonstrates that the requirement of the prior sentence (as set forth in 40 CFR 76.11(d)(1)(ii)(A)) is met for a year under the plan, then the units covered by the plan shall be deemed to be in compliance for that year with their alternative contemporaneous annual emission limitations and any annual heat input limits.

PERMIT APPLICATION: The permit application, including the NO_x Compliance Plan and NO_x Averaging Plan, is attached and incorporated as part of this permit. The owners and operators of this source must comply with the standard requirements and special provisions set forth in the application.

COMMENTS, NOTES, AND JUSTIFICATIONS: This permit contains provisions related to SO₂ emissions and requires the owners and operators to hold SO₂ allowances under the federal Acid Rain program to account for SO₂ emissions from the affected units. An allowance is a limited authorization to emit up to one ton of SO₂ during or after a specified calendar year. The transfer of allowances to and from a unit account does not necessitate a revision to the unit SO₂ allocations denoted in this permit (See 40 CFR 72.84).

This permit contains provisions related to NO_x emissions requiring the affected units to comply with applicable emission limitations for NO_x under the Acid Rain program. Pursuant to 40 CFR 76.11, the Illinois EPA is approving a NO_x emission averaging plan that includes Newton Units 1 and 2 for calendar years 2005 through 2009. In addition to the described NO_x compliance plan, Newton Units 1 and 2 shall comply with all other applicable requirements of 40 CFR Part 76, including the duty to reapply for a NO_x compliance plan and requirements covering excess emissions.

This permit does not affect the source's responsibility to meet all other applicable local, state and federal requirements, including state requirements under 35 Ill. Adm. Code Part 217 Subpart W, which addresses NO_x emissions from Newton Units 1 and 2.

If you have any questions regarding this permit, please contact Kunj Patel at 217-782-2113.

Donald E. Sutton, P.E. Raymond E. Pilapil
Acting Manager, Permits Section
Division of Air Pollution Control

DESREP:KMP:jar

cc: Cecilia Mijares, USEPA Region V
John Justice, IEPA Region 3

Formatted: Indent: Left: 1.75"

Plant Name (from Step 1)	Newton
--------------------------	--------

STEP 3
Read the
standard
requirements

Permit Requirements

- (1) The designated representative of each affected source and each affected unit at the source shall:
- (i) Submit a complete Acid Rain permit application (including a compliance plan) under 40 CFR part 72 in accordance with the deadlines specified in 40 CFR 72.30; and
 - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain permit application and issue or deny an Acid Rain permit;
- (2) The owners and operators of each affected source and each affected unit at the source shall:
- (i) Operate the unit in compliance with a complete Acid Rain permit application or a superseding Acid Rain permit issued by the permitting authority; and
 - (ii) Have an Acid Rain Permit.

Monitoring Requirements

- (1) The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the unit with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

Sulfur Dioxide Requirements

- (1) The owners and operators of each source and each affected unit at the source shall:
- (i) Hold allowances, as of the allowance transfer deadline, in the unit's compliance subaccount (after deductions under 40 CFR 73.34(c)), or in the compliance subaccount of another affected unit at the same source to the extent provided in 40 CFR 73.35(b)(3), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the unit; and
 - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An affected unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
- (i) Starting January 1, 2000, an affected unit under 40 CFR 72.8(a)(2); or
 - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an affected unit under 40 CFR 72.8(a)(3).
- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Plant Name (from Step 1) Newton

Acid Rain - Page 3

STEP 3,
Cont'd.

Nitrogen Oxides Requirements The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements

(1) The designated representative of an affected unit that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.

(2) The owners and operators of an affected unit that has excess emissions in any calendar year shall:

- (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
- (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

Recordkeeping and Reporting Requirements

(1) Unless otherwise provided, the owners and operators of the source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:

- (i) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated representative;
- (ii) All emissions monitoring information, in accordance with 40 CFR part 75, provided that to the extent that 40 CFR part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply.
- (iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program; and
- (iv) Copies of all documents used to complete an Acid Rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.

(2) The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under 40 CFR part 72 subpart I and 40 CFR part 75.

Liability

(1) Any person who knowingly violates any requirement or prohibition of the Acid Rain Program, a complete Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8, including any requirement for the payment of any penalty owed to the United States, shall be subject to enforcement pursuant to section 113(c) of the Act.

(2) Any person who knowingly makes a false, material statement in any record, submission, or report under the Acid Rain Program shall be subject to criminal enforcement pursuant to section 113(c) of the Act and 18 U.S.C. 1001.

(3) No permit revision shall excuse any violation of the requirements of the Acid Rain Program that occurs prior to the date that the revision takes effect.

(4) Each affected source and each affected unit shall meet the requirements of the Acid Rain Program.

Plant Name (from Step 1) Newton

**Step 3,
Cont'd.**

Liability, Cont'd

(5) Any provision of the Acid Rain Program that applies to an affected source (including a provision applicable to the designated representative of an affected source) shall also apply to the owners and operators of such source and of the affected units at the source.

(6) Any provision of the Acid Rain Program that applies to an affected unit (including a provision applicable to the designated representative of an affected unit) shall also apply to the owners and operators of such unit. Except as provided under 40 CFR 72.44 (Phase II repowering extension plans) and 40 CFR 76.11 (NO_x averaging plans), and except with regard to the requirements applicable to units with a common stack under 40 CFR part 75 (including 40 CFR 75.16, 75.17, and 75.18), the owners and operators and the designated representative of one affected unit shall not be liable for any violation by any other affected unit of which they are not owners or operators or the designated representative and that is located at a source of which they are not owners or operators or the designated representative.

(7) Each violation of a provision of 40 CFR parts 72, 73, 74, 75, 76, 77, and 78 by an affected source or affected unit, or by an owner or operator or designated representative of such source or unit, shall be a separate violation of the Act.

Effect on Other Authorities

No provision of the Acid Rain Program, an Acid Rain permit application, an Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 shall be construed as:

(1) Except as expressly provided in title IV of the Act, exempting or excluding the owners and operators and, to the extent applicable, the designated representative of an affected source or affected unit from compliance with any other provision of the Act, including the provisions of title I of the Act relating to applicable National Ambient Air Quality Standards or State Implementation Plans;

(2) Limiting the number of allowances a unit can hold; provided, that the number of allowances held by the unit shall not affect the source's obligation to comply with any other provisions of the Act;

(3) Requiring a change of any kind in any State law regulating electric utility rates and charges, affecting any State law regarding such State regulation, or limiting such State regulation, including any prudence review requirements under such State law;

(4) Modifying the Federal Power Act or affecting the authority of the Federal Energy Regulatory Commission under the Federal Power Act; or,


(5) Interfering with or impairing any program for competitive bidding for power supply in a State in which such program is established.

STEP 4

Certification

Read the certification statement, sign, and date

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name <u>Daniel F. Cole</u>	
Signature 	Date <u>6/20/04</u>



Phase II NO_x Compliance Plan Page 11 of 21

For more information, see instructions and refer to 40 CFR 75.9

This submission is: New Revised

STEP 1
Indicate plant name, State, and ORIS code from MADD, if applicable

Plant Name	Newton	IL	6017
		State	ORIS Code

STEP 2

Identify each affected Group 1 and Group 2 boiler using the boiler ID# from MADD, if applicable. Indicate boiler type: "CB" for cell burner, "CY" for cyclone, "DBW" for dry bottom wet-fired, "T" for tangentially fired, "V" for vertically fired, and "WB" for wet bottom. Indicate the compliance option selected for each unit.

Id 1	Id 2	ID#	ID#	ID#	ID#
Type T	Type T	Type	Type	Type	Type

- | | | | | | | |
|--|-------------------------------------|-------------------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| (a) Standard annual average emission limitation of 0.50 lb/MMBtu (for Phase I dry bottom wet-fired boilers) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| (b) Standard annual average emission limitation of 0.40 lb/MMBtu (for Phase I tangentially fired boilers) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| (c) EPA-approved early election plan under 40 CFR 75.9 through 10/1/07 (also indicate above emission limit specified in plan) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| (d) Standard annual average emission limitation of 0.65 lb/MMBtu (for Phase II dry bottom wet-fired boilers) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| (e) Standard annual average emission limitation of 0.40 lb/MMBtu (for Phase II tangentially fired boilers) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| (f) Standard annual average emission limitation of 0.65 lb/MMBtu (for cell burner boilers) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| (g) Standard annual average emission limitation of 0.55 lb/MMBtu (for cyclone boilers) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| (h) Standard annual average emission limitation of 0.40 lb/MMBtu (for vertically fired boilers) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| (i) Standard annual average emission limitation of 0.34 lb/MMBtu (for wet bottom boilers) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| (j) NO _x Averaging Plan (include NO _x Averaging form) | <input checked="" type="checkbox"/> | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| (k) Common stack agreement under 40 CFR 75.17(e)(1)(ii) (check the standard emission limitation box above for most stringent limitation applicable to any unit utilizing stack) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| (l) Common stack agreement under 40 CFR 75.17(e)(2)(ii) with NO _x Averaging (check the NO _x Averaging Plan box and include NO _x Averaging form) | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |

Newton
Plant Name (from Step 1)

NO_x Compliance - Page 2
Page 2 of 2

STEP 2, cont'd.

Id#	Id#	Id#	Id#	Id#	Id#
Type	Type	Type	Type	Type	Type

(m) EPA-approved common stack apportionment method pursuant to 40 CFR 75.114(a)(1)(C), (a)(2)(ii)(B), or (b)(2)	<input type="checkbox"/>					
(n) AEL (include Phase I) AEL Demonstration Period, Final AEL, Petition, or AEL Renewal form as appropriate)	<input type="checkbox"/>					
(o) Petition for AEL Demonstration period or final AEL under review by U.S. EPA or demonstration period ongoing	<input type="checkbox"/>					
(p) Reproving submission plan approved or under review	<input type="checkbox"/>					

STEP 3
Read the standard requirements and certification, enter the name of the designated representative, sign &

Standard Requirements

General. This source is subject to the standard requirements in 40 CFR 72.9 (consistent with 40 CFR 76.3(a)(1)(i)). Those requirements are listed in this source's Acid Rain Permit.


Special Provisions for Early Election Units

Hydrogen Oxides. A unit that is governed by an approved early election plan shall be subject to an emissions limitation for H₂O, as provided under 40 CFR 76.3(a)(2) except as provided under 40 CFR 76.3(a)(4).
Liability. The owners and operators of a unit governed by an approved early election plan shall be liable for any violation of the plan or 40 CFR 76.3 at that unit. The owners and operators shall be liable, beginning January 1, 2000, for fulfilling the obligations specified in 40 CFR Part 77.

Termination. An approved early election plan shall be in effect only until the earlier of January 1, 2008 or January 1 of the calendar year for which a termination of the plan takes effect. If the designated representative of the unit under an approved early election plan fails to demonstrate compliance with the applicable emissions limitation under 40 CFR 76.3 for any year during the period beginning January 1 of the first year the early election takes effect and ending December 31, 2007, the permitting authority will terminate the plan. The termination will take effect beginning January 1 of the year after the year for which there is a failure to demonstrate compliance, and the designated representative may not submit a new early election plan. The designated representative of the unit under an approved early election plan may terminate the plan any year prior to 2008 but may not submit a new early election plan. In order to terminate the plan, the designated representative must submit a notice under 40 CFR 72.40(a) by January 1 of the year for which the termination is to take effect. If an early election plan is terminated 365 days prior to 2000, the unit shall meet, beginning January 1, 2000, the applicable emissions limitation for NO_x for Phase II units with Group 1 boilers under 40 CFR 76.7. If an early election plan is terminated on or after 2000, the unit shall meet, beginning on the effective date of the termination, the applicable emissions limitation for NO_x for Phase II units with Group 1 boilers under 40 CFR 76.7.

Certification

I am authorized to make the submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my review of these individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name Daniel F. Cole	
Signature 	Date 6/30/04



Phase II NO_x Averaging Plan

For more information, see instructions and refer to 40 CFR 76.11

Page 1

This submission is: New Revised

Page 11 of 13

STEP 1

Identify the units participating in this averaging plan by plant name, State, and boiler ID# from NADB. In column (a), fill in each unit's applicable emission limitation from 40 CFR 76.5, 76.6, or 76.7. In column (b), assign an alternative contemporaneous annual emissions limitation (ACEL) in lb/mmBtu to each unit. In column (c), assign an annual heat input limitation in mmBtu to each unit. Continue to page 3 if necessary.

Plant Name	State	ID#	(a) Emission Limitation	(b) ACEL	(c) Annual Heat Input Limit
Coffeen	IL	01	0.86	0.86	22,000,000
Coffeen	IL	02	0.86	0.86	38,000,000
Hutsonville	IL	05	0.45	0.45	3,100,000
Hutsonville	IL	06	0.45	0.45	3,200,000
Meredosia	IL	01	0.45	0.45	1,300,000
Meredosia	IL	02	0.45	0.45	1,300,000
Meredosia	IL	03	0.45	0.45	1,300,000
Meredosia	IL	04	0.45	0.45	1,300,000
Meredosia	IL	05	0.45	0.45	12,000,000

STEP 2

Use the formula to enter the Ebu-weighted annual emission rate averaged over the units if they are operated in accordance with the proposed averaging plan and the Ebu-weighted annual average emission rate for the same units if they are operated in compliance with 40 CFR 76.5, 76.6, or 76.7. The former must be less than or equal to the latter.

Ebu-weighted annual emission rate averaged over the units if they are operated in accordance with the proposed averaging plan

Ebu-weighted annual average emission rate for same units operated in compliance with 40 CFR 76.5, 76.6 or 76.7

$$0.607 \leq 0.607$$

$$\frac{\sum_{i=1}^n (R_{L_i} \times HI_i)}{\sum_{i=1}^n HI_i} \leq \frac{\sum_{i=1}^n [R_{L_i} \times HI_i]}{\sum_{i=1}^n HI_i}$$

Where,

- R_{L_i} = Alternative contemporaneous annual emissions limitation for unit i, in lb/mmBtu, as specified in column (b) of Step 1.
- R_{L_i} = Applicable emission limitation for unit i, in lb/mmBtu, as specified in column (a) of Step 1.
- HI_i = Annual heat input for unit i, in mmBtu, as specified in column (c) of Step 1.
- n = Number of units in the averaging plan

Plant Name (from Step 1) Newton

NO, Averaging - Page 2

STEP 3
Mark one of the two options and enter dates.

- This plan is effective for calendar year 2005 through calendar year 2009 unless notification to terminate the plan is given.
- Treat this plan as identical plans, each effective for one calendar year for the following calendar years: _____ and _____ unless notification to terminate one or more of these plans is given.

STEP 4
Read the special provisions and certification, enter the name of the designated representative, and sign and date.

Special Provisions

Emission Limitations

Each affected unit in an approved averaging plan is in compliance with the Acid Rain emission limitation for NO_x under the plan only if the following requirements are met:

- (i) For each unit, the unit's actual annual average emission rate for the calendar year, in lb/mmBtu, is less than or equal to its alternative contemporaneous annual emission limitation in the averaging plan, and
- (ii) For each unit with an alternative contemporaneous emission limitation less stringent than the applicable emission limitation in 40 CFR 76.5, 76.6, or 76.7, the actual annual heat input for the calendar year does not exceed the annual heat input limit in the averaging plan.
- (b) For each unit with an alternative contemporaneous emission limitation more stringent than the applicable emission limitation in 40 CFR 76.5, 76.6, or 76.7, the actual annual heat input for the calendar year is not less than the annual heat input limit in the averaging plan, or
- (c) If one or more of the units does not meet the requirements of (i), the designated representative shall demonstrate, in accordance with 40 CFR 76.11(d)(1)(ii)(A) and (B), that the actual lbu-weighted annual average emission rate for the units in the plan is less than or equal to the lbu-weighted annual average rate for the same units had they each been operated, during the same period of time, in compliance with the applicable emission limitations in 40 CFR 76.5, 76.6, or 76.7.
- (d) If there is a successful group showing of compliance under 40 CFR 76.11(d)(1)(ii)(A) and (B) for a calendar year, then all units in the averaging plan shall be deemed to be in compliance for that year with their alternative contemporaneous emission limitations and annual heat input limits under (i).

Liability


The owners and operators of a unit governed by an approved averaging plan shall be liable for any violation of the plan or this section at that unit or any other unit in the plan, including liability for fulfilling the obligations specified in part 77 of this chapter and sections 113 and 411 of the Act.

Termination

The designated representative may submit a notification to terminate an approved averaging plan, in accordance with 40 CFR 72.40(d), no later than October 1 of the calendar year for which the plan is to be terminated.

Certification

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information or omitting required statements and information, including the possibility of fine or imprisonment.

Name	<u>Daniel F. Cole</u>	
Signature		Date <u>6/6/04</u>