

SUBPART D: CAIR NO_x EGU OZONE SEASON TRADING PROGRAM

Section

225.400	Purpose
225.405	Applicability
225.410	Compliance Requirements
225.415	Appeal Procedures
225.420	CAIR NO _x EGU Ozone Season Permitting Requirements
225.425	CAIR NO _x EGU Ozone Season Trading Budgets
225.430	Timing for CAIR NO _x EGU Ozone Season Allocations
225.435	Methodology for Calculating CAIR NO _x EGU Ozone Season Allocations
225.440	CAIR NO _x EGU Ozone Season Allocations
225.445	New Unit Set-Aside
225.450	Energy Efficiency Set-Aside
225.455	Renewable Energy Set-Aside
225.460	Other: IGCC, Clean Coal Technology, Control Equipment Upgrades Set-Aside, Efficient Operators, and Early Adopters
225.465	(Reserved)
225.470	Monitoring, Record Keeping and Reporting for Gross Output
225.480	Opt-in Provisions (Reserved)

- Applicability: Same as the annual program. Emission requirements begin May 1, 2009.
- Compliance Requirements – Same as the annual program. The allowance transfer deadline remains the November 30, after each control period. Ozone season or control period for this Subpart is May 1 through September 30 of each calendar year.
- Permitting Requirements – Same as the annual program.
- NO_x Ozone Season Trading Budgets – The total base EGU CAIR NO_x budget is 30,701 tons per control period in 2009 through 2014. The Agency is considering a minimum of a 5% reduction for a new source set-aside, and a minimum of a 25% reduction for environmental set-asides, clean coal technologies, and EGUs that implement equipment upgrades. The model rule does not provide for a compliance supplement pool for this program.
- For the control period 2015 and thereafter, the total base EGU CAIR budget is 28,926, subject to reductions for the above set-asides.
- Timing for NO_x Allocations – By October 2006, the Agency will allocate for 2009, 2010, and 2011, and each July 31 thereafter for the control period three years hence.
- Methodology for Calculating NO_x Allocations – Same as the annual program, where allocations will be based on gross electrical and thermal output.
- New Unit Set-Aside – A unit will receive an allocation based on its gross output until it rolls into the existing pool for allocations.