

Logan County

Water System	%GW	<GPD>	Population	Source Dates	Water Quality Issues	DB Search	SWAP Review	Potential Sources	Susceptibility
Atlanta	100	186,000	1,603	1987, 2001, 1996 (4)	Pb, As	6 LPC; 44 IEMA	9 potential sources	Not susceptible to IOC, VOC, or SOC	ND
Bartmann Health Center	100	10,000	ND	1986	None	1 IEMA	ND	ND	
Beason Chestnut PWD	100	43,100	600	1986 (?)	Cl, Mn	1 LPC; 1 IEMA	1 potential source	Susceptable	
Broadwell	100	14,490	150	1987	Mn	1 LPC, 1 IEMA	1 potential source	Susceptible	
Elkhart	100	67,200	500	1986	Mn	5 LPC, 23 IEMA	17 potential sources	Low to Susceptible	
Emden	100	90,500	515	1986	None	4 LPC; 30 IEMA	15 Potential Sources	Not Susceptible	
Hartsburg	100	22,611	400	1987, 2010, 2011	Cl, NO3	3 LPC; 30 IEMA	11 Potential Sources	Susceptible	
IL American-Lincoln	100	2,506,000	17,800	1986 (?)	Fe, Mn	48 LPC; 40 IEMA	12 Potential Sources	Susceptible	
Latham	100	27,700	380	1986	None	2 LPC; 12 IEMA	3 Potential Sources	Not Susceptible	
Middletown	100	29,000	425	1995 (?)	Pb, Mn, As	None	None	Not Susceptible	
Morningside MHP	100	11,400	138	1987	None	None	None	Susceptible	
Mount Pulaski	100	175,000	1,800	1982-2000	NO3, Mn	4 LPC; 6 IEMA	2 Potential Sources	Susceptible	
New Holland	100	30,805	333	1986	Mn, NO3, 2VOC	2 LPC; 28 IEMA	9 potential sources	Susceptible	