

NPDES Permit No. IL0059625  
Notice No. JAR:13061201.jar

Public Notice Beginning Date: **July 25, 2013**

Public Notice Ending Date: **August 26, 2013**

National Pollutant Discharge Elimination System (NPDES)  
Permit Program

Draft Reissued NPDES Permit to Discharge into Waters of the State

Public Notice/Fact Sheet Issued By:

Illinois Environmental Protection Agency  
Bureau of Water,  
Division of Water Pollution Control  
Permit Section  
1021 North Grand Avenue East  
Post Office Box 19276  
Springfield, Illinois 62794-9276  
217/782-0610

Name and Address of Discharger:

Frontier Communications  
11799 North College Avenue  
Carmel, Indiana 46032

Name and Address of Facility:

Frontier North, Inc.  
9062-9038 Old State Route 13 West  
Marion, Illinois 62959  
(Williamson County)

The Illinois Environmental Protection Agency (IEPA) has made a tentative determination to issue a NPDES permit to discharge into the waters of the state and has prepared a draft permit and associated fact sheet for the above named discharger. The Public Notice period will begin and end on the dates indicated in the heading of this Public Notice/Fact Sheet. The last day comments will be received will be on the Public Notice period ending date unless a commentor demonstrating the need for additional time requests an extension to this comment period and the request is granted by the IEPA. Interested persons are invited to submit written comments on the draft permit to the IEPA at the above address. Commentors shall provide his or her name and address and the nature of the issues proposed to be raised and the evidence proposed to be presented with regards to those issues. Commentors may include a request for public hearing. Persons submitting comments and/or requests for public hearing shall also send a copy of such comments or requests to the permit applicant. The NPDES permit and notice number(s) must appear on each comment page.

The application, engineer's review notes including load limit calculations, Public Notice/Fact Sheet, draft permit, comments received, and other documents are available for inspection and may be copied at the IEPA between 9:30 a.m. and 3:30 p.m. Monday through Friday when scheduled by the interested person.

If written comments or requests indicate a significant degree of public interest in the draft permit, the permitting authority may, at its discretion, hold a public hearing. Public notice will be given 45 days before any public hearing. Response to comments will be provided when the final permit is issued. For further information, please call Jaime Rabins at 217/782-0610.

The applicant is engaged in providing cable services (SIC 4841). Wastewater is generated from restrooms and results in an average discharge of 0.0001 MGD of sanitary from outfall 001. Wastewater is treated in a septic tank followed by a sand filter.

Application is made for the existing discharge which is located in Williamson County, Illinois. The following information identifies the discharge point, receiving stream and stream classifications:

Outfall	Receiving Stream	Latitude		Longitude		Stream Classification	Biological Stream Characterization
001	Unnamed Tributary of Little Crab Orchard Creek	37° 43' 45"	North	89° 00' 30"	West	General Use	Not Rated

To assist you further in identifying the location of the discharge please see the attached map.

The stream segment receiving the discharge from outfall 001 is not on the draft 2012 Illinois Integrated Water Quality Report and Section 303(d) List as it has not been assessed. The receiving water has not been given an integrity rating or been listed as biologically significant in the 2008 Illinois Department of Natural Resources publication *Integrating Multiple Taxa in a Biological Stream Rating System*.

The discharge(s) from the facility shall be monitored and limited at all times as follows:



Outfall: 001 Sanitary (DAF = 0.0001 MGD)

	LOAD LIMITS lbs/day			CONCENTRATION			
	DAF (DMF)			LIMITS mg/l			
PARAMETER	30 DAY AVERAGE	DAILY MAXIMUM	REGULATION	30 DAY AVERAGE	DAILY MAXIMUM	REGULATION	
Flow (MGD)							
pH						35 IAC 302.204	
BOD <sub>5</sub>				10	20	35 IAC 304.120(c)	
Total Suspended Solids				12	24	35 IAC 304.120(c)	
Fecal Coliform						35 IAC 304.121	
Total Residual Chlorine					0.05	35 IAC 302.208	
				Weekly Avg.	Monthly Avg.	Daily Max	
Ammonia (as N)							
Mar-May, Sep-Oct				6.8	2.7	15	
Jun-Aug				4.5	1.8	15	
Nov-Feb				6.7	4.0	6.7	
						35 IAC 302.212	

The following explain the conditions of the proposed permit:

The special conditions clarify: flow, pH, TRC, monitoring location, DMRs, re-opener, and treatment plant operator.

**Frontier Communications  
Frontier North, Inc.  
NPDES No. IL0059625**





NPDES Permit No. IL0059625

Illinois Environmental Protection Agency

Division of Water Pollution Control

1021 North Grand Avenue East

Post Office Box 19276

Springfield, Illinois 62794-9276

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

Reissued (NPDES) Permit

Expiration Date:

Issue Date:

Effective Date:

Name and Address of Permittee:

Facility Name and Address:

Frontier Communications  
11799 North College Avenue  
Carmel, Indiana 46032

Frontier North, Inc.  
9062-9038 Old State Route 13 West  
Marion, Illinois 62959  
(Williamson County)

Discharge Number and Name:

Receiving Waters:

001 Sanitary

Unnamed Tributary of Little Crab Orchard Creek

In compliance with the provisions of the Illinois Environmental Protection Act, Title 35 of Ill. Adm. Code, Subtitle C and/or Subtitle D, Chapter 1, and the Clean Water Act (CWA), the above-named permittee is hereby authorized to discharge at the above location to the above-named receiving stream in accordance with the standard conditions and attachments herein.

Permittee is not authorized to discharge after the above expiration date. In order to receive authorization to discharge beyond the expiration date, the permittee shall submit the proper application as required by the Illinois Environmental Protection Agency (IEPA) not later than 180 days prior to the expiration date.

Alan Keller, P.E.  
Manager, Permit Section  
Division of Water Pollution Control

SAK:JAR:13061201.jar

NPDES Permit No. IL0059625

Effluent Limitations and Monitoring

1. From the effective date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

Outfall: 001 Sanitary (DAF = 0.0001 MGD)

	LOAD LIMITS lbs/day DAF (DMF)		CONCENTRATION LIMITS mg/l				
PARAMETER	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM		SAMPLE FREQUENCY	SAMPLE TYPE
Flow (MGD)	See Special Condition 1					1/Month	
pH	See Special Condition 2					1/Month	Grab
BOD <sub>5</sub>			10	12		1/Month	Grab
Total Suspended Solids			20	24		1/Month	Grab
Fecal Coliform	See Special Condition 3					1/Month	Grab
Total Residual Chlorine	See Special Condition 4			0.05		1/Month	Grab
			Weekly Avg.	Monthly Avg.	Daily Max		
Ammonia (as N) Mar-May, Sep-Oct Jun-Aug Nov-Feb			6.8 4.5 6.7	2.7 1.8 4.0	15 15 6.7	1/Month	Grab

NPDES Permit No. IL0059625

Special Conditions

SPECIAL CONDITION 1. Flow shall be measured in units of Million Gallons per Day (MGD) and reported as a monthly average and a daily maximum value on the monthly Discharge Monitoring Report.

SPECIAL CONDITION 2. The pH shall be in the range 6.5 to 9.0. The monthly minimum and monthly maximum values shall be reported on the DMR form.

SPECIAL CONDITION 3. The daily maximum fecal coliform count shall not exceed 400 per 100 ml.

SPECIAL CONDITION 4. All samples for total residual chlorine (TRC) shall be analyzed by an applicable method contained in 40 CFR 136, equivalent in accuracy to low-level amperometric titration. Any analytical variability of the method used shall be considered when determining the accuracy and precision of the results obtained.

SPECIAL CONDITION 5. Samples taken in compliance with the effluent monitoring requirements shall be taken at a point representative of the discharge, but prior to entry into the receiving stream.

SPECIAL CONDITION 6. The Permittee shall record monitoring results on Discharge Monitoring Report (DMR) Forms using one such form for each outfall each month.

In the event that an outfall does not discharge during a monthly reporting period, the DMR Form shall be submitted with no discharge indicated.

The Permittee may choose to submit electronic DMRs (eDMRs) instead of mailing paper DMRs to the IEPA. More information, including registration information for the eDMR program, can be obtained on the IEPA website, <http://www.epa.state.il.us/water/edmr/index.html>.

The completed Discharge Monitoring Report forms shall be submitted to IEPA no later than the 15<sup>th</sup> day of the following month, unless otherwise specified by the permitting authority.

Permittees not using eDMRs shall mail Discharge Monitoring Reports with an original signature to the IEPA at the following address:

Illinois Environmental Protection Agency  
Division of Water Pollution Control  
1021 North Grand Avenue East  
Post Office Box 19276  
Springfield, Illinois 62794-9276

Attention: Compliance Assurance Section, Mail Code # 19

SPECIAL CONDITION 7. If an applicable effluent standard or limitation is promulgated under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the Clean Water Act and that effluent standard or limitation is more stringent than any effluent limitation in the permit or controls a pollutant not limited in the NPDES Permit, the Agency shall revise or modify the permit in accordance with the more stringent standard or prohibition and shall so notify the permittee.

SPECIAL CONDITION 8. The use or operation of this facility shall be by or under the supervision of a Certified Class K operator.

