

NPDES Permit No. IL0003191
Notice No. MEL:13100901.mel

Public Notice Beginning Date: **February 24, 2014**

Public Notice Ending Date: **March 26, 2014**

National Pollutant Discharge Elimination System (NPDES)
Permit Program

Draft Modified NPDES Permit to Discharge into Waters of the State

Public Notice/Fact Sheet Issued By:

Illinois Environmental Protection Agency
Bureau of Water
Division of Water Pollution Control
Permit Section
1021 North Grand Avenue East
Post Office Box 19276
Springfield, Illinois 62794-9276
217/782-0610

Name and Address of Discharger:

Pierce Biotechnology
3747 North Meridian Road
Rockford, Illinois 61101

Name and Address of Facility:

Pierce Biotechnology
3747 North Meridian Road
Rockford, Illinois 61101
(Winnebago County)

The Illinois Environmental Protection Agency (IEPA) has made a tentative determination to issue a NPDES permit to discharge into the waters of the state and has prepared a draft permit and associated fact sheet for the above named discharger. The Public Notice period will begin and end on the dates indicated in the heading of this Public Notice/Fact Sheet. The last day comments will be received will be on the Public Notice period ending date unless a commentor demonstrating the need for additional time requests an extension to this comment period and the request is granted by the IEPA. Interested persons are invited to submit written comments on the draft permit to the IEPA at the above address. Commentors shall provide his or her name and address and the nature of the issues proposed to be raised and the evidence proposed to be presented with regards to those issues. Commentors may include a request for public hearing. Persons submitting comments and/or requests for public hearing shall also send a copy of such comments or requests to the permit applicant. The NPDES permit and notice number(s) must appear on each comment page.

The application, engineer's review notes including load limit calculations, Public Notice/Fact Sheet, draft permit, comments received, and other documents are available for inspection and may be copied at the IEPA between 9:30 a.m. and 3:30 p.m. Monday through Friday when scheduled by the interested person.

If written comments or requests indicate a significant degree of public interest in the draft permit, the permitting authority may, at its discretion, hold a public hearing. Public notice will be given 45 days before any public hearing. Response to comments will be provided when the final permit is issued. For further information, please call Mark E. Liska at 217/782-0610.

The applicant is engaged in the production of chemical products in the research and medical fields (SIC 2866). Waste water is generated from the discharge of non-contact cooling water. Plant operation results in an average discharge of 4.59 MGD of non-contact cooling water from outfall 001, 4.59 MGD of non-contact cooling water from outfall 002, and 0.036 MGD of non-contact cooling water from outfall 003.

Modification: Outfall 003 has been added. This outfall consists of 0.036 MGD of non-contact cooling water.

Application is made for the existing discharge(s) which are located in Winnebago County, Illinois. The following information identifies the discharge point, receiving stream and stream classifications:

<u>Outfall</u>	<u>Receiving Stream</u>	<u>Latitude</u>	<u>Longitude</u>	<u>Stream Classification</u>	<u>Integrity Rating</u>
001	Unnamed tributary to North Fork of Kent Creek	42° 18' 45" North	89° 10' 22" West	General Use	Not Rated
002	Unnamed tributary to North Fork of Kent Creek	42° 18' 45" North	89° 10' 22" West	General Use	Not Rated
003	Unnamed tributary to North Fork of Kent Creek	42° 18' 45" North	89° 10' 19" West	General Use	Not Rated

To assist you further in identifying the location of the discharge please see the attached map.

The unnamed stream segment receiving the discharge from outfall(s) 001, 002 and 003 is not on the 2008 or 2010 303(d) list of impaired waters and is not a biologically significant stream.

The discharge(s) from the facility shall be monitored and limited at all times as follows:


Outfall: 001, 002, and 003 – Non-contact Cooling Water (Discharge = 4.59 MGD)

PARAMETER	LOAD LIMITS lbs/day <u>DAF (DMF)</u>			CONCENTRATION <u>LIMITS mg/L</u>		
	30 DAY AVERAGE	DAILY MAXIMUM	REGULATION	30 DAY AVERAGE	DAILY MAXIMUM	REGULATION
Flow						35 IAC 309.146
Temperature						35 IAC 302.211

The following explain the conditions of the proposed permit:

Special Conditions will require monthly DMR reporting and explain the temperature limits.

Outfall 003 consists of a new discharge of non-contact cooling water without additives and is not subject to an antidegradation assessment pursuant to 35 Ill. Adm. Code 302.105(d)(5).



NPDES Permit No. IL0003191

Illinois Environmental Protection Agency

Division of Water Pollution Control

1021 North Grand Avenue East

Post Office Box 19276

Springfield, Illinois 62794-9276

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

Modified (NPDES) Permit

Expiration Date:

Issue Date: December 30, 2011

Effective Date: January 1, 2012

Modification Date:

Name and Address of Permittee:

Pierce Biotechnology
3747 North Meridian Road
Rockford, Illinois 61101

Facility Name and Address:

Pierce Biotechnology
3747 North Meridian Road
Rockford, Illinois 61101
(Winnebago County)

Discharge Number and Name:

001 Non-contact Cooling Water
002 Non-contact Cooling Water
003 Non-contact Cooling Water

Receiving Waters:

Unnamed tributary to North Fork of Kent Creek
Unnamed tributary to North Fork of Kent Creek
Unnamed tributary to North Fork of Kent Creek

In compliance with the provisions of the Illinois Environmental Protection Act, Title 35 of Ill. Adm. Code, Subtitle C and/or Subtitle D, Chapter 1, and the Clean Water Act (CWA), the above-named permittee is hereby authorized to discharge at the above location to the above-named receiving stream in accordance with the standard conditions and attachments herein.

Permittee is not authorized to discharge after the above expiration date. In order to receive authorization to discharge beyond the expiration date, the permittee shall submit the proper application as required by the Illinois Environmental Protection Agency (IEPA) not later than 180 days prior to the expiration date.

Alan Keller, P.E.
Manager, Permit Section
Division of Water Pollution Control

SAK: MEL:13100901.mel

NPDES Permit No. IL0003191

Effluent Limitations and Monitoring

- From the modification date of this permit until the expiration date, the effluent of the following discharge(s) shall be monitored and limited at all times as follows:

Outfall(s): 001 and 002 – Non-contact Cooling Water (Discharge = 0.459 MGD)
 003 – Non-contact Cooling Water (Discharge = 0.036 MGD)

PARAMETER	LOAD LIMITS lbs/day <u>DAF (DMF)</u>		CONCENTRATION <u>LIMITS mg/L</u>		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM		
Flow	See Special Condition 1				Continuous	Measure
Temperature	See Special Condition 2				1/Month	Single Reading

Special Conditions

SPECIAL CONDITION 1. Flow shall be measured in units of Million Gallons per Day (MGD) and reported as a monthly average and a daily maximum on the monthly Discharge Monitoring Report. The permittee shall be required to submit continuous flow monitoring data on the DMR form within 180 days of the issuance of this permit. The permittee may estimate flow data until then.

SPECIAL CONDITION 2. This facility is not allowed any mixing with the receiving stream in order to meet applicable water quality thermal limitations. Therefore, discharge of wastewater from this facility must meet the following thermal limitations prior to discharge into the receiving stream.

- A. The discharge must not exceed the maximum limits in the following table during more than one percent of the hours in the 12 month period ending with any month. Moreover, at no time shall the water temperature of the discharge exceed the maximum limits in the following table by more than 1.7° C (3° F).

	<u>Jan.</u>	<u>Feb.</u>	<u>Mar.</u>	<u>April</u>	<u>May</u>	<u>June</u>	<u>July</u>	<u>Aug.</u>	<u>Sept.</u>	<u>Oct.</u>	<u>Nov.</u>	<u>Dec.</u>
F	60	60	60	90	90	90	90	90	90	90	90	60
C	16	16	16	32	32	32	32	32	32	32	32	16

- B. In addition, the discharge shall not cause abnormal temperature changes that may adversely affect aquatic life unless caused by natural conditions.
- C. The discharge shall not cause the maximum temperature rise above natural temperatures to exceed 2.8° C (5° F).
- D. The monthly maximum value shall be reported on the DMR form.

SPECIAL CONDITION 3. The Permittee shall record monitoring results on Discharge Monitoring Report (DMR) Forms using one such form for each outfall each month.

In the event that an outfall does not discharge during a monthly reporting period, the DMR Form shall be submitted with no discharge indicated.

The Permittee may choose to submit electronic DMRs (NetDMRs) instead of mailing paper DMRs to the IEPA. More information, including registration information for the NetDMR program, can be obtained on the IEPA website, <http://www.epa.state.il.us/water/net-dmr/index.html>.

The completed Discharge Monitoring Report forms shall be submitted to IEPA no later than the 15th day of the following month, unless otherwise specified by the permitting authority.

Permittees not using NetDMRs shall mail Discharge Monitoring Reports with an original signature to the IEPA at the following address:

Illinois Environmental Protection Agency
 Division of Water Pollution Control
 1021 North Grand Avenue East
 Post Office Box 19276
 Springfield, Illinois 62794-9276

Attention: Compliance Assurance Section, Mail Code # 19

SPECIAL CONDITION 4. Samples taken in compliance with the effluent monitoring requirements shall be taken at a point representative of the discharge, but prior to entry into the receiving stream.

SPECIAL CONDITION 5. If an applicable effluent standard or limitation is promulgated under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the Clean Water Act and that effluent standard or limitation is more stringent than any effluent limitation in the permit or controls a pollutant not limited in the NPDES Permit, the Agency shall revise or modify the permit in accordance with the more stringent standard or prohibition and shall so notify the permittee.

SPECIAL CONDITION 6. For the purpose of this permit, the discharge from outfalls 001, 002 and 003 are limited to non-contact cooling water, free from process and other wastewater discharges. In the event that the permittee shall require the use of water treatment additives, the permittee must request a change in this permit in accordance with the Standard Conditions -- Attachment H.