

NPDES Permit No. IL0072460  
Notice No. LRL:08011002.docx

Public Notice Beginning Date: **July 22, 2015**

Public Notice Ending Date: **August 21, 2015**

National Pollutant Discharge Elimination System (NPDES)  
Permit Program

Draft Modified NPDES Permit to Discharge into Waters of the State

Public Notice/Fact Sheet Issued By:

Illinois Environmental Protection Agency  
Bureau of Water  
Division of Water Pollution Control  
Permit Section  
1021 North Grand Avenue East  
Post Office Box 19276  
Springfield, Illinois 62794-9276  
217/782-0610

Name and Address of Discharger:

Gas Recovery Services of Illinois, Inc.  
26 West 570 Schick Road  
Hanover Park, Illinois 60103

Name and Address of Facility:

Mallard Lake Electric  
26 West 570 Schick Road  
Hanover Park, Illinois 60103  
(DuPage County)

The Illinois Environmental Protection Agency (IEPA) has made a tentative determination to issue a NPDES permit to discharge into the waters of the state and has prepared a draft permit and associated fact sheet for the above named discharger. The Public Notice period will begin and end on the dates indicated in the heading of this Public Notice/Fact Sheet. The last day comments will be received will be on the Public Notice period ending date unless a commentor demonstrating the need for additional time requests an extension to this comment period and the request is granted by the IEPA. Interested persons are invited to submit written comments on the draft permit to the IEPA at the above address. Commentors shall provide his or her name and address and the nature of the issues proposed to be raised and the evidence proposed to be presented with regards to those issues. Commentors may include a request for public hearing. Persons submitting comments and/or requests for public hearing shall also send a copy of such comments or requests to the permit applicant. The NPDES permit and notice number(s) must appear on each comment page.

The application, engineer's review notes including load limit calculations, Public Notice/Fact Sheet, draft permit, comments received, and other documents are available for inspection and may be copied at the IEPA between 9:30 a.m. and 3:30 p.m. Monday through Friday when scheduled by the interested person.

If written comments or requests indicate a significant degree of public interest in the draft permit, the permitting authority may, at its discretion, hold a public hearing. Public notice will be given 45 days before any public hearing. Response to comments will be provided when the final permit is issued. For further information, please call Leslie Lowry at 217/782-0610.

The applicant is engaged in the generation of electricity by combustion of landfill gas (SIC 4911). The waste heat from the turbines is used to produce steam for additional electricity generation. Wastewater is generated from treating water for use in the boiler and precipitation which contacts the site. Plant operation results in an average discharge of 0.0154 MGD of dual media filter backwash, water softener regenerant waste, reverse osmosis reject, boiler blowdown, and stormwater from outfall 001.

The following modification is proposed:

The SWPPP was removed from the permit because SIC 4911 is not regulated under 40 CFR 122.26.

Application is made for existing discharge which is located in DuPage County, Illinois. The following information identifies the discharge point, receiving stream and stream classifications:

<u>Outfall</u>	<u>Receiving Stream</u>	<u>Latitude</u>		<u>Longitude</u>		<u>Stream Classification</u>	<u>Integrity Rating</u>
001	Unnamed Tributary to Mallard Lake	41° 57' 30"	North	88° 07' 30"	West	General Use	Not Rated

To assist you further in identifying the location of the discharge please see the attached map.

The stream segment receiving the discharge from outfall 001 is on the draft 2014 303(d) list of impaired waters and is not a biologically significant stream on the 2008 Illinois Department of Natural Resources Publication – *Integrating Multiple Taxa in a Biological Stream Rating System*.

The discharge from the facility shall be monitored and limited at all times as follows:


PARAMETER	LOAD LIMITS lbs/day <u>DAF (DMF)</u>		REGULATION	CONCENTRATION <u>LIMITS mg/l</u>		REGULATION
	30 DAY AVERAGE	DAILY MAXIMUM		30 DAY AVERAGE	DAILY MAXIMUM	
<u>Outfall 001:</u>						
Flow (MGD)						
pH				6.5 – 9 s.u.		35 IAC 302.204
Temperature						35 IAC 302.211
Total Suspended Solids				15	30	35 IAC 304.124
Oil and Grease				15	20	40CFR423.12
Sulfate					1520.9	35 IAC 302.208
Chloride					500	35 IAC 302.208

The following explain the conditions of the proposed permit:

The Special Conditions clarify flow, temperature, pH, discharge monitoring report submission, and monitoring location.



**Gas Recovery Services of Illinois, Inc.**  
**Mallard Lake Electric**  
**NPDES No. IL0072460**





NPDES Permit No. IL0072460

Illinois Environmental Protection Agency

Division of Water Pollution Control

1021 North Grand Avenue East

Post Office Box 19276

Springfield, Illinois 62794-9276

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

Modified (NPDES) Permit

Expiration Date: July 31, 2017

Issue Date: July 18, 2012

Effective Date: August 1, 2012

Modification Date:

Name and Address of Permittee:

Gas Recovery Services of Illinois, Inc.  
26 West 570 Schick Road  
Hanover Park, Illinois 60103

Facility Name and Address:

Mallard Lake Electric  
26 West 570 Schick Road  
Hanover Park, Illinois 60103  
(DuPage County)

Discharge Number and Name:

001 Dual Media Filter Backwash, Water Softener Regenerant  
Waste, RO Reject, Boiler Blowdown, and Stormwater

Receiving Waters:

Unnamed Tributary to Mallard Lake

In compliance with the provisions of the Illinois Environmental Protection Act, Title 35 of Ill. Adm. Code, Subtitle C and/or Subtitle D, Chapter 1, and the Clean Water Act (CWA), the above-named permittee is hereby authorized to discharge at the above location to the above-named receiving stream in accordance with the standard conditions and attachments herein.

Permittee is not authorized to discharge after the above expiration date. In order to receive authorization to discharge beyond the expiration date, the permittee shall submit the proper application as required by the Illinois Environmental Protection Agency (IEPA) not later than 180 days prior to the expiration date.

Alan Keller, P.E.  
Manager, Permit Section  
Division of Water Pollution Control

SAK:LRL:08011002.docx

NPDES Permit No. IL0072460

Effluent Limitations and Monitoring

1. From the modification date of this permit until the expiration date, the effluent of the following discharge shall be monitored and limited at all times as follows:

PARAMETER	LOAD LIMITS lbs/day DAF (DMF)		CONCENTRATION LIMITS mg/l		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM		
<u>Outfall 001</u> – Dual Media Filter Backwash, Water Softener Regenerant Waste, RO Reject, Boiler Blowdown, and Stormwater (DAF = 0.0154 MGD)						
Flow (MGD)	See Special Condition 1.				1/Month	Measure
pH	See Special Condition 2.				1/Month	Grab
Temperature	See Special Condition 3.				1/Month	Single Reading
Total Suspended Solids			15	30	1/Month	Grab
Oil and Grease			15	20	1/Month	Grab
Sulfate				1520.9	1/Month	Grab
Chloride				500	1/Month	Grab

NPDES Permit No. IL0072460

Special Conditions

SPECIAL CONDITION 1. Flow shall be measured in units of Million Gallons per Day (MGD) and reported as a monthly average and a daily maximum on the Discharge Monitoring Report.

SPECIAL CONDITION 2. The pH shall be in the range 6.5 to 9.0. The monthly minimum and monthly maximum values shall be reported on the DMR form.

SPECIAL CONDITION 3. This facility is not allowed any mixing with the receiving stream in order to meet applicable water quality thermal limitations. Therefore, discharge of wastewater from this facility must meet the following thermal limitations prior to discharge into the receiving stream.

A. The discharge must not exceed the maximum limits in the following table during more than one percent of the hours in the 12 month period ending with any month. Moreover, at no time shall the water temperature of the discharge exceed the maximum limits in the following table by more than 1.7° C (3° F).

	<u>Jan.</u>	<u>Feb.</u>	<u>Mar.</u>	<u>April</u>	<u>May</u>	<u>June</u>	<u>July</u>	<u>Aug.</u>	<u>Sept.</u>	<u>Oct.</u>	<u>Nov.</u>	<u>Dec.</u>
°F	60	60	60	90	90	90	90	90	90	90	90	60
°C	16	16	16	32	32	32	32	32	32	32	32	16

B. In addition, the discharge shall not cause abnormal temperature changes that may adversely affect aquatic life unless caused by natural conditions.

C. The discharge shall not cause the maximum temperature rise above natural temperatures to exceed 2.8° C (5° F).

D. The monthly maximum value shall be reported on the DMR form.

SPECIAL CONDITION 4. Samples taken in compliance with the effluent monitoring requirements shall be taken at a point representative of the discharge but prior to entry into the receiving stream.

SPECIAL CONDITION 5. The Permittee shall record monitoring results on Discharge Monitoring Report (DMR) Forms using one such form for each outfall each month.

In the event that an outfall does not discharge during a monthly reporting period, the DMR Form shall be submitted with no discharge indicated.

The Permittee may choose to submit electronic DMRs (NetDMRs) instead of mailing paper DMRs to the IEPA. More information, including registration information for the NetDMR program, can be obtained on the IEPA website, <http://www.epa.state.il.us/water/net-dmr/index.html>.

The completed Discharge Monitoring Report forms shall be submitted to IEPA no later than the 15th day of the following month, unless otherwise specified by the permitting authority.

Permittees not using NetDMRs shall mail Discharge Monitoring Reports with an original signature to the IEPA at the following address:

Illinois Environmental Protection Agency  
 Division of Water Pollution Control  
 1021 North Grand Avenue East  
 Post Office Box 19276  
 Springfield, Illinois 62794-9276

Attention: Compliance Assurance Section, Mail Code # 19

SPECIAL CONDITION 6. If an applicable effluent standard or limitation is promulgated under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the Clean Water Act and that effluent standard or limitation is more stringent than any effluent limitation in the permit or controls a pollutant not limited in the NPDES Permit, the Agency shall revise or modify the permit in accordance with the more stringent standard or prohibition and shall so notify the permittee.

SPECIAL CONDITION 7. In the event the permittee shall require the use of water treatment additives, the permittee must request a change in the permit in accordance with Standard Conditions - Attachment H.

Special Conditions

SPECIAL CONDITION 8. The effluent, alone or in combination with other sources, shall not cause a violation of any applicable water quality standard outlined in 35 Ill. Adm. Code 302.