

NPDES Permit No. IL0066818
Notice No. FRB:14110701.bah

Public Notice Beginning Date: **March 13, 2015**

Public Notice Ending Date: **April 13, 2015**

National Pollutant Discharge Elimination System (NPDES)
Permit Program

PUBLIC NOTICE/FACT SHEET
of
Draft Reissued NPDES Permit to Discharge into Waters of the State

Public Notice/Fact Sheet Issued By:

Illinois EPA
Division of Water Pollution Control
Permit Section
1021 North Grand Avenue East
Post Office Box 19276
Springfield, Illinois 62794-9276
217/782-0610

Name and Address of Discharger:

Village of Hinsdale
19 East Chicago Avenue
Hinsdale, Illinois 60521

Name and Address of Facility:

Combined Sewer Overflows
Hinsdale, Illinois
(DuPage County)

The Illinois Environmental Protection Agency (IEPA) has made a tentative determination to issue a NPDES Permit to discharge into the waters of the state and has prepared a draft Permit and associated fact sheet for the above named discharger. The Public Notice period will begin and end on the dates indicated in the heading of this Public Notice/Fact Sheet. All comments on the draft Permit and requests for hearing must be received by the IEPA by U.S. Mail, carrier mail or hand delivered by the Public Notice Ending Date. Interested persons are invited to submit written comments on the draft Permit to the IEPA at the above address. Commentors shall provide his or her name and address and the nature of the issues proposed to be raised and the evidence proposed to be presented with regards to those issues. Commentors may include a request for public hearing. Persons submitting comments and/or requests for public hearing shall also send a copy of such comments or requests to the Permit applicant. The NPDES Permit and notice numbers must appear on each comment page.

The application, engineer's review notes including load limit calculations, Public Notice/Fact Sheet, draft Permit, comments received, and other documents are available for inspection and may be copied at the IEPA between 9:30 a.m. and 3:30 p.m. Monday through Friday when scheduled by the interested person.

If written comments or requests indicates a significant degree of public interest in the draft Permit, the permitting authority may, at its discretion, hold a public hearing. Public notice will be given 45 days before any public hearing. Response to comments will be provided when the final Permit is issued. For further information, please call Francis Burba at 217/782-0610.

The following water quality and effluent standards and limitations were applied to the discharge:

Title 35: Environmental Protection, Subtitle C: Water Pollution, Chapter I: Pollution Control Board and the Clean Water Act were applied in determining the applicable standards, limitations and conditions contained in the draft Permit.

The length of the Permit is approximately 5 years.

The main discharge numbers are 001, 002, 006 and 007. The seven day once in ten year low flow (7Q10) of the receiving stream, Flag Creek, is 0 cfs.

Pursuant to the waiver provisions authorized by 40 CFR § 123.24, this draft permit is within the class, type, and size for which the Regional Administrator, Region V, has waived his right to review, object, or comment on this draft permit action.

Application is made for the existing discharge(s) which is (are) located in DuPage County, Illinois. The following information identifies the discharge point, receiving stream and stream classifications:

Outfall	Receiving Stream	Latitude	Longitude	Stream Classification	Biological Stream Characterization
001	Flag Creek	41° 48' 22" North	87° 55' 15" West	General Use	D
002	Flag Creek	41° 48' 09" North	87° 55' 55" West	General Use	D
006	Flag Creek	41° 48' 21" North	87° 54' 45" West	General Use	D
007	Flag Creek	41° 48' 01" North	87° 54' 50" West	General Use	D

This permit authorizes discharge from 4 CSOs in accordance with 35 Ill. Adm. Code 306.305. The Long Term Control Plan (LTCP) was submitted in June 2009 with additional information received March 1, 2010 and April 13, 2010. The LTCP was approved March 19, 2012. The LTCP, once implemented, is presumed to result in no more than four overflow events in a typical year. Construction will include sewer separation projects throughout the collection system. The LTCP construction will be completed by December 31, 2021. Upon completion of construction, post-construction monitoring will be required to verify that water quality standards are met.

To assist you further in identifying the location of the discharge(s) please see the attached map.

The stream segment(s) (Waterbody Segment GK-03) receiving the discharge from outfall(s) 001, 002, 006 and 007 is on the 303 (d) list of impaired waters.

The following parameters have been identified as the pollutants causing impairment:

Potential Causes	Uses Impaired
Alterations in stream-side or littoral vegetative cover (non-pollutant), aquatic algae (non-pollutant), arsenic, DDT, hexachlorobenzene, methoxychlor, and phosphorus	Aquatic life


This Permit contains an authorization to treat and discharge excess flow as follows:

Discharge Number(s) and Name(s); 006 Veeck Park Treated Combined Sewage Outfall

Parameter	CONCENTRATION LIMITS (mg/L)		Regulation
	Monthly Average		
BOD ₅	Report		40 CFR 133.102
Suspended Solids	Report		40 CFR 133.102
Fecal Coliform	Daily Maximum Shall Not Exceed 400 per 100 mL		35 IAC 304.121
pH	Shall be in the range of 6 to 9 Standard Units		35 IAC 304.125
Chlorine Residual	0.75		35 IAC 302.208
Total Phosphorus (as P)	Report		35 IAC 309.146

This draft Permit also contains the following requirements as special conditions:

1. Reopening of this Permit to include different final effluent limitations.
2. Submission of the operational data in a specified form and at a required frequency at any time during the effective term of this Permit.
3. Prohibition against causing or contributing to violations of water quality standards.
4. An authorization of combined sewer discharges.
5. Recording the monitoring results on Discharge Monitoring Report Forms using one such form for each outfall each month and submitting the forms to IEPA each month.
6. Capacity, Management, Operations and Maintenance (CMOM) requirements.
7. Submission of annual fiscal data.
8. Operation of the facility by or under the supervision of a certified operator.



NPDES Permit No. IL0066818

Illinois Environmental Protection Agency

Division of Water Pollution Control

1021 North Grand Avenue East

Post Office Box 19276

Springfield, Illinois 62794-9276

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

Draft (NPDES) Permit

Expiration Date:

Issue Date:

Effective Date:

Name and Address of Discharger:

Name and Address of Facility:

Village of Hinsdale
19 East Chicago Avenue
Hinsdale, Illinois 60521

Combined Sewer Overflows
Hinsdale, Illinois
(DuPage County)

Receiving Waters: Flag Creek

In compliance with the provisions of the Illinois Environmental Protection Act, Title 35 of the Ill. Adm. Code, Subtitle C, Chapter I, and the Clean Water Act (CWA), the above-named Permittee is hereby authorized to discharge at the above location to the above-named receiving stream in accordance with the standard conditions and attachments herein.

Permittee is not authorized to discharge after the above expiration date. In order to receive authorization to discharge beyond the expiration date, the Permittee shall submit the proper application as required by the Illinois Environmental Protection Agency (IEPA) not later than 180 days prior to the expiration date.

Alan Keller, P.E.
Manager, Permit Section
Division of Water Pollution Control

SAK:FRB:14110701.BAH

Effluent Limitations, Monitoring, and Reporting

FINAL

Discharge Number(s) and Name(s): 006 Veeck Park Treated Combined Sewage Outfall

From the effective date of this Permit until the expiration date, the effluent of the above discharge(s) shall be monitored and limited at all times as follows:

Parameter			CONCENTRATION	Sample Frequency	Sample Type
			<u>LIMITS mg/L</u>		
			Monthly Average		
Total Flow (MG)	See Below		Report	Daily When Discharging	Continuous
BOD ₅			Report	Daily When Discharging	Grab
Suspended Solids			Report	Daily When Discharging	Grab
Fecal Coliform	Daily Maximum Shall Not Exceed 400 per 100 mL			Daily When Discharging	Grab
pH	Shall be in the range of 6 to 9 Standard Units			Daily When Discharging	Grab
Chlorine Residual			0.75	Daily When Discharging	Grab
Total Phosphorus (as P)			Report	Daily When Discharging	Grab

Total flow in million gallons shall be reported on the Discharge Monitoring Report (DMR) in the quantity maximum column.

Report the number of days of discharge in the comments section of the DMR.

Fecal Coliform shall be reported on the DMR as daily maximum.

Chlorine Residual shall be reported on the DMR as a monthly average concentration.

pH shall be reported on the DMR as a minimum and a maximum.

BOD₅ and Suspended Solids shall be reported on the DMR as a monthly average concentration.

Total Phosphorus shall be reported on the DMR as a maximum value.

Special Conditions

SPECIAL CONDITION 1. This Permit may be modified to include different final effluent limitations or requirements which are consistent with applicable laws and regulations. The IEPA will public notice the permit modification.

SPECIAL CONDITION 2. The IEPA may request in writing submittal of operational information in a specified form and at a required frequency at any time during the effective period of this permit.

SPECIAL CONDITION 3. The effluent, alone or in combination with other sources, shall not cause or contribute to a violation of any applicable water quality standard outlined in 35 Ill. Adm. Code 302 and 303.

SPECIAL CONDITION 4.

AUTHORIZATION OF
COMBINED SEWER AND TREATMENT PLANT DISCHARGES

The IEPA has determined that at least a portion of the collection system consists of combined sewers. References to the collection system and the sewer system refer only to those parts of the system which are owned and operated by the Permittee unless otherwise indicated. The Permittee is authorized to discharge from the overflow(s)/bypass(es) listed below provided the diversion structure is located on a combined sewer and the following terms and conditions are met:

<u>Discharge Number</u>	<u>Location</u>	<u>Receiving Water</u>
001	Walnut Street	Flag Creek
002	Chestnut Street & Grant Street	Flag Creek
007	3 rd & Princeton Street	Flag Creek

A. CSO Monitoring, Reporting and Notification Requirements

- The Permittee shall monitor the frequency of discharge (number of discharges per month) and estimate the duration (in hours) of each discharge from each outfall listed in this Special Condition. Estimates of storm duration and total rainfall shall be provided for each storm event.

<u>Start Date</u>	<u>Rainfall Duration (hrs.)</u>	<u>Rainfall Amount (in.)</u>	<u>CSO Outfall #</u>	<u>Outfall Description</u>	<u>Estimated Duration of CSO Discharge (hrs.)</u>	<u>Estimated Volume of CSO Discharge (MG)</u>

For frequency reporting, all discharges from the same storm, or occurring within 24 hours, shall be reported as one. The date that a discharge commences shall be recorded for each outfall. Reports shall be in the form specified by the IEPA and on forms provided by the IEPA (e.g., Form IL 532-2471, or updated form of same). These forms shall be submitted to the IEPA monthly with the DMRs and covering the same reporting period as the DMRs. Parameters (other than flow frequency and volume), if required in this Permit, shall be sampled and reported as indicated in the transmittal letter for such report forms.

- All Submittals listed in this Special Condition can be mailed to the following address:

Illinois Environmental Protection Agency
Division of Water Pollution Control
1021 North Grand Avenue East
Post Office Box 19276
Springfield, Illinois 62794-9276
Attention: CSO Coordinator, Compliance Assurance Section

All submittals hand carried shall be delivered to 1021 North Grand Avenue East.

B. CSO Treatment Requirements

- All combined sewer overflows shall be given sufficient treatment to prevent pollution and the violation of applicable water quality standards and to the extent required by the federal Clean Water Act, the 1994 CSO Control Policy including any amendments made by the Wet Weather Water Quality Act of 2000. Sufficient treatment consists of the following:

All dry weather flows, the first flush of storm flows, and additional flows, but not less than ten times the average dry weather flow for the design year, shall be conveyed to the Flagg Creek Sanitary District WWTP for treatment and MWRDGC – Stickney WWTP for treatment.

- All CSO discharges authorized by this Permit shall be treated, in whole or in part, to the extent necessary to prevent accumulations

Special Conditions

of sludge deposits, floating debris and solids in accordance with 35 Ill. Adm. Code 302.203 and to prevent depression of oxygen levels below the applicable water quality standards.

5. Overflows during dry weather are prohibited. Dry weather overflows shall be reported to the IEPA pursuant to Standard Condition 12(f) of this Permit (24 hour notice).
6. The collection system shall be operated to optimize transport of wastewater flows and to minimize CSO discharges and the treatment system, if applicable, shall be operated to maximize treatment of wastewater flows.

C. CSO Nine Minimum Controls

7. The Permittee shall comply with the nine minimum controls contained in the National CSO Control Policy published in the Federal Register on April 19, 1994. The nine minimum controls are:
 - a. Proper operation and maintenance programs for the sewer system and the CSOs;
 - b. Maximum use of the collection system for storage;
 - c. Review and modification of pretreatment requirements to assure CSO impacts are minimized;
 - d. Maximization of flow to the POTW for treatment;
 - e. Prohibition of CSOs during dry weather;
 - f. Control of solids and floatable materials in CSOs;
 - g. Pollution prevention programs which focus on source control activities;
 - h. Public notification to ensure that citizens receive adequate information regarding CSO occurrences and CSO impacts; and,
 - i. Monitoring to characterize impacts and efficiency of CSO controls.

A CSO pollution prevention plan (PPP) shall be developed by the Permittee unless one has already been prepared for this collection system. Any previously-prepared PPP shall be reviewed, and revised if necessary, by the Permittee to address the items contained in Chapter 8 of the U.S. EPA guidance document, Combined Sewer Overflows, Guidance For Nine Minimum Controls, and any items contained in previously-sent review documents from the IEPA concerning the PPP. Combined Sewer Overflows, Guidance For Nine Minimum Controls is available on line at <http://www.epa.gov/npdes/pubs/owm0030.pdf>. The PPP (or revised PPP) shall be presented to the general public at a public information meeting conducted by the Permittee annually during the term of the effective date of this Permit. The Permittee shall submit documentation that the pollution prevention plan complies with the requirements of this Permit and that the public information meeting was held. Such documentation shall be submitted to the IEPA within twelve (12) months of the effective date of this Permit and shall include a summary of all significant issues raised by the public, the Permittee's response to each issue, and two (2) copies of the "CSO Pollution Prevention Plan Certification" one (1) with original signatures. This certification form is available online at <http://www.epa.state.il.us/water/permits/waste-water/forms/cso-pol-prev.pdf>. Following the public meeting, the Permittee shall implement the pollution prevention plan and shall maintain a current pollution prevention plan, updated to reflect system modifications, on file at the sewage treatment works or other acceptable location and made available to the public. The pollution prevention plan revisions shall be submitted to the IEPA one (1) month from the revision date. The most recent Pollution Prevention Plan was dated July 2008.

D. Sensitive Area Considerations

8. Pursuant to Section II.C.3 of the federal CSO Control Policy of 1994, sensitive areas are any water likely to be impacted by a CSO discharge which include one or more of the following criteria: (1) designated as an Outstanding National Resource Water; (2) found to contain shellfish beds; (3) found to contain threatened or endangered aquatic species or their habitat; (4) used for primary contact recreation; (5) National Marine Sanctuaries; or, (6) within the protection area for a drinking water intake structure.

The IEPA has tentatively determined that none of the outfalls listed in this Special Condition discharge to sensitive areas. However, if information becomes available that causes the IEPA to reverse this determination, the IEPA will notify the Permittee in writing. Upon the date contained in the notification letter, the Permittee shall revise the LTCP and schedule to eliminate or relocate these outfalls. If elimination or relocation is not economically feasible or technically achievable the Permittee shall submit a revised plan and schedule for treating the discharge. Such justification shall be in accordance with Section II.C.3 of the National CSO Control Policy.

Special ConditionsE. CSO Operational and Maintenance Plans

9. The IEPA received a CSO operational and maintenance plan "CSO O&M plan" on July 16, 2008 prepared for this sewerage system. The Permittee shall fully implement the plan and review and revise, if needed, the CSO O&M plan to reflect system changes.

The CSO O&M plan shall be presented to the general public at a public information meeting conducted by the Permittee within nine (9) months of the effective date of this Permit or within nine (9) months of the CSO system being modified. The Permittee shall submit documentation that the CSO O&M plan complies with the requirements of this Permit and that the public information meeting was held. Such documentation shall be submitted to the IEPA within twelve (12) months of the effective date of this Permit and shall include a summary of all significant issues raised by the public, the Permittee's response to each issue, and two (2) copies of the "CSO Operational Plan Checklist and Certification", one (1) with original signatures. Copies of the "CSO Operational Plan Checklist and Certification" are available online at <http://www.epa.state.il.us/water/permits/waste-water/forms/cso-checklist.pdf>. Following the public meeting, the Permittee shall maintain a current CSO O&M plan, updated to reflect system modifications, on file at the sewage treatment works and made available to the public. The CSO O&M plan revisions shall be submitted to the IEPA one (1) month from the revision date.

The objectives of the CSO O&M plan are to reduce the total loading of pollutants and floatables entering the receiving stream and to ensure that the Permittee ultimately achieves compliance with water quality standards. These plans, tailored to the local government's collection and waste treatment systems, shall include mechanisms and specific procedures where applicable to ensure:

- a. Collection system inspection on a scheduled basis;
- b. Sewer, catch basin, and regulator cleaning and maintenance on a scheduled basis;
- c. Inspections are made and preventive maintenance is performed on all pump/lift stations;
- d. Collection system replacement, where necessary;
- e. Detection and elimination of illegal connections;
- f. Detection, prevention, and elimination of dry weather overflows;
- g. The collection system is operated to maximize storage capacity and the combined sewer portions of the collection system are operated to delay storm entry into the system; and,
- h. The treatment and collection systems are operated to maximize treatment.

F. Sewer Use Ordinances

10. The Permittee, within six (6) months of the effective date of this Permit, shall review and where necessary, modify its existing sewer use ordinance to ensure it contains provisions addressing the conditions below. If no ordinance exists, such ordinance shall be developed, adopted, and implemented within six (6) months from the effective date of this Permit. Upon completion of the review of the sewer use ordinance(s), the Permittee shall submit two (2) copies of a completed "Certification of Sewer Use Ordinance Review", one (1) copy with original signatures. Copies of the certification form can be obtained on line at <http://www.epa.state.il.us/water/permits/waste-water/forms/sewer-use.pdf>. The Permittee shall submit additional copies of the sewer use ordinance(s) to the IEPA upon written request. Sewer use ordinances must contain specific provisions to:

- a. Prohibit introduction of new inflow sources to the sanitary sewer system;
- b. Require that new sanitary sewer construction tributary to the combined sewer system be designed to minimize and/or delay inflow contribution to the combined sewer system;
- c. Require that inflow sources on the combined sewer system be connected to a storm sewer, in accordance with any approved Long Term Control Plan;
- d. Provide that any new building domestic sewage connection shall be distinct from the building inflow connection;
- e. Assure that CSO impacts from industrial and/or commercial sources are minimized and control by determining which industrial and/or commercial discharges, are tributary to CSOs; and,
- f. Assure that the owners of all publicly owned systems with sewers tributary to the Permittee's collection system have procedures in place adequate to ensure that the objectives, mechanisms, and specific procedures given in Paragraph 9

Special Conditions

of this Special Condition are achieved.

The Permittee shall enforce the applicable sewer use ordinances.

G. CSO Long-Term Control Planning and Compliance with Water Quality Standards

11. a. Pursuant to Section 301 of the federal Clean Water Act, 33 U.S.C. § 1311 and 40 CFR § 122.4, discharges from the CSOs, including the outfalls listed in this Special Condition and any other outfall listed as a "Treated Combined Sewage Outfall", shall not cause or contribute to violations of applicable water quality standards or cause use impairment in the receiving waters. In addition, discharges from CSOs shall comply with all applicable parts of 35 Ill. Adm. Code 306.305(a), (b), (c), and (d).
- b. This is a Phase II Permit under USEPA's 1994 CSO Policy requiring implementation of the LTCP submitted by the permittee to IEPA June 2009, with additional information dated March 1, 2010 and April 13, 2010. The implementation schedule can be found under the Additional Action Items and Required Reporting of this Special Condition (Item 14b). The LTCP construction and operational implementation shall be completed by December 31, 2021. All provisions of this Special Condition shall stay in effect prior to and after completion of construction. Project reports shall be submitted to the Agency six (6) months from the effective date of this Permit and every six (6) months thereafter.
- c. Flag Creek was monitored upstream and downstream of the outfalls during CSO overflow events and on days when there were no CSO events in 2012, 2013 and 2014, and the water quality downstream of the CSOs was similar to the upstream quality. Upon completion of construction, post-construction monitoring shall be implemented for a twenty-four (24) month period. Within thirty (30) months of completion of construction, the results shall be submitted to the IEPA along with recommendations and conclusions as to whether or not the discharges from any of the CSOs (treated or untreated) authorized by this permit are causing or contributing to violations of applicable water quality standards or causing use impairment in the receiving water(s).
- d. Should the results of the post-construction water quality monitoring plan or if information becomes available that causes IEPA to conclude that the discharges from any of the CSOs (treated or untreated) authorized to discharge under this Permit are causing or contributing to violations of water quality standards or are causing use impairment in the receiving water(s), the IEPA will notify the Permittee in writing. Upon receiving such notification, the Permittee shall develop and implement a revised CSO Long-Term Control Plan (LTCP) for assuring that the discharges from the CSOs (treated or untreated) authorized in this Permit comply with the provisions of Paragraph 11.a above. The revised LTCP shall contain all applicable elements of Paragraph 11.e below including a schedule for implementation and provisions for re-evaluating compliance with applicable standards and regulations after complete implementation. Three (3) copies of the revised LTCP shall be submitted to the IEPA within twelve (12) months of receiving the IEPA written notice. The LTCP shall be:
1. Consistent with Section II.C.4.a.i of the Policy; or,
 2. Consistent with either Section II.C.4.a.ii, Section II.C.4.a.iii, or Section II.C.4.b of the Policy and be accompanied by data sufficient to demonstrate that the LTCP, when completely implemented, will be sufficient to meet water quality standards.
- e. Pursuant to the Policy, the required components of the LTCP include the following:
1. Characterization, monitoring, and modeling of the Combined Sewer System (CSS);
 2. Consideration of Sensitive Areas;
 3. Evaluation of alternatives;
 4. Cost/Performance considerations;
 5. Revised CSO Operational Plan;
 6. Maximizing treatment at the treatment plant;
 7. Implementation schedule;
 8. Post-Construction compliance monitoring program; and
 9. Public participation.

Following submittal of the revised LTCP, the Permittee shall respond to any initial IEPA review letter in writing within ninety (90) days of the date of such a review letter, and within thirty (30) days of any subsequent review letter(s), if any. Implementation of the revised LTCP shall be as indicated by IEPA in writing or other enforceable mechanism.

12. A public notification program in accordance with Section II.B.8 of the federal CSO Control Policy of 1994 shall be developed employing a process that actively informs the affected public. The program shall include at a minimum public notification of CSO occurrences and CSO impacts, with consideration given to including mass media and/or Internet notification. The Permittee shall post and maintain signs in waters likely to be impacted by CSO discharges at the point of discharge and at points where these waters are used for primary contact recreation. Signage's message should be visible from both shoreline and water vessel approach (if appropriate), respectively. Provisions shall be made to include modifications of the program when necessary and

Special Conditions

notification to any additional member of the affected public. The program shall be presented to the general public at a public information meeting conducted by the Permittee. The Permittee shall conduct the public information meeting providing a summary and status of the CSO control program annually during the term of this Permit. The Permittee shall submit documentation that the public information meeting was held, shall submit a summary of all significant issues raised by the public and the Permittee's response to each issue and shall identify any modifications to the program as a result of the public information meeting within 60 days of holding the public meeting. The Permittee shall submit copies of the public notification program to the IEPA upon written request.

13. If any of the CSO discharge points listed in this permit are eliminated, or if additional CSO discharge points, not listed in this permit, are discovered, the Permittee shall notify the IEPA in writing within one (1) month of the respective outfall elimination or discovery. Such notification shall be in the form of a request for the appropriate modification of this NPDES Permit.

H. Summary of Compliance Dates in this CSO Special Condition

14.

- a. The following summarizes the dates that submittals contained in this Special Condition are due at the IEPA (unless otherwise indicated):

Submission of CSO Monitoring Data (Paragraph 1)	25th of every month
Submission of Revised CSO O&M Plan (Paragraph 9)	1 month from revision date
Elimination of a CSO or Discovery of Additional CSO Locations (Paragraph 13)	1 month from discovery or elimination
Control (or Justification for No Control) of CSOs to Sensitive Areas (Paragraph 8)	Upon date contained in IEPA notification letter
Certification of Sewer Use Ordinance Review (Paragraph 10)	6 months from the effective date of this Permit
Conduct Pollution Prevention, and PN Public Information meeting (Paragraphs 7 and 12)	Annually
No Submittal Due with this Milestone	
Conduct OMP Public Information Meeting (Paragraph 9)	9 months from the effective date of this Permit
No Submittal Due with this Milestone	
Submit Pollution Prevention Certification and OMP Certification (Paragraphs 7 and 9)	12 months from the effective date of this Permit
Submit PN Information Meeting Summary (Paragraph 12)	60 days after the public meeting
CSO Long Term Control Plan (Paragraph 10)	
Complete LTCP Construction and Implement Full Operation	December 31, 2021

- b. Additional Action Items and Required Reporting

Progress Reports	6 months from the effective date of this Permit and every six months thereafter
Sewer Separation Projects:	
Vine Street (from North to Center)	December 31, 2017 Construction Complete
The Lane (from Walker to Elm)	December 31, 2019 Construction Complete
Bodin Street (from Seventh to Eighth)	December 31, 2020 Construction Complete
Bruner Street (from Sixth to Eighth)	December 31, 2020 Construction Complete
Grant Street (From Eighth to Ninth)	December 31, 2020 Construction Complete

Special Conditions

Elm Street (from Fourth to Sixth)	December 31, 2021 Construction Complete
Fifth Street (from Garfield to Park)	December 31, 2021 Construction Complete
Park Street (from Sixth to Seventh)	December 31, 2021 Construction Complete
Sixth Street (from Garfield to Oak)	December 31, 2021 Construction Complete
Blain Street (from Chicago to First)	December 31, 2021 Construction Complete
Chicago Avenue (from Garfield to Park)	December 31, 2021 Construction Complete
Park Street (from Chicago to First)	December 31, 2021 Construction Complete
Submit Results of Post-Construction Monitoring Plan (Paragraph 11)	30 months after completion of construction

All submittals listed in this Special Condition can be mailed to the following address:

Illinois Environmental Protection Agency
Division of Water Pollution Control
1021 North Grand Avenue East
Post Office Box 19276
Springfield, Illinois 62794-9276

Attention: CSO Coordinator, Compliance Assurance Section

All submittals hand carried shall be delivered to 1021 North Grand Avenue East.

I. Reopening and Modifying this Permit

15. The IEPA may initiate a modification for this Permit at any time to include requirements and compliance dates which have been submitted in writing by the Permittee and approved by the IEPA, or other requirements and dates which are necessary to carry out the provisions of the Illinois Environmental Protection Act, the Clean Water Act, or regulations promulgated under those Acts. Public Notice of such modifications and opportunity for public hearing shall be provided.

SPECIAL CONDITION 5. The Permittee shall record monitoring results on Discharge Monitoring Report (DMR) Forms using one such form for each outfall each month.

In the event that an outfall does not discharge during a monthly reporting period, the DMR Form shall be submitted with no discharge indicated.

The Permittee may choose to submit electronic DMRs (NetDMRs) instead of mailing paper DMRs to the IEPA. More information, including registration information for the NetDMR program, can be obtained on the IEPA website, <http://www.epa.state.il.us/water/net-dmr/index.html>.

The completed Discharge Monitoring Report forms shall be submitted to IEPA no later than the 25th day of the following month, unless otherwise specified by the permitting authority.

Permittees not using NetDMRs shall mail Discharge Monitoring Reports with an original signature to the IEPA at the following address:

Illinois Environmental Protection Agency
Division of Water Pollution Control
Attention: Compliance Assurance Section, Mail Code # 19
1021 North Grand Avenue East
Post Office Box 19276
Springfield, Illinois 62794-9276

SPECIAL CONDITION 6. The Permittee shall work towards the goals of achieving no discharges from sanitary sewer overflows or basement back-ups and ensuring that overflows or back-ups, when they do occur do not cause or contribute to violations of applicable standards or cause impairment in any adjacent receiving water. Overflows from sanitary sewers are expressly prohibited by Ill. Adm. Code 306.304. In order to accomplish these goals, the Permittee shall develop, implement and submit to the IEPA a Capacity, Management, Operations, and Maintenance (CMOM) plan which includes an Asset Management strategy within twelve (12) months of the effective date of this Permit or review and revise any existing plan accordingly. The permittee shall modify the Plan to incorporate any comments that it

Special Conditions

receives from IEPA and shall implement the modified plan as soon as possible. The Permittee should work as appropriate, in consultation with affected authorities at the local, county, and/or state level to develop the plan components involving third party notification of overflow events. The Permittee may be required to construct additional sewage transport and/or treatment facilities in future permits or other enforceable documents should the implemented CMOM plan indicate that the Permittee's facilities are not capable of conveying and treating the flow for which they were designed.

The CMOM plan shall include the following elements:

A. Measures and Activities:

1. A complete map and system inventory for the collection system owned and operated by the Permittee;
2. Organizational structure; budgeting; training of personnel; legal authorities; schedules for maintenance, sewer system cleaning, and preventative rehabilitation; checklists, and mechanisms to ensure that preventative maintenance is performed on equipment owned and operated by the Permittee;
3. Documentation of unplanned maintenance;
4. An assessment of the capacity of the collection and treatment system owned and operated by the Permittee at critical junctions and immediately upstream of locations where overflows and back-ups occur or are likely to occur; use flow monitoring as necessary;
5. Identification and prioritization of structural deficiencies in the system owned and operated by the Permittee;
6. Scheduled inspections and testing;
7. The Permittee shall develop and implement an Asset Management strategy to ensure the long-term sustainability of the collection system. Asset management shall be used to assist the Permittee in making decisions on when it is most appropriate to repair, replace or rehabilitate particular assets and develop long-term funding strategies; and
8. Asset management shall include but is not limited to the following elements:
 - a. Asset Inventory and State of the Asset;
 - b. Level of Service;
 - c. Critical Asset Identification;
 - d. Life Cycle Cost; and
 - e. Long-Term Funding Strategy.

B. Design and Performance Provisions:

1. Monitor the effectiveness of CMOM;
2. Upgrade the elements of the CMOM plan as necessary; and
3. Maintain a summary of CMOM activities.

C. Overflow Response Plan:

1. Know where overflows and back-ups within the facilities owned and operated by the Permittee occur;
2. Respond to each overflow or back-up to determine additional actions such as clean up; and
3. Locations where basement back-ups and/or sanitary sewer overflows occur shall be evaluated as soon as practicable for excessive inflow /infiltration, obstructions or other causes of overflows or back-ups as set forth in the System Evaluation Plan.

D. System Evaluation Plan:

1. Summary of existing SSO and Excessive I/I areas in the system and sources of contribution;
2. Evaluate plans to reduce I/I and eliminate SSOs;
3. Special provisions for Pump Stations and force mains and other unique system components; and
4. Construction plans and schedules for correction.

E. Reporting and Monitoring Requirements:

1. Program for SSO detection and reporting; and
2. Program for tracking and reporting basement back-ups, including general public complaints.

F. Third Party Notice Plan:

1. Describes how, under various overflow scenarios, the public, as well as other entities, would be notified of overflows within the Permittee's system that may endanger public health, safety or welfare;
2. Identifies overflows within the Permittee's system that would be reported, giving consideration to various types of events including events with potential widespread impacts;
3. Identifies who shall receive the notification;
4. Identifies the specific information that would be reported including actions that will be taken to respond to the overflow;

Special Conditions

5. Includes a description of the lines of communication; and
6. Includes the identities and contact information of responsible POTW officials and local, county, and/or state level officials.

For additional information concerning USEPA CMOM guidance and Asset Management please refer to the following web site addresses.

http://www.epa.gov/npdes/pubs/cmom_guide_for_collection_systems.pdf and

http://water.epa.gov/type/watersheds/wastewater/upload/guide_smallsystems_assetmanagement_bestpractices.pdf

SPECIAL CONDITION 7. During January of each year the Permittee shall submit annual fiscal data regarding sewerage system operations to the Illinois Environmental Protection Agency/Division of Water Pollution Control/Compliance Assurance Section. The Permittee may use any fiscal year period provided the period ends within twelve (12) months of the submission date.

Submission shall be on forms provided by IEPA titled "Fiscal Report Form For NPDES Permittees".

SPECIAL CONDITION 8. The use or operation of the treatment facility shall be by or under the supervision of a Certified Class 3 operator.

