

	DATES			Lead	Copper	Iron						Manganese						Coliform	
Reporting Limit				5 ug/L	50 ug/L	50.0 ug/L						15.0 ug/L							
Action Level or State MCL				15 ug/L	1300 ug/L	1000 ug/L						150 ug/L							
ROUND	Round 1	Round 2	Round 3	Round 1	Round 1	Round 1	Round 1	Round 2	Round 2	Round 3	Round 3	Round 1	Round 1	Round 2	Round 2	Round 3	Round 3	Round 1	Round 1
LOCATION/SAMPLER				IEPA	IEPA	IEPA	Bethalto	IEPA	Bethalto	IEPA	Bethalto	IEPA	Bethalto	IEPA	Bethalto	IEPA	Bethalto	IEPA	Bethalto
Civic Memorial High School	8/28/2025	9/3/2025	9/11/2025			ND	ND	ND	ND	ND	ND	ND	16.8	ND	ND	ND	ND	Absent	Absent
Trimpe Middle School	8/28/2025	9/3/2025	9/11/2025			ND	ND	ND	ND	ND	51.2	16.6	26.0	ND	ND	ND	ND	Absent	Absent
119 St Mary's	8/28/2025	9/3/2025	9/11/2025	ND	139	ND	ND	ND	ND	ND	ND	26.1	22.4	ND	ND	80.2	ND	Absent	Absent
229 St Mary's	8/27/2025	9/3/2025	9/11/2025	ND	75.5	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	Absent	Absent
300 Kutter	8/28/2025	9/4/2025	9/11/2025	ND	103	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	55.1	Absent	Absent
Bethalto East School	8/28/2025	9/3/2025	9/11/2025			ND	ND	ND	ND	ND	ND	40.1	19.7	ND	ND	ND	ND	Absent	Absent
321 Jersey	8/27/2025	9/4/2025	9/11/2025	ND	518	ND	ND	ND	117	ND	ND	20.1	ND	21	17.5	ND	ND	Absent	Absent
Parkside Primary School	8/27/2025	9/3/2025	9/11/2025			ND	ND	ND	ND	ND	ND	24.1	15.9	18.9	ND	17.8	ND	Absent	Absent
Our Lady Queen of Peace School	8/27/2025	9/3/2025	9/11/2025			ND	ND	ND	ND	ND	ND	ND	ND	ND	ND	16.2	ND	Absent	Absent
Zion Lutheran School	8/27/2025	9/4/2025	9/11/2025			ND	ND	ND	ND	ND	ND	15.5	17.6	17.9	15.4	ND	ND	Absent	Absent
VILLAGE OF BETHALTO FINISHED WATER	8/26/2025	9/4/2025	9/11/2025	ND	ND	ND		ND	ND	ND	ND	41.4		21.8	23.4	40.3	23	Absent	Absent