MEMORANDUM

DATE:

September 9, 2024

TO:

Chris Davis

FROM:

Corey Branson 30F

SUBJECT:

City of Cahokia Heights - Lift Station Rehabilitation-16 Locations

Project Number(s): PSR-01 - PSR-16

I have reviewed the Contract Documents and Specifications and supporting documentation received by the Permit Section on May 10, 2024, from the Watershed Management Section for the City of Cahokia Heights. The project consists of converting six (6) existing sewage eductor lift stations and two (2) existing suction lift stations to submersible duplex lift stations. The work includes removal and replacement of lift station pumps, control panels, valves, pressure gauges, guide bars, float switches, lift cables, disconnect switches, power and alarm cables, discharge pipe, force main, wet well lids, valve vaults, access hatches, and fencing, together with a resto ration of all disturbed surfaces and all other incidental work required to complete the project.

The project has already been issued permits for the eight (8) following lift stations:

73rd Street (2024-71368).
73rd & Oakland (2024-71369).
63rd & Laura (2024-71370).
71st & Ames (2024-71371).
Beachland (2024-71372).
Lake Drive Pill Box (2024-71373).
Willie Holmes Pill Box (2024-71374).
75th & Pershing (2024-71375).

The project will not require permits for the following eight (8) lift stations since the work being performed is considered maintenance:

Cooper Drive.
LaSalle.

Williams & Ellen.

2125 S. First Street, Champaign, IL 61820 (217) 278-5800 115 S. LaSalle Street, Suite 2203, Chicago, IL 60603 1101 Eastport Plaza Dr., Suite 100, Collinsville, IL 62234 (618) 346-5120 9511 Harrison Street, Des Plaines, IL 60016 (847) 294-4000 595 S. State Street, Elgin, IL 60123 (847) 608-3131 2309 W. Main Street, Suite 116, Marion, IL 62959 (618) 993-7200 412 SW Washington Street, Suite D, Peoria, IL 61602 (309) 671-3022 4302 N. Main Street, Rockford, IL 61103 (815) 987-7760 Williams & Kay. Ellen & Richard. Hutchings Street. Donald Street. Miskell Blvd.

I find the proposed project approvable from the technical standpoint.

cc: Records Unit