

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2025

SYSTEM NAME	SYSTEM ID	RS/CR	EPA REGION	NATURE OF PROBLEM	POPULATION SERVED	LISTING DATE
AIR VIEW MHP	IL1615185	CR	1	NO BACKUP SOURCE	200	8/7/2020
ALBION	IL0470050	RS	7	MANGANESE MCL VIOLATION	2839	1/19/2022
ALEXANDER WATER DISTRICT	IL1370020	RS	5	TOTAL TRIHALOMETHANES MCL VIOLATION	140	6/21/2024
ALEXIS*	IL1874000	CR	5	INADEQUATE SOURCE CAPACITY	836	10/16/2024
ALTO PASS WATER DISTRICT	IL1815150	RS	7	INADEQUATE SOURCE CAPACITY	1015	6/30/2021
ANCHOR	IL1130050	CR	4	ONLY ONE WELL	155	8/28/2020
ANDOVER	IL0730100	RS	1	NO BACKUP SOURCE	644	3/24/2016
APPLE CREEK WATER COOP	IL1370040	RS	5	TOTAL TRIHALOMETHANES MCL VIOLATION	968	9/27/2023
AQUA ILLINOIS - HIGHLAND ESTATES	IL0915220	CR	2	ONLY ONE WELL	171	1/13/2021
AQUA ILLINOIS - INDIANOLA	IL1830500	CR	4	ONLY ONE WELL	224	12/11/2020
AQUA ILLINOIS - OAK RUN	IL0955200	RS	5	NSF/ANSI STANDARD 60 VIOLATION	1800	1/27/2023
AQUA ILLINOIS - SKYLINE	IL0915450	CR	2	ONLY ONE WELL	249	1/8/2021
AQUA ILLINOIS - SUN RIVER TERRACE	IL0910720	CR	2	ONLY ONE WELL	498	1/13/2021
ASSUMPTION*	IL0210050	RS	5	TOTAL TRIHALOMETHANES MCL VIOLATION	1315	10/23/2024
ATLANTA	IL1070050	RS	5	MINIMUM CHLORINE RESIDUAL VIOLATION	1692	3/23/2022
AVANTARA LONG GROVE	IL0971110	RS	2	INADEQUATE PRESSURE TANK	200	12/1/2003
BARBERRY ACRES MHP	IL0915145	RS	2	INADEQUATE PRESSURE TANK	50	10/4/1983
BATCHTOWN	IL0130050	RS	6	INADEQUATE STORAGE CAPACITY	290	11/14/2023
BAYLES LAKE LOT OWNERS ASSOCIATION	IL0755110	RS	4	NO ELEVATED OR GROUND STORAGE	645	12/13/2023
BEAVER CREEK VILLAGE MHP	IL0755125	CR	4	ONLY ONE WELL	48	1/6/2021
BELLMONT	IL1850100	RS	7	NO EMERGENCY GENERATOR	297	10/27/2023
BILL-MAR HEIGHTS MHP	IL2015345	RS	1	INADEQUATE PRESSURE TANK	240	3/18/1983
BLACKHAWK ESTATES LLC	IL0317765	RS	2	COMBINED RADIUM MCL VIOLATION	1238	5/24/2024
BONNIE	IL0810150	RS	7	NO ELEVATED OR GROUND STORAGE	437	7/20/2018
BROADVIEW ESTATES EAST PEORIA	IL1795365	RS	5	INADEQUATE PRESSURE TANK	89	3/18/1983
BROWNING	IL1690050	CR	5	ONLY ONE WELL	175	12/2/2020
BUCKINGHAM	IL0910250	RS	2	INADEQUATE PRESSURE TANK	300	12/15/2023

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2025

SYSTEM NAME	SYSTEM ID	RS/CR	EPA REGION	NATURE OF PROBLEM	POPULATION SERVED	LISTING DATE
BUFFALO HOLLOW FARMS WATER ASSOCIATION	IL1430080	RS	5	INADEQUATE PRESSURE TANK	45	6/16/2008
BUFFALO HOLLOW FARMS WATER ASSOCIATION	IL1430080	CR	5	ONLY ONE WELL	45	7/22/2020
BUSY BEE MHP #1	IL1975195	RS	2	INADEQUATE PRESSURE TANK	25	7/15/2022
BUSY BEE MHP #1	IL1975195	CR	2	ONLY ONE WELL	25	12/4/2020
CAMP GROVE	IL1235100	CR	1	ONLY ONE WELL	100	6/24/2020
CANTON	IL0570250	CR	5	INADEQUATE TREATMENT CAPACITY	16748	3/15/2007
CAPRON MHP	IL0075105	RS	1	INADEQUATE PRESSURE TANK	90	3/18/1983
CAPRON MHP	IL0075105	CR	1	ONLY ONE WELL	90	1/27/2021
CARBON HILL	IL0630100	CR	2	INADEQUATE TREATMENT CAPACITY	345	12/14/2016
CARBONDALE	IL0770150	RS	7	TOTAL ORGANIC CARBON REMOVAL VIOLATION	22107	9/5/2024
CARROLL HEIGHTS UTILITIES COMPANY	IL0155200	CR	1	ONLY ONE WELL	80	1/27/2021
CARTHAGE	IL0670250	CR	5	ONLY ONE WELL	2605	4/11/2023
CEDAR BROOK ESTATES SUBDIVISION	IL1615170	CR	1	ONLY ONE WELL	200	8/7/2020
CEDAR POINT WATER COMPANY	IL0995040	CR	1	ONLY ONE WELL	266	8/26/2020
CEDAR WATER COMPANY, INC.	IL0955150	CR	5	ONLY ONE WELL	172	1/13/2021
CENTRAL MACOUPIN RURAL WATER DISTRICT	IL1170040	RS	5	MINIMUM CHLORINE RESIDUAL VIOLATION	1898	8/29/2018
CENTURY PINES APARTMENTS	IL0150020	RS	1	INADEQUATE PRESSURE TANK	25	12/14/1990
CENTURY PINES APARTMENTS	IL0150020	CR	1	ONLY ONE WELL	25	1/27/2021
CHAIN-O-LAKES MHP	IL0975165	RS	2	INADEQUATE PRESSURE TANK	84	12/15/1989
CHAIN-O-LAKES MHP	IL0975165	CR	2	ONLY ONE WELL	84	8/28/2020
CHERRYDALE SUBDIVISION	IL1615120	CR	1	ONLY ONE WELL	63	8/5/2020
CHESTERFIELD	IL1170200	RS	5	MINIMUM CHLORINE RESIDUAL VIOLATION	180	8/29/2018
CHIGAKWA PARK ESTATES	IL1615140	CR	1	ONLY ONE WELL	53	8/7/2020
CLARKS MHP	IL2015425	RS	1	INADEQUATE PRESSURE TANK	90	12/16/1991
CLARKS MHP	IL2015425	CR	1	ONLY ONE WELL	90	12/4/2020
COAL CITY	IL0630200	CR	2	INADEQUATE TREATMENT CAPACITY	5749	12/14/2016
COBDEN	IL1810150	RS	7	INADEQUATE SOURCE CAPACITY	1343	6/30/2021
COLONIAL MEADOWS	IL1135100	RS	6	MINIMUM CHLORINE RESIDUAL VIOLATION	190	9/19/2018

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2025

SYSTEM NAME	SYSTEM ID	RS/CR	EPA REGION	NATURE OF PROBLEM	POPULATION SERVED	LISTING DATE
COLONIAL MEADOWS	IL1135100	CR	6	ONLY ONE WELL	190	9/26/2020
COOKS MILLS WATER ASSOCIATION	IL0295200	RS	4	INADEQUATE SOURCE CAPACITY AND INADEQUATE TREATMENT CAPACITY	600	12/29/2021
COUNTRY ACRES MHP (LA SALLE COUNTY)	IL0995365	RS	1	COMBINED RADIUM AND GROSS ALPHA MCL VIOLATIONS	222	5/26/2021
COUNTRY LANE MHP	IL1135385	CR	4	ONLY ONE WELL	50	6/24/2020
COUNTRY VIEW ESTATES MHP	IL0195625	CR	4	ONLY ONE WELL	97	1/27/2021
COUNTRY VIEW ESTATES SUBDIVISION	IL1415220	CR	1	ONLY ONE WELL	125	7/15/2020
CRISWELL COURT MHP	IL1975105	RS	2	INADEQUATE PRESSURE TANK	94	12/15/1989
DAYSRING BIBLE COLLEGE (north area)	IL0977189	RS	2	INADEQUATE PRESSURE TANK	52	6/15/1988
DE WITT	IL0390100	CR	4	ONLY ONE WELL	175	1/27/2021
DES PLAINES MHP	IL0317775	RS	2	INADEQUATE SOURCE CAPACITY, INADEQUATE PRESSURE TANK, AND GROSS ALPHA MCL VIOLATION	581	3/16/1984
DIXIE ESTATES SUBDIVISION	IL1975520	CR	2	ONLY ONE WELL	180	12/9/2020
DIXMOOR	IL0310660	RS	2	NO ELEVATED OR PRESSURE STORAGE	2973	2/24/2023
DONNY BROOK ESTATES	IL0375150	CR	1	ONLY ONE WELL	30	1/27/2021
DWIGHT	IL1050250	RS	4	ARSENIC MCL VIOLATION	4400	9/27/2023
EAGARVILLE	IL1170300	RS	5	MINIMUM CHLORINE RESIDUAL VIOLATION	127	2/23/2024
EAST END WATER ASSOCIATION	IL1610140	RS	1	INADEQUATE PRESSURE TANK	40	3/15/2002
EAST END WATER ASSOCIATION	IL1610140	CR	1	ONLY ONE WELL	40	7/31/2020
EAST LAWN WATER ASSOCIATION	IL1615100	CR	1	ONLY ONE WELL	160	8/5/2020
EAST LYNN COMMUNITY WATER SYSTEM	IL1835200	CR	4	ONLY ONE WELL	112	12/11/2020
EAST MORELAND WATER ASSOCIATION	IL1975600	RS	2	NO ELEVATED OR GROUND STORAGE	1055	9/9/2016
EAST SIDE MHP	IL0195825	CR	4	ONLY ONE WELL	95	1/27/2021
EBERTS 3RD ADDITION	IL1615330	CR	1	ONLY ONE WELL	99	8/12/2020
EDELSTEIN WATER COOPERATIVE	IL1435150	RS	5	INADEQUATE GROUND STORAGE	125	1/1/2015
EDELSTEIN WATER COOPERATIVE	IL1435150	CR	5	ONLY ONE WELL	125	7/24/2020
EDINBURG	IL0210150	RS	5	TOTAL TRIHALOMETHANES MCL VIOLATION	1068	12/16/2022

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2025

SYSTEM NAME	SYSTEM ID	RS/CR	EPA REGION	NATURE OF PROBLEM	POPULATION SERVED	LISTING DATE
EHLERS MHP	IL0195645	RS	4	INADEQUATE PRESSURE TANK	112	12/17/1982
EJ WATER - SANGCHRIS SERVICE AREA	IL1670230	RS	5	TOTAL TRIHALOMETHANES MCL VIOLATION	886	1/2/2024
EJ WATER - WITT	IL1350850	CR	5	INADEQUATE TREATMENT CAPACITY	991	3/17/2008
ELIZABETH (upper elevation area)	IL0850150	RS	1	LOW SYSTEM PRESSURE	675	6/15/1999
ELM OAK MUTUAL WATER SYSTEM	IL0975736	CR	2	ONLY ONE WELL	50	8/28/2020
EVERGREEN VILLAGE SUBDIVISION	IL1615310	CR	1	ONLY ONE WELL	130	8/12/2020
EXETER - MERRITT WATER COOP	IL1710010	RS	5	TOTAL TRIHALOMETHANES MCL VIOLATION AND INADEQUATE STORAGE CAPACITY	820	10/1/2013 & 9/4/2024
FALCON FARMS	IL1617635	RS	1	NO ELEVATED OR GROUND STORAGE	475	10/31/2019
FORD HEIGHTS	IL0310720	RS	2	MINIMUM CHLORINE RESIDUAL VIOLATION	1813	12/9/2022
FOUNTAIN WATER DISTRICT	IL1330020	CR	6	INADEQUATE SOURCE CAPACITY & INADEQUATE TREATMENT CAPACITY	3650	5/21/2024
FOUR STAR CAMPGROUND	IL0990060	RS	1	INADEQUATE PRESSURE TANK	150	6/15/1999
FOUR STAR CAMPGROUND	IL0990060	CR	1	ONLY ONE WELL	150	8/26/2020
FOX CREEK FARMS WATER COMPANY	IL1435750	CR	5	ONLY ONE WELL	221	7/29/2020
FOX LAWN HOMEOWNERS WATER ASSOCIATION	IL0935150	CR	2	ONLY ONE WELL	167	1/13/2021
FRENTRESS LAKE	IL0850010	CR	1	ONLY ONE WELL	150	1/8/2021
GARDEN STREET IMPROVEMENT ASSOCIATION	IL1975376	CR	2	ONLY ONE WELL	54	12/9/2020
GENESEO HICKORY HILLS HOA	IL0730080	CR	1	ONLY ONE WELL	93	8/12/2020
GOLCONDA	IL1510100	RS	7	INADEQUATE SOURCE CAPACITY	672	9/14/2022
GREEN ACRES MHP	IL1035165	CR	1	ONLY ONE WELL	200	8/26/2020
GREEN MEADOWS ESTATES OF ROCKFORD LLC	IL2015495	RS	1	COMBINED RADIUM MCL VIOLATION; INADEQUATE GROUND STORAGE & INADEQUATE PRESSURE TANK	970	6/15/2012
HARMON	IL1030300	CR	1	ONLY ONE WELL	149	8/26/2020
HAZELWOOD 4TH ADDITION	IL0735350	CR	1	ONLY ONE WELL	135	1/6/2021
HAZELWOOD WEST SUBDIVISION	IL0735250	CR	1	ONLY ONE WELL	70	1/6/2021
HEATHERFIELD SUBDIVISION	IL0635150	CR	2	ONLY ONE WELL	90	1/29/2021

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2025

SYSTEM NAME	SYSTEM ID	RS/CR	EPA REGION	NATURE OF PROBLEM	POPULATION SERVED	LISTING DATE
HETTICK	IL1170500	RS	5	MINIMUM CHLORINE RESIDUAL VIOLATION	182	6/30/2021
HICKORY HILLS 2ND ADDITION	IL1615450	CR	1	ONLY ONE WELL	42	7/28/2023
HIGHLAND LAKE WATER COMPANY	IL0970255	CR	2	ONLY ONE WELL	36	8/26/2020
HIGHLAND SUBDIVISON	IL0895530	RS	2	INADEQUATE PRESSURE TANK	40	9/16/1983
HIGHLAND SUBDIVISION	IL0895530	CR	2	ONLY ONE WELL	40	1/8/2021
HILLCREST	IL1410250	RS	1	INADEQUATE SOURCE CAPACITY	1400	2/13/2018
HILLCREST	IL1410250	CR	1	INADEQUATE STORAGE CAPACITY	1400	11/2/2017
HILLCREST COURT 2ND ADDITION	IL1615490	CR	1	ONLY ONE WELL	66	2/13/2024
HILLSDALE ESTATES, LLC	IL1615530	RS	1	INADEQUATE PRESSURE TANK	63	3/18/1983
HILLSDALE ESTATES, LLC	IL1615530	CR	1	ONLY ONE WELL	63	8/14/2020
HILLSDALE PROPERTIES	IL1615728	RS	1	INADEQUATE PRESSURE TANK	60	1/14/1982
HILLSDALE PROPERTIES	IL1615728	CR	1	ONLY ONE WELL	60	6/24/2020
HOLLANDS GROVE COURT SUBDIVISION	IL1795300	CR	5	ONLY ONE WELL	40	12/2/2020
HOLLY HOCK HILL MHP	IL0975245	RS	2	INADEQUATE PRESSURE TANK	52	12/16/1983
HOLLY HOCK HILL MHP	IL0975245	CR	2	ONLY ONE WELL	52	8/28/2020
HONEYCUTT HILL MHP LLC	IL1955225	RS	1	INADEQUATE PRESSURE TANK	75	9/17/1982
HOPEWELL	IL1235150	CR	1	ONLY ONE WELL	420	7/1/2020
IL AMERICAN - ANDALUSIA (upper elevation area)	IL1610050	RS	1	LOW SYSTEM PRESSURE	1050	10/1/2003
IL AMERICAN - LEONORE	IL0990400	CR	1	ONLY ONE WELL	111	8/26/2020
IL AMERICAN - MIDWEST PALOS	IL0317050	CR	2	ONLY ONE WELL	132	1/27/2021
IL AMERICAN - NETTLE CREEK	IL0630040	CR	2	ONLY ONE WELL	317	1/29/2021
IL AMERICAN - RIDGECREST	IL0635100	CR	2	ONLY ONE WELL	203	1/29/2021
IL PRAIRIE ESTATE SBDV WATER ASSN	IL0995300	CR	1	ONLY ONE WELL	112	8/26/2020
INDIAN BLUFFS SUBDIVISION	IL1615520	CR	1	ONLY ONE WELL	150	8/14/2020
INDIAN CREEK HOMEOWNERS AND WATER ASSN	IL1135250	CR	4	ONLY ONE WELL	240	6/17/2020
INGALLS PARK SUBDIVISION	IL1975880	RS	2	NO ELEVATED OR GROUND STORAGE	744	9/16/1983
IROQUOIS MOBILE ESTATES, INC.	IL0755185	CR	4	ONLY ONE WELL	105	1/8/2021

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2025

SYSTEM NAME	SYSTEM ID	RS/CR	EPA REGION	NATURE OF PROBLEM	POPULATION SERVED	LISTING DATE
JASPER WATERWORKS CORP	IL1910020	RS	7	MINIMUM CHLORINE RESIDUAL VIOLATION AND TOTAL TRIHALOMETHANES MCL VIOLATION	1483	10/28/2022
JOHNSBURG 1	IL1110040	CR	2	ONLY ONE WELL	174	8/28/2020
KENNEY	IL0390200	CR	4	ONLY ONE WELL	374	1/29/2021
KINGSTON	IL0370250	RS	1	NO OPTIMAL CORROSION CONTROL TREATMENT	1160	2/16/2022
KNOLLS EDGE SUBDIVISION	IL1415250	CR	1	ONLY ONE WELL	100	7/17/2020
LAFAYETTE	IL1750100	CR	1	ONLY ONE WELL	250	12/2/2020
LAKE LYNWOOD WATER SYSTEM	IL0735330	CR	1	ONLY ONE WELL	75	1/6/2021
LAKE OF EGYPT PWD	IL1995200	RS	7	TOTAL ORGANIC CARBON REMOVAL VIOLATION	11,368	9/5/2024
LAKE WILDWIND LLC	IL2035125	CR	1	ONLY ONE WELL	200	12/4/2020
LAND AND WATER ASSOCIATION	IL0995050	RS	1	COMBINED RADIUM MCL VIOLATION	100	8/26/2022
LAND AND WATER ASSOCIATION	IL0995050	CR	1	ONLY ONE WELL	100	8/26/2020
LASALLE	IL0990300	CR	1	INADEQUATE SOURCE CAPACITY & INADEQUATE TREATMENT CAPACITY	9700	11/1/2004
LE ROY	IL1130750	RS	4	MINIMUM CHLORINE RESIDUAL VIOLATION	3800	2/16/2024
LEWISTOWN	IL0570600	RS	5	MANGANESE MCL VIOLATION	2400	12/29/2021
LIBERTY PARK HOMEOWNERS' ASSOCIATION	IL0435600	RS	2	INADEQUATE GROUND STORAGE CAPACITY	837	9/17/1992
LICK CREEK PWD (area served by Anna - Jonesboro Water Commission)	IL1815100	RS	7	TOTAL TRIHALOMETHANES MCL VIOLATION	2191	5/3/2024
LICK CREEK PWD (area served by Lake of Egypt PWD)	IL1815100	RS	7	INADEQUATE CHLORINE RESIDUAL	2191	12/8/2023
LINDENWOOD WATER ASSOCIATION	IL1415300	CR	1	ONLY ONE WELL	35	7/22/2020
LINWAY ESTATES MHP	IL0315935	RS	2	NO ELEVATED OR GROUND STORAGE	460	2/28/2017
LISBON NORTH, INC.	IL0631000	RS	2	INADEQUATE PRESSURE TANK	25	9/14/1990
LISBON NORTH, INC.	IL0631000	CR	2	ONLY ONE WELL	25	1/29/2021
LONDON MILLS	IL0574620	RS	5	INADEQUATE SOURCE CAPACITY	400	7/13/2022
LYNN WATER ASSOCIATION	IL0735100	CR	1	ONLY ONE WELL	100	1/8/2021
LYNNWOOD WATER CORPORATION	IL0995336	RS	1	INADEQUATE PRESSURE TANK	100	3/18/1983

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2025

SYSTEM NAME	SYSTEM ID	RS/CR	EPA REGION	NATURE OF PROBLEM	POPULATION SERVED	LISTING DATE
LYNNWOOD WATER CORPORATION	IL0995336	CR	1	ONLY ONE WELL	100	8/26/2020
LYNWOOD 3RD ADDITION	IL0735280	CR	1	ONLY ONE WELL	100	1/6/2021
M C L W SYSTEM, INC.	IL1315150	CR	1	ONLY ONE WELL	98	7/10/2020
MACOMB	IL1090350	RS	5	TOTAL TRIHALOMETHANES MCL VIOLATION	15052	2/23/2024
MACOMB	IL1090350	CR	5	INADEQUATE CLARIFIER CAPACITY	15052	12/14/2016
MAEYSTOWN	IL1330200	CR	6	INADEQUATE SOURCE CAPACITY AND INADEQUATE TREATMENT CAPACITY	325	5/21/2024
MALTA	IL0370350	RS	1	NO AUTO-START GENERATOR & INADEQUATE HIGH SERVICE PUMP CAPACITY	1143	6/15/2012
MANCUSO VILLAGE PARK MHP	IL2015545	RS	1	INADEQUATE PRESSURE TANK	537	6/18/1982
MANTENO MHP	IL0915385	RS	2	INADEQUATE PRESSURE TANK	144	12/14/1990
MAPLE ACRES MHP	IL0115135	RS	1	ARSENIC MCL VIOLATION	250	2/23/2024
MAPLETON	IL1430500	RS	5	NO OPTIMAL CORROSION CONTROL TREATMENT	261	5/13/2022
MAQUON	IL0950350	CR	5	ONLY ONE WELL	284	1/13/2021
MARENGO	IL1110650	RS	2	INADEQUATE SOURCE WATER TREATMENT	7572	8/19/2022
MARSEILLES SOUTH	IL0990110	CR	1	ONLY ONE WELL	100	8/26/2020
MASON CITY	IL1250350	CR	5	INADEQUATE STORAGE CAPACITY	2558	1/1/2006
MAYFAIR SUBDIVISION	IL1795750	CR	5	ONLY ONE WELL	90	12/11/2020
MAZON	IL0630500	CR	2	NEAR A MANGANESE MCL VIOLATION	987	7/8/2022
MEADOWBROOK MH COMMUNITY	IL1635060	RS	6	TOTAL TRIHALOMETHANES AND HALOACETIC ACIDS MCL VIOLATIONS	228	4/12/2024
MILL POINT MHP	IL2035165	CR	1	ONLY ONE WELL	160	12/4/2020
MILLSTONE PWD*	IL1515050	RS	7	ARSENIC MCL VIOLATION	5565	10/16/2024
MONMOUTH*	IL1870150	RS	5	COMBINED RADIUM MCL VIOLATION	8902	10/30/2024
MOUND CITY	IL1530100	CR	7	ONLY ONE WELL	588	6/5/2020
MOUNT AUBURN	IL0210350	RS	5	TOTAL TRIHALOMETHANES MCL VIOLATION	480	2/23/2024

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2025

SYSTEM NAME	SYSTEM ID	RS/CR	EPA REGION	NATURE OF PROBLEM	POPULATION SERVED	LISTING DATE
MOUNT ERIE	IL1910350	RS	7	INADEQUATE SOURCE CAPACITY AND TOTAL TRIHALOMETHANES MCL VIOLATION	116	5/21/2021
MOUNT MORRIS ESTATES MHP	IL1415185	CR	1	ONLY ONE WELL	395	7/15/2020
MOUNT VERNON ASSOCIATION INC.	IL0855100	CR	1	ONLY ONE WELL	491	1/8/2021
MOUNT ZION	IL1150350	RS	4	TOTAL TRIHALOMETHANES MCL VIOLATION	5833	1/19/2022
NASON	IL0810350	RS	7	NO STORAGE	243	5/25/2022
NORTH HAZELWOOD SUBDIVISION	IL0735850	CR	1	ONLY ONE WELL	100	1/8/2021
NORTH HENDERSON	IL1310300	CR	1	ONLY ONE WELL	187	7/2/2020
OAK GROVE MHP - ROCK ISLAND COUNTY	IL1617785	CR	1	ONLY ONE WELL	100	12/2/2020
OAK RIDGE SD	IL2035300	RS	1	INADEQUATE PRESSURE TANK	300	3/20/1981
OAK VIEW ESTATES	IL0730120	CR	1	ONLY ONE WELL	95	1/29/2021
OAKWOOD WEST SUBDIVISION	IL0730070	CR	1	ONLY ONE WELL	57	1/29/2021
OPHIEM PWS	IL0735150	CR	1	ONLY ONE WELL	100	1/8/2021
OSCO MUTUAL WATER SUPPLY COMPANY, INC.	IL0735200	RS	1	INADEQUATE PUMP CAPACITY	115	12/15/1989
OTTAWA ESTATES MHP	IL0995225	RS	1	INADEQUATE PRESSURE TANK	70	3/18/1983
OTTAWA ESTATES MHP	IL0995225	CR	1	ONLY ONE WELL	70	8/26/2020
PARADISE MANOR MHP	IL1617665	CR	1	ONLY ONE WELL	200	11/20/2020
PARK MEADOWLAND WEST MHP	IL0075235	CR	1	ONLY ONE WELL	100	1/27/2021
PAULS MHP	IL0975485	RS	2	INADEQUATE PRESSURE TANK	38	12/16/1983
PAULS MHP	IL0975485	CR	2	ONLY ONE WELL	38	8/28/2020
PEORIA HEIGHTS	IL1434750	RS	5	MANGANESE MCL VIOLATION	5908	12/29/2021
PHIL-AIRE ESTATES MHP	IL2015625	CR	1	ONLY ONE WELL	80	12/4/2020
POLO DR AND SADDLE RD SUBDIVISION	IL0437000	RS	1	INADEQUATE CHLORINE RESIDUAL AND NO EMERGENCY POWER	93	1/26/2024
POLO DR AND SADDLE RD SUBDIVISION	IL0437000	CR	1	ONLY ONE WELL	93	1/29/2021
PORT BARRINGTON SHORES SUBDIVISION	IL0971120	CR	2	ONLY ONE WELL	67	8/26/2020
PORT BYRON	IL1610550	RS	1	MANGANESE MCL VIOLATION	1678	1/19/2022
PORTS SULLIVAN LAKE OWNERS' ASSOCIATION	IL0971160	RS	2	INADEQUATE PRESSURE TANK	293	6/15/1999
POWERS WATER CO., INC	IL0895550	CR	2	ONLY ONE WELL	214	1/8/2021

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2025

SYSTEM NAME	SYSTEM ID	RS/CR	EPA REGION	NATURE OF PROBLEM	POPULATION SERVED	LISTING DATE
PRAIRIE OAKS ESTATES HOMEOWNERS' ASSOCIATION	IL0630060	CR	2	ONLY ONE WELL	107	1/29/2021
PRAIRIE PATH WATER - BAHL WATER COMPANY	IL0855200	RS	1	NO ELEVATED OR GROUND STORAGE	700	12/15/1993
PRAIRIE PATH WATER - CAMELOT	IL1975200	CR	2	ONLY ONE WELL	575	12/9/2020
PRAIRIE PATH WATER - CHERRY HILL WATER COMPANY	IL1975280	CR	2	ONLY ONE WELL ONLY ONE WELL PER DISTRIBUTION SYSTEM	624	12/9/2020
PRAIRIE PATH WATER - ROCKVALE*	IL1415350	CR	1	ONLY ONE WELL PER DISTRIBUTION SYSTEM	298	10/10/2024
PRAIRIE PATH WATER - WALK-UP WOODS WATER COMPANY	IL1115800	RS	2	NO ELEVATED OR GROUND STORAGE	781	12/17/1982
PRAIRIE ROAD PUMP ASSOCIATION	IL2015100	RS	1	INADEQUATE PRESSURE TANK MINIMUM CHLORINE RESIDUAL VIOLATION	150	1/1/2006
QUAIL RUN MHP	IL1190270	RS	6	INADEQUATE PRESSURE TANK	168	2/9/2024
RAINBOW LANE MHP	IL2015645	RS	1	INADEQUATE PRESSURE TANK	83	6/17/1983
RAINBOW LANE MHP	IL2015645	CR	1	ONLY ONE WELL	83	12/4/2020
RAINBOW RIDGE	IL1615580	CR	1	ONLY ONE WELL	46	8/14/2020
REDDICK	IL0914780	RS	2	COMBINED RADIUM MCL VIOLATION	196	2/23/2024
REDDICK	IL0914780	CR	2	ONLY ONE WELL	196	1/8/2021
RIDGEWOOD LEDGES WATER ASSOCIATION	IL1615670	CR	1	ONLY ONE WELL	300	6/24/2020
RIO	IL0950450	RS	5	NSF/ANSI STANDARD 60 VIOLATION	265	11/3/2023
ROCKLAND MHP	IL0975585	RS	2	INADEQUATE PRESSURE TANK	165	12/16/1983
ROLLING GREEN ESTATES MHP	IL1415245	CR	1	ONLY ONE WELL	191	7/17/2020
ROLLING MEADOWS MHC	IL1415265	CR	1	ONLY ONE WELL	447	3/19/2024
ROYAL OAKS MHP	IL1115145	RS	2	INADEQUATE PRESSURE TANK	131	6/17/1983
RUSTIC ACRES WATER ASSOCIATION	IL0735500	CR	1	ONLY ONE WELL	260	1/6/2021
SANTA FE ESTATES WATER ASSOCIATION	IL1435490	CR	5	ONLY ONE WELL	84	7/29/2020
SCALES MOUND	IL0850400	RS	1	LOW SYSTEM PRESSURE (at elev. above 990 ft. MSL)	376	9/15/1997
SEATON	IL1310350	CR	1	ONLY ONE WELL	200	7/2/2020
SECOR	IL2030600	RS	1	ARSENIC MCL VIOLATION	400	11/8/2023
SENECA MOBILE HOMES LLC	IL0995425	RS	1	INADEQUATE PRESSURE TANK	10	9/17/1982
SENECA MOBILE HOMES LLC	IL0995425	CR	1	ONLY ONE WELL	10	8/26/2020

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2025

SYSTEM NAME	SYSTEM ID	RS/CR	EPA REGION	NATURE OF PROBLEM	POPULATION SERVED	LISTING DATE
SHANGRI-LA MHP	IL1415285	RS	1	INADEQUATE PRESSURE TANK	450	9/16/1983
SHERIDAN CORRECTIONAL CENTER	IL0995840	CR	1	INADEQUATE TREATMENT CAPACITY	1800	1/27/2023
SILVIS HEIGHTS WATER CORP	IL1615750	RS	1	NO EMERGENCY GENERATOR	1460	12/1/2003
SIX OAKS MHP	IL2015685	RS	1	INADEQUATE PRESSURE TANK	48	6/18/1982
SIX OAKS MHP	IL2015685	CR	1	ONLY ONE WELL	48	12/4/2020
SOUTH JACKSONVILLE	IL1370400	RS	5	INADEQUATE SOURCE CAPACITY	3508	8/19/2022
SOUTH PEKIN	IL1790650	RS	5	MANGANESE MCL VIOLATION	1146	1/19/2022
SPIN LAKE HOMEOWNERS' ASSOCIATION	IL1135140	RS	4	NITRITE MCL VIOLATION	200	10/1/2021
SPIN LAKE HOMEOWNERS' ASSOCIATION	IL1135140	CR	4	ONLY ONE WELL	200	6/16/2020
SPRING VALLEY*	IL0111000	RS	1	ONLY ONE WELL	5582	11/1/2024
STEELEVILLE*	IL1570650	RS	6	COMBINED RADIUM MCL VIOLATION	1930	10/23/2024
STELLE COMMUNITY ASSOCIATION	IL0535100	CR	4	ONLY ONE WELL	100	1/29/2021
STEPHENSON MOBILE ESTATES	IL1775235	RS	1	INADEQUATE PRESSURE TANK AND INADEQUATE CHLORINE RESIDUAL	223	6/17/1983
STONEWOOD EDGEWOOD TERRACE LLC	IL1795345	RS	5	INADEQUATE CHLORINE RESIDUAL	248	10/28/2022
STORYBOOK HIGHLANDS	IL0935250	CR	2	ONLY ONE WELL	100	1/13/2021
STRATFORD WEST APARTMENTS	IL1095200	CR	5	ONLY ONE WELL	44	8/26/2020
STRAWN	IL1050700	CR	4	ONLY ONE WELL	133	8/26/2020
SUBURBAN APARTMENTS (DE KALB UNIV DVL)**	IL0375148	CR	1	INADEQUATE PRESSURE TANK	1050	12/16/1992
SUBURBAN HEIGHTS SUBDIVISION	IL1615800	CR	1	ONLY ONE WELL	60	11/20/2020
SUNNY HILLS ESTATES SUBDIVISION	IL0735300	RS	1	INADEQUATE PRESSURE TANK	525	6/15/2000
SUNNYLAND SUBDIVISION**	IL1977730	RS	2	INADEQUATE SOURCE CAPACITY	300	6/12/2018
SWEDONA WATER ASSOCIATION	IL1315200	RS	1	INADEQUATE PRESSURE TANK	110	6/15/1990
SYLVAN LAKE 1ST SUBDIVISION	IL0977100	RS	2	INADEQUATE PRESSURE TANK	210	6/14/1991
TENNANTS SHADY OAKS SUBDIVISION	IL1615540	CR	1	ONLY ONE WELL	44	8/14/2020
TIMBER BROOK ESTATES	IL0735450	CR	1	ONLY ONE WELL	120	1/6/2021
TIMBER RIDGE MOBILE ESTATES	IL1775255	RS	1	INADEQUATE PRESSURE TANK	150	6/17/1996
TIMBER RIDGE SUBDIVISION	IL0735470	CR	1	ONLY ONE WELL	90	1/6/2021
TISKILWA	IL0111050	CR	1	INADEQUATE STORAGE CAPACITY	740	9/20/2017
TOWER RIDGE SUBDIVISION	IL1615780	CR	1	ONLY ONE WELL	70	11/20/2020
TOWNERS SUBDIVISION	IL0977250	RS	2	INADEQUATE PRESSURE TANK	206	1/14/1982

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2025

SYSTEM NAME	SYSTEM ID	RS/CR	EPA REGION	NATURE OF PROBLEM	POPULATION SERVED	LISTING DATE
VALLEY VIEW MANOR	IL0195865	RS	4	ARSENIC MCL VIOLATION	120	3/12/2024
VALLEY VIEW MANOR	IL0195865	CR	4	ONLY ONE WELL	120	1/27/2021
VALMEYER	IL1330250	CR	6	INADEQUATE SOURCE CAPACITY AND INADEQUATE TREATMENT CAPACITY	1263	5/21/2024
VAN ORIN WATER COMPANY	IL0115000	CR	1	ONLY ONE WELL	100	1/27/2021
VANDALIA	IL0510350	RS	6	HALOACETIC ACIDS MCL VIOLATION	7458	9/5/2024
VERMONT	IL0570950	RS	5	TOTAL TRIHALOMETHANE MCL VIOLATION & HALOACETIC ACID MCL VIOLATION	738	5/27/2020
VICTORIA	IL0950550	CR	5	ONLY ONE WELL	316	1/13/2021
WALTONVILLE	IL0810400	RS	7	LOW SYSTEM PRESSURE AND NOT MEETING STORAGE, PUMPING, AND EMERGENCY GENERATOR REQUIREMENTS	1901	5/25/2022
WATER WERKS	IL1615130	CR	1	ONLY ONE WELL	43	8/5/2020
WATERMAN	IL0370600	CR	1	ONLY ONE WELL	1506	1/27/2021
WEATHERSTONE LAKES MHP	IL0312800	RS	2	INADEQUATE CHLORINE RESIDUAL	221	1/19/2024
WESTFIELD	IL0230200	RS	4	NO OPTIMAL CORROSION CONTROL TREATMENT	678	2/16/2022
WHITE HALL	IL0610400	CR	6	INADEQUATE STORAGE CAPACITY	2900	10/1/2012
WILLOWAY TERRACE MHP	IL0317595	RS	2	NO ELEVATED OR GROUND STORAGE & INADEQUATE SOURCE CAPACITY	900	6/15/1984
WINDCREST SUBDIVISION	IL0730040	CR	1	ONLY ONE WELL	40	1/29/2021
WINDING CREEK ESTATES	IL1615850	CR	1	ONLY ONE WELL	144	11/20/2020
WINSLOW	IL1770550	CR	1	ONLY ONE WELL	350	12/2/2020
WOOD DALE ESTATES	IL0437245	RS	2	INADEQUATE PRESSURE TANK	145	6/17/1983
WOODLAND	IL0751000	RS	4	INADEQUATE SOURCE CAPACITY	319	7/15/2022
YATES CITY	IL0950700	CR	5	ONLY ONE WELL	828	1/13/2021
YOUNGS HILLCREST MHP	IL0190040	CR	4	ONLY ONE WELL	34	1/27/2021

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2025

WATER SYSTEMS REMOVED FROM PREVIOUS LIST

ANNA
AQUA ILLINOIS - NUNDA
ARCADIA CARE
BARDOLPH
BECKWITH COMMUNITY ASSOCIATION
BEECHER CITY
BISHOP HILL
BROWNSTOWN
CHENOA
COMPTON
COYNE CENTER COOP
DANVERS
DONOVAN
ESQUIRE ESTATES MHP
GERMANTOWN
HARVEST ESTATES
LAKE SHANNON
MARK
MC NABB
MEADOWS MENNONITE HOME
MOUND PWD
NEPONSET
NEW HOPE WATERWORKS CORP.
QUINCY
TABLE GROVE
VILLAGE GREEN MHP
WINDSOR

**Illinois Environmental Protection Agency
Division of Public Water Supplies
Restricted Status / Critical Review Combined List**

January 2025

***WATER SYSTEMS ADDED**

ALEXIS
ASSUMPTION
MILLSTONE PWD
MONMOUTH
PRAIRIE PATH WATER - ROCKVALE
SPRING VALLEY
STEELEVILLE

****WATER SYSTEM UPDATES**

COUNTRY VIEW ESTATES SUBDIVISION (removed from restricted status
only)
SUBURBAN APARTMENTS (DE KALB UNIV DVL)
SUNNYLAND SUBDIVISION